

EM133

TOU SMART ENERGY METER



SATEC EM133 is a Smart DIN Rail TOU Energy Meter. It is based on SATEC's best seller PM130 PLUS with an off-the-shelf LCD display (similar to the BFM136 display). The EM133 provides the full functionality of the PM130EH PLUS combined with 2 Digital Inputs, 1 Digital Output, IR (Infra Red) communication and battery backup for the real time clock. It is fully compatible with all PM130 PLUS modules.

The EM133 can serve any application from residential energy metering, through industrial energy and harmonic analysis through utility comprehensive substation automation. It provides multifunctional 3-phase power metering, revenue metering and basic power quality information. The EM133 features an internal real time clock (RTC), battery backup and onboard non-volatile memory for event and data logging. The device includes 16 set points and 4 counters that operate the built in 2 DI/ 1RO or the various analog and digital I/O add-ons.

The EM133 offers a wide range of network configurations and versatile voltage and current connections: 57 to 400V AC, up to 63A direct current measurement, connection of standard CTs (1A, 5A) and a wide range of remote CTs (split or solid cores).

Main Features

Multifunctional 3-Phase Smart Meter

- True RMS, volts, amps, power, power factor, neutral current, voltage and current unbalance, frequency
- Ampere/Volt demand meter
- 25, 50, 60 and 400 Hz measurements
- 128 samples per cycle

Billing/TOU Energy Meter

- Accuracy Class 0.5S per IEC 62053-22
- MID certified EN50470-3 Class B or C (5A)
- Four-quadrant active and reactive energy poly-phase static meter
- Three-phase total and per phase energy measurements; active, reactive and apparent energy counters
- Time-of-Use, 4 totalization and tariff energy/demand registers x 8 tariffs, 4 seasons x 4 types of days, 8 tariff changes per day
- One-time easy programmable tariff calendar schedule
- Automatic daily energy and maximum demand profile log for total and tariff registers

Заличено по чл.2 от ЗЗЛД

Harmonic Analyzer

- Voltage and current THD, TDD and K-Factor, up to 40th order harmonic
- Voltage and current harmonic spectrum and angles

Real-time Waveform Capture (via PC)

- Real-time "scope mode" waveform monitoring capability
- Simultaneous 6-channel 8-cycle waveform capture at a rate of 64 samples per cycle

Programmable Logical Controller

- Embedded programmable controller
- 16 control set points; programmable thresholds and delays
- Relay output control
- 1-cycle response time

Event and Data Recording

- Non-volatile memory for long-term event and data recording for at least 90 days history storage capabilities
- Event recorder for logging internal diagnostic events and setup changes
- Two data recorders; programmable data logs on a periodic basis; automatic daily energy and maximum demand profile log

Display

- Easy to read 2 x 16 Characters LCD display, adjustable update time
- Auto-scroll option with adjustable page exposition time; auto-return to a default page

Real-time Clock

- Backup for 260 days

Inputs/Outputs

- Built-in 2 Digital Inputs and 1 form A solid state digital output
- Optional module 8 Digital Inputs
- Optional module 4 Digital Inputs and 2 digital outputs (Solid State or Electro Mechanical)
- Optional module 12 Digital Inputs and 4 digital outputs with optional Ethernet, RS-485 or CAN
- Optional module 4 Analog Outputs

Communications

- Standard 2-wire RS-485 communication port
- Built-in IR communication port
- Optional multipurpose RS-232/422/485 port
- Optional 10/100Base T port
- Optional PROFIBUS port
- Optional RF module (available in certain regions only)
- Optional 2G/3G modem
- Optional CANopen port

Communication protocols

- Modbus RTU
- SATEC ASCII
- DNP 3.0
- IEC 60870-5-101 (option)
- IEC 60870-5-104 (option)

Meter Security

- 3 levels Password security for protecting meter setups and accumulated data from unauthorized changes

Upgradeable Firmware

- Easy upgrading device firmware through a serial or Ethernet port.

Software Support

- Includes comprehensive Power Analysis Software (PAS) for configuration and data acquisition
- Optional ExpertPower™ client for communicating with the SATEC proprietary ExpertPower™ Internet services

Заличено по чл.2 от ЗЗЛД

Specifications

VOLTAGE INPUTS

Voltage Connections	3 phases, 1 Neutral
Voltage Ratings	Direct voltage connection: → 220 to 400V (L-N) → 380 to 690V (L-L) → Range 0-800VAC Via PT (Power Transformer): → 57.7 to 120V (L-N) → 100 to 207V (L-L) → Range 0-250VAC
Starting Voltage	0.2% U_N
Input Impedance	$\geq 1M\Omega$
Burden with Aux. Power supply	$\leq 0.2VA/phase$
Overload withstand	4000 VAC (L-G) for 1 min.
Impulse Voltage	6kV
Terminal Blocks	4 Sealed, pitch 7-10mm 2.5 to 4 mm ²

CURRENT INPUTS

Current Connections	3 galvanic isolated inputs
Current Ratings	Choice of 4 options: → ../5A CT connection → ../1A CT connection → Direct up to 100A → Remote CT (40mA)
Starting Current	0.2% I_N
Burden per phase	$< 0.2 VA$ (../5A) $< 0.05 VA$ (../1A)
Overload (continuous)	$2 \times I_N$ ($1.2 \times I_N$ for 100A model)
Over current	$50 \times I_N$ (for 1 second)
Galvanic isolation	4000 VAC (L-G) for 1 min.
Terminal Blocks	6 Sealed, pitch 7-10mm 4 to 16 mm ²

AUXILIARY POWER SUPPLY

Rated Input	40-300 V AC/DC
Insulation Dielectric withstand	4000 VAC for 1 min.
Output power	4W
Terminal Blocks	2 Sealed, pitch 7-10mm 2.5 to 4 mm ²

BUILT IN COMMUNICATION

Communication Type	RS-485
Max. Baud Rate	115.2 kb/s
Isolation	4000 VAC (L-G) for 1 min.
Max. Cable Length	1000 m
Protocols	MODBUS RTU/ASCII DNP 3.0 IEC 60870 -5-101 (option) IEC 60870 -5-104 (option)
Terminal Blocks	3 Sealed, pitch 7-10mm 2.5 to 4 mm ²

INFRA RED COMMUNICATION

Baud rate	Up to 19.200 kb/s
Protocols	MODBUS RTU/ASCII

ADD-ON MODULES

Max. # of Modules	1
Available Modules	RS-232; PROFIBUS; ETHERNET; Digital I/O; Analog Outputs

FRONT PANEL

Display type	2x16 Characters Transflective LCD with backlight
Character size	3.2x1.85 mm
Viewing area	46x11 mm
LEDs	Total 6 LEDs: → 1 Pulse calibration output → 3 voltage indication → 2 RX/TX activity
Keypad	2 buttons
Nameplate	According to IEC 60688 and IEC 62052-11

MECHANICAL

Enclosure	DIN Rail mount Complies with EN50022
Dimensions [WxHxD]	125 x 90 x 75mm
Enclosure Material	Reinforced Polycarbonate

TEMPERATURE

Operational	-25°C to 60°C
Storage	-30°C to 85°C

Залічено по чл.2 от ЗЗЛД

Standards Compliance specifications

EMC per IEC 60688 and IEC 62052-11:

Immunity:

- IEC61000-4-2: Electrostatic discharge, 15/- air/contact
- IEC61000-4-3: Electromagnetic RF Fields, 10V/m @ 80Mhz – 1000MHz
- IEC61000-4-4: Fast Transients burst, 4KV on current and voltage circuits and 2 KV for auxiliary circuits
- IEC61000-4-5: Surge 4KV on current and voltage circuits and 1 KV for auxiliary circuits
- IEC61000-4-6: Conducted Radio-frequency, 10V @ 0.15Mhz – 80MHz
- IEC61000-4-8: Power Frequency Magnetic Field

Emission (radiated/conducted):

- EN55022: 2010 Class A (CISPR 22)
- FCC p.15 Class A mandatory

Safety

- UL/IEC 61010-1
- UL 916

Insulation

- IEC 62052-11: Insulation impulse 6KV/500Ω @ 1.2/50 μs
- IEC 62053-22: AC voltage tests related to ground, 4 kV AC @ 1mn, for power and signal ports (above 40V)
- 2.5KVAC r.m.s. @ 1mn, for other ports (below 40V)

Atmospheric Environment

- Operational ambient temperature range: -25°C to +60 °C
- Long-term damp heat withstand according to IEC 68-2-3 <95% (non condensing), +40 °C
- Transport and storage temperature range: -30°C to +85 °C
- IEC 60068-2-6: Vibration
- Frequency range: 10Hz to 150Hz
- Transition frequency: 60Hz
- Constant movement amplitude 0.075mm, f<60Hz
- Constant acceleration 9.8 m/s² (1g), f > 60Hz
- Additional Transport vibration and shocks:
- Longitudinal acceleration: 2.0 g
- Vertical acceleration: 1.2 g
- Transversal acceleration: 1.2 g
- Enclosure protection: IP20

Accuracy according to:


- IEC 62053-22, class 0.5S – active energy
- IEC 62053-21, class 0.5 – reactive energy
- IEC 60688, class 0.5S – active energy
- IEC 60688, class 1 – reactive energy
- EN 50470-3, class B or C (5A version)

Заличено по чл.2 от ЗЗЛД

Order String

OPTIONS	
Current Inputs	
5 Ampere (MID Certified)	5
1 Ampere	1
Direct current measurement up to 63A	63
High Accuracy Current Sensors (HACS). Requires ordering of 3 HACS - please refer to SATEC's HACS Datasheet.	HACS
5A split core remote high accuracy current sensor (HACS), 50/60Hz only	RS5
Calibration at Frequency	
25 Hz	25HZ
50 Hz	50HZ
60 Hz	60HZ
400 Hz	400HZ
Resolution	
Low Resolution 1A, 1V	-
High Resolution 0.01A, 0.1V	H
Power Supply	
40-300V AC/DC (MID Certified)	ACDC
Powered from measured voltages (120-277 V L-N), only for 50/60Hz	SE
12V/24V DC power supply	21DC
Communication Protocol	
Modbus and DNP 3.0	-
Modbus and IEC 60870-101/104	870
Testing and Certificate	
Full functional test, calibration at various workloads & detailed test report	-
Full functional test, calibration at various workloads & detailed test report plus ISO 17025 and ILAC certified calibration certificate	CC

EM133



Заличено по чл.2 от ЗЗЛД

Expansion Module (Max 1 module per instrument, can be ordered separately)

4 Analog Outputs: ±1mA	AO1
4 Analog Outputs: 0-20mA	AO2
4 Analog Outputs: 0-1mA	AO3
4 Analog Outputs: 4-20mA	AO4
4 Analog Outputs: 0-3mA	AO5
4 Analog Outputs: ±3mA	AO6
4 Analog Outputs: 0-5mA	AO7
4 Analog Outputs: ±5mA	AO8
Communication: Ethernet (TCP/IP)	ETH
Communication: PROFIBUS	PRO
Communication: RS232 (for DIN rail enclosure)	RS232D
Communication: RS232/422/485	RS232
Communication: 2G/3G GSM Modem (Doesn't support 870 protocol)	T3G
Communication: 2G/3G CDMA Modem (Doesn't support 870 protocol)	T3C
Communication: CAN Bus (EM133 only, doesn't support 870 protocol)	CAN
Communication: RF (available in certain regions only – contact your SATEC partner for available options)	RF-x-y
4 Digital Inputs (Dry Contact) / 2 Relay Outputs 250V / 5A AC	DIOR
4 Digital Inputs (Dry Contact) / 2 SSR Outputs 250V / 0.1A AC	DIOS
8 Digital Inputs (Dry Contact - Not Compatible with EM133-AR)	8DI
12 Digital Inputs (Dry Contact) / 4 Relay Outputs 250V/5A AC	12DIOR-DRC
12 Digital Inputs (125VDC) / 4 Relay Outputs 250V/5A AC	12DIOR-125V
12 Digital Inputs (250VDC) / 4 Relay Outputs 250V/5A AC	12DIOR-250V
12DIOR-DRC with Ethernet	12DIOR-DRC-ETH
12DIOR-125V with Ethernet	12DIOR-125V-ETH
12DIOR-250V with Ethernet	12DIOR-250V-ETH
12DIOR-DRC with RS-485	12DIOR-DRC-485
12DIOR-125V with RS-485	12DIOR-125V-485
12DIOR-250V with RS-485	12DIOR-250V-485
12DIOR-DRC with CANopen	12DIOR-DRC-CAN
12DIOR-125V with CANopen	12DIOR-125V-CAN
12DIOR-250V with CANopen	12DIOR-250V-CAN

Заличено по чл.2 от ЗЗЛД



ENVIRONMENTAL & MECHANICAL LABORATORY

TEST REPORT

ENERGY POWER METER

For

SII

21/08/2014

Report No: 20140818-1524

Report Edition: 01

Report Status: Released

This document cor
QualiTech and othe
party without prior written consent of QualiTech

Заличено по чл.2 от ЗЗЛД

ВЛГНО 0 01

Handwritten signature

ENVIRONMENTAL & MECHANICAL LABORATORY DETAILS

Name:	Environmental & Mechanical Lab.
Address:	30, Hasivim St., Petach Tikva, Israel, 4959388.
Phone No.:	972-3-9266170. 972-3-9268810.
Fax No.:	972-3-9268811.
E-Mail:	eli.avital@ecitele.com

CUSTOMER DETAILS

Company Name:	SII
Representative	Leonid Fine
Address:	42 Haim Levanon St., Tel Aviv 69977.
Phone No.:	03-6367635
Fax No.:	03-6467779
E-Mail:	leon_fine@sii.org.il

Handwritten signature

Заличено по чл.2 от ЗЗЛД

Handwritten initials

DOCUMENT CONTROL




DOCUMENT HISTORY

The following table records information regarding released editions of this document and briefly describes their file location, purpose, and changes made to them.

Edition ID	Release Date	Responsible Author	File Reference, Purpose and Description of Changes
01	21/08/2014	Dina Klebansky	File Reference: W:\Reports\TR\Proj2014\SII ENERGY POWER METER 2014-07-23.doc Purpose: Changes:

DOCUMENT APPROVALS

This edition has been approved by:

	Name	Title	Signature	Date
Compiled	Dina Klebansky	Technical Writer	 Заличено по чл.2 от ЗЗЛД	21/08/2014
Tested	Zion Asslizada	Test Engineer	 Заличено по чл.2 от ЗЗЛД	21/08/2014
Approved	Eli Avital	Environmental, HALT and HASS Labs Manager	 Заличено по чл.2 от ЗЗЛД	21/08/2014


OPEN ISSUES

This part of the document control section is used to record and track open issues and/or unresolved questions. As the development of this document proceeds, these issues and questions should be resolved and then removed from the list.

No.	Subject/Section	Description
1.		
2.		

Заличено по чл.2 от ЗЗЛД

Handwritten signature

Handwritten signature


W/M

EXECUTIVE SUMMARY

The following table summarizes the tests that have been performed in QualiTech - Environmental & Mechanical Laboratory.

SII had performed the functional tests and the tests results are his sole responsibility.

The stated results apply only to the specific UUT that were currently tested.

No.	Test Name	Pass /Fail	Job Number	Notes
1.	Sine Vibration Test	Pass	14/2487	
2.	Mechanical Shock Test	Pass	14/2488	
3.	High Temperature (Dry Heat- Storage) Test	Pass	14/2489	
4.	Low Temperature (Storage) Test	Pass	14/2518	
5.	Temperature and Humidity (Damp Heat-Operation) Test	Pass	14/2519	
6.	Immunity to Voltage Surge Test	Pass	14/2628	Performed by EMC Lab.
7.	Temperature Cycling (Storage & Operation) Test	Pass	14/2631	

Statement of Compliance with test requirements:

QualiTech - Environmental & Mechanical Lab. declare that the UUT ENERGY POWER METER was tested to comply with the requirements of the applicable environmental test specification.

Customer granted the permission to reproduce and distribute this report only in the full format with no change and no addition.

A2LA symbol in the front page is applicable only to the tests under the scope of QualiTech accreditations.

QualiTech has A2LA accreditation to ISO/IEC 17025:2005 for test types as listed in the following link:
<http://www.a2la.org/scopepdf/1881-01.pdf>

Заличено по чл.2 от ЗЗЛД

TABLE OF CONTENTS

1. INTRODUCTION	7
1.1. PURPOSE	7
1.2. GLOSSARY	7
1.3. APPLICABLE DOCUMENTS	7
2. UUT DESCRIPTION	8
3. SINE VIBRATION TEST - 14/2487	9
3.1. UNIT UNDER TEST OVERVIEW	9
3.2. TECHNICAL SOURCE	9
3.3. TEST INSTRUMENTATION	9
3.4. LAB'S ENVIRONMENTAL CONDITIONS	9
3.5. TEST PROCEDURE	9
3.5.1. EXCLUSIONS FROM THE TEST METHOD	9
3.5.2. VIBRATION TEST PROCEDURE DESCRIPTION	10
3.5.3. TEST PERFORMANCE	10
3.5.4. TEST PICTURES	10
3.5.5. TEST GRAPHS	12
3.5.6. ACCELEROMETERS LIST	13
3.5.7. MEASUREMENT POINTS DESCRIPTION	13
3.6. TEST RESULTS	13
4. MECHANICAL SHOCK TEST - 14/2488	14
4.1. UNIT UNDER TEST OVERVIEW	14
4.2. TECHNICAL SOURCE	14
4.3. TEST INSTRUMENTATION	14
4.4. LAB'S ENVIRONMENTAL CONDITIONS	14
4.5. TEST PROCEDURE	14
4.5.1. EXCLUSIONS FROM THE TEST METHOD	14
4.5.2. MECHANICAL SHOCK TEST PROCEDURE DESCRIPTION	15
4.5.3. TEST PERFORMANCE	15
4.5.4. TEST PICTURES	15
4.5.5. TEST GRAPHS	17
4.5.6. ACCELEROMETERS LIST	25
4.5.7. MEASUREMENT POINTS DESCRIPTION	25
4.6. TEST RESULTS	25
5. DRY HEAT (Storage) TEST - 14/2489	26
5.1. UNIT UNDER TEST OVERVIEW	26
5.2. TECHNICAL SOURCE	26
5.3. TEST INSTRUMENTATION - TEMPERATURE CHAMBER	26
5.4. LAB'S ENVIRONMENTAL CONDITIONS	26
5.5. TEST PROCEDURE	26
5.5.1. EXCLUSIONS FROM THE TEST METHOD	26
5.5.2. HIGH TEMPERATURE TEST PROCEDURE DESCRIPTION	26
5.5.3. TEST PERFORMANCE	27
5.5.4. TEST PICTURES	27
5.5.5. TEST GRAPHS	28
5.6. TEST RESULTS	28
6. LOW TEMPERATURE (Storage) TEST - 14/2518	29
6.1. UNIT UNDER TEST OVERVIEW	29
6.2. TECHNICAL SOURCE	29
6.3. TEST INSTRUMENTATION - TEMPERATURE CHAMBER	29
6.4. LAB'S ENVIRONMENTAL CONDITIONS	29
6.5. TEST PROCEDURE	29
6.5.1. EXCLUSIONS FROM THE TEST METHOD	29
6.5.2. LOW TEMPERATURE TEST PROCEDURE DESCRIPTION	29
6.5.3. TEST PERFORMANCE	30
6.5.4. TEST PICTURES	30
6.5.5. TEST GRAPHS	31
6.6. TEST RESULTS	31
7. HIGH TEMPERATURE (DUMP HEAT -Operation) TEST - 14/2519	32
7.1. UNIT UNDER TEST OVERVIEW	32
7.2. TECHNICAL SOURCE	32
7.3. TEST INSTRUMENTATION - TEMPERATURE & HUMIDITY CHAMBER	32
7.4. LAB'S ENVIRONMENTAL CONDITIONS	32

Заличено по чл.2 от ЗЗЛД

QUALITECH

7.5.	TEST PROCEDURE.....	32
7.5.1.	EXCLUSIONS FROM THE TEST METHOD.....	32
7.5.2.	TEMPERATURE & HUMIDITY TEST PROCEDURE DESCRIPTION.....	32
7.5.3.	TEST PERFORMANCE.....	33
7.5.4.	TEST PICTURES.....	33
7.5.5.	TEST GRAPHS.....	34
7.6.	TEST RESULTS.....	34
8.	IMMUNITY TO VOLTAGE SURGE TEST - 14/2628.....	35
8.1.	UNIT UNDER TEST OVERVIEW.....	35
8.2.	IMMUNITY TO VOLTAGE SURGE TEST.....	35
8.2.1.	TEST METHOD: EN61000-4-5.....	35
8.2.2.	TEST PROCEDURE:.....	35
8.2.3.	LIST OF TEST EQUIPMENT:.....	35
8.2.4.	TEST RESULTS:.....	36
8.2.5.	TEST PICTURES.....	36
9.	TEMPERATURE CYCLING (Storage & Operation) TEST - 14/2631.....	39
9.1.	UNIT UNDER TEST OVERVIEW.....	39
9.2.	TECHNICAL SOURCE.....	39
9.3.	TEST INSTRUMENTATION - TEMPERATURE CHAMBER.....	39
9.4.	LAB'S ENVIRONMENTAL CONDITIONS.....	39
9.5.	TEST PROCEDURE.....	39
9.5.1.	EXCLUSIONS FROM THE TEST METHOD.....	39
9.5.2.	TEMPERATURE CYCLING TEST PROCEDURE DESCRIPTION.....	40
9.5.3.	TEST PERFORMANCE.....	40
9.5.4.	TEST PICTURES.....	41
9.5.5.	TEST GRAPHS.....	42
9.6.	TEST RESULTS.....	42
10.	PARAMETERS ACCURACY & UNCERTAINTY BALANCE.....	43

ВАРИАНТ А ОБЯЗАТЕЛНА



Заличено по чл.2 от ЗЗЛД

Handwritten mark

1. INTRODUCTION

1.1. PURPOSE

The purpose of this report is to outline the test results of the ENERGY POWER METER, which was tested according to the applicable documents (see section 1.3), at ECI Telecom Environmental & Mechanical Lab.

1.2. GLOSSARY

1	ETR	Environmental Test Report
2	ETS	European Telecommunication Standard
3	IEC	International Electronic Community
4	N/A	Not Applicable
5	NCR	No Calibration Required
6	RH	Relative Humidity
7	TBD	To Be Defined
8	UUT	Unit Under Test

1.3. APPLICABLE DOCUMENTS

This section contains a list of resources referenced by or related to this document.

- BS EN 62052-11:2003.
- IEC 60068.

Handwritten mark

Заличено по чл.2 от ЗЗЛД

Handwritten mark

Handwritten mark



2. UUT DESCRIPTION

4 units of SATEC Ltd.:

1. BFM 136 - Power meter, 100 – 240Vac, 50/60Hz, 10VA.
2. EM133 – 5 Power meter, 400Vac, 3 phases, 5A (10A), 3VA.
3. PM 130EH PLUS – Power meter, 240Vac, 50/60Hz, 5A, 9VA.
4. PM 175 – Power meter, 690Vac, 50Hz, 5A, 10W.

All units are 3-phase, multi-channel, multi-function energy meters suitable for use in single-phase and multi-phase electrical networks. The units monitor and measure voltage and current and calculate power consumption. Current monitored and measured via current transformers.

The units are intended for wall or DIN rail mounting.

The units are equipped with RS-485 serial port module for communication. The Ethernet 10/100BaseT and wireless modem are also available.

Заличено по чл.2 от ЗЗЛД

3. SINE VIBRATION TEST - 14/2487

3.1. UNIT UNDER TEST OVERVIEW

Test Date	23/07/2014
Customer Representative	Leonid Fine
Customer Name	SII
Unit Name	ENERGY POWER METER
Item Manufacturer	SATEC
Item Quantity	4 units

3.2. TECHNICAL SOURCE

- BS EN 62052-11:2003, Paragraph 5.2.2.3.
- IEC 60068-2-6.

3.3. TEST INSTRUMENTATION

No.	Instrument Type	Instrument Model	Due Cal.
1.	Electrodynamic Vibration System	U&D TA117-60/CSTA	10/12/2014
2.	Vibration Control System	U&D VWIN Model 2000	10/12/2014
3.	Charge Amplifier	ENDEVCO ISOTRON P.S. Model 2793	10/12/2014
4.	Control Accelerometer Model	ENDEVCO 2224C	See Due Cal. at Accelerometers List Paragraph.

3.4. LAB'S ENVIRONMENTAL CONDITIONS

Parameter Name	Parameter Value	Tolerance Value	Measure Unit
Temperature	25	± 10	Degree Celsius (°C).
Humidity	55	± 27	% R.H.
Mains Voltage	230	± 23	Volts
Mains Frequency	50	± 2	Hertz
Site Air Pressure	760	± 5	mmHg
	1012	± 5	millibar

3.5. TEST PROCEDURE

3.5.1. EXCLUSIONS FROM THE TEST METHOD

None.

Заличено по чл.2 от ЗЗЛД

WYJ


3.5.2. VIBRATION TEST PROCEDURE DESCRIPTION

Item Position	The test item was strictly attached to vibration exciter.
Vibration Axes	3 (X, Y, Z).
Sweeping Frequency	Logarithm. From 10 Hz To 150 Hz. Within 03:54 minutes
Vibration Time in Each Axis	01:18 hours
Vibration Level	1 g max.

3.5.3. TEST PERFORMANCE

Functional Test	<ul style="list-style-type: none">• At the end of test.• Performed by customer representative.
Visual Test	<ul style="list-style-type: none">• At the end of test.• Performed by customer representative.

3.5.4. TEST PICTURES



WYJ


Заличено по чл.2 от ЗЗЛД

WYJ

WYJ



Handwritten signature





Handwritten scribble




Заличено по чл.2 от ЗЗЛД

3.5.5. TEST GRAPHS

Заличено по чл.2 от ЗЗЛД

Handwritten signature



3.5.6. ACCELEROMETERS LIST

Channel (U&D)	Servo Output (mV/g)	Accelerometer Type		Due Cal.
		Model	Serial Number	
1	122	ENDEVCO 2224C	19604	10/12/2014
2	123	ENDEVCO 2224C	19606	10/12/2014

3.5.7. MEASUREMENT POINTS DESCRIPTION


No.	Setup	Run No.	Channel Meas. U&D	Control Axis	Meas. Axis	Definition of measurement points
1.	iec 68-2-6 Test Fc	4	1	X	N/A	Control on vibration fixture.
2.	iec 68-2-6 Test Fc	5	1	Y	N/A	Control on vibration fixture.
3.	iec 68-2-6 Test Fc	6	1,2	Z	N/A	Control on vibration fixture.

3.6. TEST RESULTS

Based on the customer's declaration - The unit under test has PASSED the test.

Заличено по чл.2 от ЗЗЛД

Handwritten signature



mg/11

4. MECHANICAL SHOCK TEST - 14/2488

4.1. UNIT UNDER TEST OVERVIEW

Test Date	23/07/2014
Customer Representative	Leonid Fine
Customer Name	SII
Unit Name	ENERGY POWER METER
Item Manufacturer	SATEC
Item Quantity	4 units

4.2. TECHNICAL SOURCE

- BS EN 62052-11:2003, Paragraph 5.2.2.2.

4.3. TEST INSTRUMENTATION

No.	Instrument Type	Instrument Model	Due Cal.
1.	Mechanical Shock Machine	Electrodynamic vibration system: U&D TA117-60/CSTA	09/12/2014
2.	Shock Control System	U&D VWIN Model 2000	10/12/2014
3.	Charge Amplifier	ENDEVCO ISOTRON P.S. Model 2793	09/12/2014
4.	Control Accelerometer Model	ENDEVCO 2224C	See Due Cal. at Accelerometers List Paragraph.

4.4. LAB'S ENVIRONMENTAL CONDITIONS

Parameter Name	Parameter Value	Tolerance Value	Measure Unit
Temperature	25	± 10	Degree Celsius (°C).
Humidity	55	± 27	% R.H.
Mains Voltage	230	± 23	Volts
Mains Frequency	50	± 2	Hertz
Site Air Pressure	760	± 5	mmHg
	1012	± 5	millibar

4.5. TEST PROCEDURE

4.5.1. EXCLUSIONS FROM THE TEST METHOD

None.

Заличено по чл.2 от ЗЗЛД

4K


4.5.2. MECHANICAL SHOCK TEST PROCEDURE DESCRIPTION

Item Position	The test item was rigidly attached to the shock machine.
Number of Shocks	3 shocks were conducted in each of the 6 directions of the test item.
Shock Level	27 g.
Time Duration	16 msec.
Shape	Half sine.
Total Number of Shocks	18 shocks.

4.5.3. TEST PERFORMANCE

Functional Test	<ul style="list-style-type: none">• At the end of test.• Performed by customer representative.
Visual Test	<ul style="list-style-type: none">• At the end of test.• Performed by customer representative.

4.5.4. TEST PICTURES




[Handwritten signature]

Заличено по чл.2 от ЗЗЛД

[Handwritten signature]

[Circular stamp with text]

Handwritten mark



Handwritten mark





Заличено по чл.2 от ЗЗЛД

Handwritten mark


Handwritten signature

4.5.5. TEST GRAPHS





Заличено по чл.2 от ЗЗЛД

Handwritten signature



W/M





Заличено по чл.2 от ЗЗЛД

[Handwritten signature]

[Handwritten marks and stamps]

Handwritten initials





Залічено по чл.2 от ЗЗЛД

Handwritten signature

Handwritten signature and stamp

Handwritten signature




Handwritten signature

Заличено по чл.2 от ЗЗЛД


Handwritten signature



W/K




B





Заличено по чл.2 от ЗЗЛД

RA





my 11



Заличено по чл.2 от ЗЗЛД

Handwritten signature





Заличено по чл.2 от ЗЗД

Handwritten signature

Handwritten signature

Handwritten signature



Заличено по чл.2 от ЗЗЛД

Handwritten signature



4.5.6. ACCELEROMETERS LIST

Channel (U&D)	Servo Output (mV/g)	Accelerometer Type		Due Cal.
		Model	Serial Number	
1	122	ENDEVCO 2224C	19604	10/12/2014

4.5.7. MEASUREMENT POINTS DESCRIPTION

No.	Setup	Run No.	Channel Meas. U&D	Control Axis	Meas. Axis	Definition of measurement points
1.	sin30g18	1	1	X	N/A	Control on shock fixture.
2.	sin30g18	2	1	X	N/A	Control on shock fixture.
3.	sin30g18	3	1	X	N/A	Control on shock fixture.
4.	sin30g18	4	1	-X	N/A	Control on shock fixture.
5.	sin30g18	5	1	-X	N/A	Control on shock fixture.
6.	sin30g18	6	1	-X	N/A	Control on shock fixture.
7.	sin30g18	7	1	Y	N/A	Control on shock fixture.
8.	sin30g18	8	1	Y	N/A	Control on shock fixture.
9.	sin30g18	9	1	Y	N/A	Control on shock fixture.
10.	sin30g18	10	1	-Y	N/A	Control on shock fixture.
11.	sin30g18	11	1	-Y	N/A	Control on shock fixture.
12.	sin30g18	12	1	-Y	N/A	Control on shock fixture.
13.	sin30g18	13	1	Z	N/A	Control on shock fixture.
14.	sin30g18	14	1	Z	N/A	Control on shock fixture.
15.	sin30g18	15	1	-Z	N/A	Control on shock fixture.
16.	sin30g18	16	1	-Z	N/A	Control on shock fixture.

4.6. TEST RESULTS

Based on the customer's declaration - The unit under test has PASSED the test.

Заличено по чл.2 от ЗЗЛД



wfm

5. DRY HEAT (Storage) TEST - 14/2489

5.1. UNIT UNDER TEST OVERVIEW

Test Date	24/07/2014
Customer Representative	Leonid Fine
Customer Name	SII
Unit Name	ENERGY POWER METER
Item Manufacturer	SATEC
Item Quantity	4 units

5.2. TECHNICAL SOURCE

- BS EN 62052-11:2003, Paragraph 6.3.1.

5.3. TEST INSTRUMENTATION - TEMPERATURE CHAMBER

No.	Instrumentation Name	Due Cal.
1.	THERMOTRON_SM-8C	11/12/2014

5.4. LAB'S ENVIRONMENTAL CONDITIONS

Parameter Name	Parameter Value	Tolerance Value	Measure Unit
Temperature	25	± 10	Degree Celsius (°C).
Humidity	55	± 27	% R.H.
Mains Voltage	230	± 23	Volts
Mains Frequency	50	± 2	Hertz
Site Air Pressure	760	± 5	mmHg
	1012	± 5	millibar

5.5. TEST PROCEDURE

5.5.1. EXCLUSIONS FROM THE TEST METHOD

None.

5.5.2. HIGH TEMPERATURE TEST PROCEDURE DESCRIPTION

Number of Cycles	One temperature cycle was conducted.
Cycle Time	73:30 hours

Temperature Change		Period	Remarks
From	To		
25°C	70°C	45 minutes	
70°C	70°C	72 hours	
70°C	25°C	45 minutes	

Заличено по чл.2 от ЗЗЛД




Handwritten signature

5.5.3. TEST PERFORMANCE

Functional Test	<ul style="list-style-type: none">• At the end of test.• Performed by customer representative.
Visual Test	<ul style="list-style-type: none">• At the end of test.• Performed by customer representative.

5.5.4. TEST PICTURES



Handwritten mark

Handwritten signature

Handwritten signature

Handwritten signature


СЕМО
ООП

Заличено по чл.2 от ЗЗЛД

Handwritten signature

WgM

5.5.5. TEST GRAPHS



5.6. TEST RESULTS

Based on the customer's declaration - The unit under test has PASSED the test.

Заличено по чл.2 от ЗЗЛД

myh

6. LOW TEMPERATURE (Storage) TEST - 14/2518

6.1. UNIT UNDER TEST OVERVIEW

Test Date	27/07/2014
Customer Representative	Leonid Fine
Customer Name	SII
Unit Name	ENERGY POWER METER
Item Manufacturer	SATEC
Item Quantity	4 units

6.2. TECHNICAL SOURCE

- BS EN 62052-11:2003, Paragraph 6.3.1.

6.3. TEST INSTRUMENTATION - TEMPERATURE CHAMBER

No.	Instrumentation Name	Due Cal.
1.	THERMOTRON_SM-8C	11/12/2014

6.4. LAB'S ENVIRONMENTAL CONDITIONS

Parameter Name	Parameter Value	Tolerance Value	Measure Unit
Temperature	25	± 10	Degree Celsius (°C).
Humidity	55	± 27	% R.H.
Mains Voltage	230	± 23	Volts
Mains Frequency	50	± 2	Hertz
Site Air Pressure	760	± 5	mmHg
	1012	± 5	millibar

6.5. TEST PROCEDURE

6.5.1. EXCLUSIONS FROM THE TEST METHOD

None.

6.5.2. LOW TEMPERATURE TEST PROCEDURE DESCRIPTION

Number of Cycles	One temperature cycle was conducted.
Cycle Time	73:40 hours

Temperature Change		Period	Remarks
From	To		
25°C	-25°C	50 minutes	
-25°C	-25°C	72 hours	
-25°C	25°C	50 minutes	

Заличено по чл.2 от ЗЗЛД




mjh

6.5.3. TEST PERFORMANCE

Functional Test	<ul style="list-style-type: none">• At the end of test.• Performed by customer representative.
Visual Test	<ul style="list-style-type: none">• At the end of test.• Performed by customer representative.

6.5.4. TEST PICTURES



[Handwritten signature]

Заличено по чл.2 от ЗЗЛД




[Handwritten signature]

[Handwritten signature]

Handwritten signature

6.5.5. TEST GRAPHS



Handwritten signature

6.6. TEST RESULTS

Based on the customer's declaration - The unit under test has PASSED the test.

Заличено по чл.2 от ЗЗД



Handwritten signature

myh

7. HIGH TEMPERATURE (DUMP HEAT -Operation) TEST - 14/2519

7.1. UNIT UNDER TEST OVERVIEW

Test Date	31/07/2014
Customer Representative	Leonid Fine
Customer Name	SII
Unit Name	ENERGY POWER METER
Item Manufacturer	SATEC
Item Quantity	4 units

7.2. TECHNICAL SOURCE

- BS EN 62052-11:2003, Paragraph 6.3.3.

7.3. TEST INSTRUMENTATION - TEMPERATURE & HUMIDITY CHAMBER

No.	Instrumentation Name	Due Cal.
1.	THERMOTRON_SM-8C	11/12/2014

7.4. LAB'S ENVIRONMENTAL CONDITIONS

Parameter Name	Parameter Value	Tolerance Value	Measure Unit
Temperature	25	± 10	Degree Celsius (°C).
Humidity	55	± 27	% R.H.
Mains Voltage	230	± 23	Volts
Mains Frequency	50	± 2	Hertz
Site Air Pressure	760	± 5	mmHg
	1012	± 5	millibar

7.5. TEST PROCEDURE

7.5.1. EXCLUSIONS FROM THE TEST METHOD

None.

7.5.2. TEMPERATURE & HUMIDITY TEST PROCEDURE DESCRIPTION

Number of Cycles	6 temperature & humidity cycles were conducted.
Cycle Time	24 hours

No.	Temperature Change		Humidity		Period	Remarks
	From	To	From	To		
1.	25°C	40°C	95%	95%	3 hours	
2.	40°C	40°C	95%	95%	9 hours	
3.	40°C	25°C	95%	95%	3 hours	
4.	25°C	25°C	95%	95%	9 hours	


Заличено по чл.2 от ЗЗЛД

Handwritten signature

7.5.3. TEST PERFORMANCE

Functional Test	<ul style="list-style-type: none">• During test.• At the end of test.• Performed by customer representative.
Visual Test	<ul style="list-style-type: none">• At the end of test.• Performed by customer representative.

7.5.4. TEST PICTURES



Handwritten scribble


Заличено по чл.2 от ЗЗЛД



Handwritten signature

mgm

7.5.5. TEST GRAPHS



[Handwritten signature]


7.6. TEST RESULTS

Based on the customer's declaration - The unit under test has PASSED the test.

- After Temperature & Humidity (Damp Heat) Test, Immunity To Voltage Surge Test was performed.

Заличено по чл.2 от ЗЗЛД

[Handwritten signature]



[Handwritten signature]

47/11

8. IMMUNITY TO VOLTAGE SURGE TEST - 14/2628

8.1. UNIT UNDER TEST OVERVIEW

Test Date	11/07/2014
Customer Representative	Leonid Fine
Customer Name	SII
Unit Name	ENERGY POWER METER
Item Manufacturer	SII
Item Quantity	4 units

- The test was performed by EMC Lab. See document below:

8.2. IMMUNITY TO VOLTAGE SURGE TEST

Date of Test: 11.07.2014
Relative Humidity: 48%
Ambient Temperature: 21°C
Atmospheric Pressure: 1011.4 hPa
Test performed by: Dmitry Isaev

[Handwritten mark]

8.2.1. TEST METHOD: EN61000-4-5

8.2.2. TEST PROCEDURE:

Surge Tests were performed on a ground reference plane 3m x 3m wide. The EUT was placed on a table 0.1m above the ground reference plane, and was configured, arranged and operated in a manner consistent with typical application and load conditions. Surge voltage was applied to the EUT power supply by means of a coupling/decoupling network, and directly to the tested ports. The surges were applied as described in the table below.

8.2.3. LIST OF TEST EQUIPMENT:

IP6.2 2 & 4 -wire Coupling Network
EMtest, Coupling/Decoupling network for burst and surge, CNI 503 A18/ 32A
EMTest, Surge Generator combination wave, VCS 500 N10

Заличено по чл.2 от ЗЗЛД

СМО

[Handwritten signature]

[Handwritten signature]

Handwritten mark


8.2.4. TEST RESULTS:

Surge Application	Test Level, kV	Repetitions at each polarity	Pass/ Fail
EM133			
V1+V2+V3+Vn to RS-485(X+ and X-)	±4	5	*
PM175			
V1+V2+V3+Vn+L+N to COM1	±4	5	*
V1+V2+V3+Vn+L+N to COM2			*
V1+V2+V3+Vn+L+N to GND			*
BFM136			
V1+V2+V3+Vn+L+N to COM1(RS-485)	±4	5	*
PM130EH Plus			
V1+V2+V3+Vn+L+N to RS-485	±4	5	*
V1+V2+V3+Vn+L+N to GND			*

* Normal performance of the EUT should be verified by the customer at customer premises after tests.

8.2.5. TEST PICTURES

Test Picture 1: Surge on EM133



Handwritten mark

Заличено по чл.2 от ЗЗЛД

Handwritten signature

Handwritten signature


Handwritten mark

Test Picture 2: Surge on PM175



Handwritten mark

Test Picture 3: Surge on BFM136



Заличено по чл.2 от ЗЗЛД

Handwritten mark

Handwritten signature

Stamp: МОС

Handwritten initials or mark in the top right corner.

Test Picture 4: Surge on PM130EH Plus



Handwritten mark or signature on the right side of the page.

Заличено по чл.2 от ЗЗЛД

Handwritten signature and a circular stamp with the letters "СМО" inside.

Large handwritten signature or mark in the bottom left corner.

my 11

9. TEMPERATURE CYCLING (Storage & Operation) TEST - 14/2631

9.1. UNIT UNDER TEST OVERVIEW

Test Date	14/08/2014, 17/08/2014
Customer Representative	Leonid Fine
Customer Name	SII
Unit Name	ENERGY POWER METER
Item Manufacturer	SATEC
Item Quantity	4 units

9.2. TECHNICAL SOURCE

- BS EN 62052-11:2003, Paragraph 6.1
- IEC 60721-3-3, Table 1.

9.3. TEST INSTRUMENTATION - TEMPERATURE CHAMBER

No.	Instrumentation Name	Due Cal.
1.	ASSO_SK-3102	27/12/2014
2.	ASSO_SD-305	12/12/2014

9.4. LAB'S ENVIRONMENTAL CONDITIONS

Parameter Name	Parameter Value	Tolerance Value	Measure Unit
Temperature	25	± 10	Degree Celsius (°C).
Humidity	55	± 27	% R.H.
Mains Voltage	230	± 23	Volts
Mains Frequency	50	± 2	Hertz
Site Air Pressure	760	± 5	mmHg
	1012	± 5	millibar

9.5. TEST PROCEDURE

9.5.1. EXCLUSIONS FROM THE TEST METHOD

None.

Заличено по чл.2 от ЗЗЛД

my 11

9.5.2. TEMPERATURE CYCLING TEST PROCEDURE DESCRIPTION

Temperature Cycling (Storage) Test

Number of Cycles	One temperature cycle was conducted.
Cycle Time	15:10 hours

Temperature Change		Period	Remarks
From	To		
25°C	-25°C	50 minutes	
-25°C	-25°C	6 hours	
-25°C	70°C	1:35 hours	
70°C	70°C	6 hours	
70°C	25°C	45 minutes	

Temperature Cycling (Operation) Test

Number of Cycles	One temperature cycle was conducted.
Cycle Time	13:50 hours

Temperature Change		Period	Remarks
From	To		
25°C	-10°C	35 minutes	
-10°C	-10°C	6 hours	
-10°C	45°C	55 minutes	
45°C	45°C	6 hours	
45°C	25°C	20 minutes	

[Handwritten signature]

9.5.3. TEST PERFORMANCE

Functional Test	<ul style="list-style-type: none"> • During test. • At the end of test. • Performed by customer representative.
Visual Test	<ul style="list-style-type: none"> • At the end of test. • Performed by customer representative.

Заличено по чл.2 от ЗЗЛД

[Handwritten signature]


[Handwritten signature]



Handwritten signature


9.5.4. TEST PICTURES

Temperature Cycling (Storage) Test



Handwritten scribble

Temperature Cycling (Operation) Test



Заличено по чл.2 от ЗЗЛД


Handwritten signature




Handwritten signature

9.5.5. TEST GRAPHS

Temperature Cycling (Storage) Test Graph



Temperature Cycling (Operation) Test Graph



Заличено по чл.2 от ЗЗЛД

9.6. T

Based on the customer's declaration - The unit under test has PASSED the test



MjH

10. PARAMETERS ACCURACY & UNCERTAINTY BALANCE

ENVIRONMENTAL & MECHANICAL LABORATORIES PARAMETERS ACCURACY & UNCERTAINTY **

Manufacturer	Model	Description	Parameter	Accuracy *	Uncertainty
AALBORG	DFC36	Gas Flow Controller	LPM	0.5	0.3
ASSOCIATED	SK-3102	Temperature Chamber	Deg C	1.5	1.5
ASSOCIATED	ZHH-2108	Temperature Chamber	Deg C	2.7	1.4
ASSOCIATED	ZHH-2127	Temp/Humidity Chamber	Deg C	1.5	1.37
			RH%	6.1	3.31
BRABENDER	KKW10.000/60	Temperature & Humidity Chamber	Deg C	1	1.45
			RH%	4.6	3.6
LANSMONT	PDT-56ED	Drop Tester	cm	0.1	0.1
MONARCH	PLT200	RPM Meter	rpm	2	0.5
TENNEY	36S	Altitude/Heat Chamber	Deg C	0.5	0.8
			Feet	100	100
TENNEY	JUNIOR	Temperature Chamber	Deg C	0.7	1.5
TENNEY	T30 RC	Temp/Humidity Chamber	Deg C	1.5	1.51
			RH%	5	3.6
TENNEY	T40 RC	Temp/Humidity Chamber	Deg C	2.1	1.6
			RH%	2.8	3.6
TENNEY	T-5S	Temperature Chamber	Deg C	2.1	1.28
THERMOTRON	F-40-CHMV-25-25-2	Temperature & Humidity Agree Chamber	Deg C	0.5	2
			RH%	3.4	2.94
THERMOTRON	F-64-CHAMV-10-10 S	Temp. & Humidity & Altitude Chamber	Deg C	3.5	1.6
			RH%	2.5	3.6
THERMOTRON	TS-8-3Z-5-5-Ln2	Thermal Shock Chamber	Deg C	0.9	1.6
U&D	VWIN 2000	Controlled Vibration Machine	g (%)	3	3
WEISS	SNT-400	Salt Fog Chamber	Salt (%)	3	3
			Deg C	0.5	0.3
			pH	0.01	0.01
LAB	SC-1000	Bounce Machine	RPM	1	0.5

* Accuracy in (%) only
** Unless otherwise s

Заличено по чл.2 от ЗЗЛД

БЛГОУ Б УГИ И ПРАВА



MjH

mj 11

END OF REPORT

[Handwritten mark]

Заличено по чл.2 от ЗЗЛД

БЛРНО С ОБЩА ОТГОВОРНОСТ



[Handwritten signature]

Wj 11

ENVIRONMENTAL TEST REPORT

CUSTOMER



Satec

UNIT NAME

PM135EH, PM172E

* Same enclosure & construction for the following Instruments:

PM130P, PM130E, PM130EH, PM135P, PM135E, PM135EH, PM172P, PM172E, PM172EH, PM174 & PM175.


DOCUMENT INFO

Document Status	Released
Document Revision	--
Document Number	2122A7769

AUTHOR & UPDATE DETAILS

Author	Chen Zakaim
Date of Issue	August 24, 2015
Last Updated By	Chen Zakaim
Last Updated On	August 24, 2015

Заличено по чл.2 от ЗЗЛД



carmel

Environmental Tests Ltd.



Customer: Satec

Unit Name: PM135EH, PM172E

Doc No.: 2122A7769, Rev (-)

myid






LABORATORY DETAILS

 Lab Name	Carmel Environmental Test Laboratories
 Address	33 Alexander Yannai St. PetachTikva, Israel
 Tel.	+972-3-5702773
 Fax	+972-3-5702774
 E-Mail	info@carmel-lab.co.il
 Website	http://www.carmel-lab.com

carmel

Environmental Tests Ltd.

CUSTOMER DETAILS

 Customer Name	Satec
 Address	POB 45022 Jerusalem 9145001, Israel
 Tel.	972-52-2382511+
 Customer Rep.	Avi Beim
 E-Mail	avib@satec-global.com

SATEC
Powerful Solutions

[Handwritten mark]

Заличено по чл.2 от ЗЗЛД



[Handwritten signature]

anj 8/

DOCUMENT CONTROL

This document is a controlled document. It is your responsibility to ensure that you have the appropriate version of this document. This document is not subject to version control when printed.

1 // DOCUMENT HISTORY

The following table records information regarding released editions of this document and briefly describes their purpose and changes made to them.

Edition ID	Release Date	Author	Purpose and Description of Changes
-	August 24, 2015	Chen Zakaim	Purpose: Release

2 // DOCUMENT APPROVALS

Author	August 24, 2015	Approved By	August 24, 2015
<i>Chen Zakaim, Technical Writer</i>		<i>Dov Carmeli, COO</i>	

3 // OPEN ISSUES

No.	Subject/Section	Description
1.		
2.		

Заличено по чл.2 от ЗЗЛД

ВЯРНО С ОРИГИНАЛА



[Handwritten signature]

mg

TABLE OF CONTENTS

1. INTRODUCTION.....	6
1.1 // PURPOSE.....	6
1.2 // SCOPE.....	6
1.3 // GLOSSARY.....	6
1.4 // APPLICABLE DOCUMENTS.....	6
1.5 // TEST INSTRUMENTATION.....	7
1.6 // SYSTEM OVERVIEW.....	7
1.7 // EXECUTIVE SUMMARY.....	7
1.8 // LABORATORY ACCREDITATION.....	8
2. DUST IP5X TEST.....	9
2.1 // UNIT UNDER TEST OVERVIEW.....	9
2.2 // TEST DESCRIPTION.....	9
2.2.1 // TEST PROCEDURE.....	9
2.2.2 // EXCLUSIONS FROM THE TEST METHOD.....	9
2.2.3 // TEST INSPECTION.....	9
2.3 // TEST RESULTS.....	9
2.4 // TEST PICTURES.....	10
3. WATER SPLASH IPX4 TEST.....	12
3.1 // UNIT UNDER TEST OVERVIEW.....	12
3.2 // TEST DESCRIPTION.....	12
3.2.1 // TEST PROCEDURE.....	12
3.2.2 // EXCLUSIONS FROM THE TEST METHOD.....	13
3.2.3 // TEST INSPECTION.....	13
3.3 // TEST RESULTS.....	13
3.4 // TEST PICTURES.....	14

[Handwritten mark]

LIST OF FIGURES

Figure 1.1 - System Overview.....	7
Figure 2.1- UUT before the Dust Test.....	10
Figure 2.2- UUT inside the Dust Chamber.....	10
Figure 2.3- UUT after the Dust Test.....	10
Figure 2.4- UUT after the Dust Test.....	11
Figure 3.1-Test Device – Oscillating Tube.....	12
Figure 3.2-UUT during the WaterTest.....	14
Figure 3.3- UUT during the Water Test.....	14

[Handwritten signature]

Заличено по чл.2 от ЗЗЛД

[Handwritten mark]





mj

Figure 3.4-- UUT during the Water Test..... 14
Figure 3.5--UUT after the Water test..... 15
Figure 3.6--UUT after the Water test..... 15
Figure 3.5--UUT at the End of the Tests..... 16
Figure 3.6-- UUT at the End of the Tests..... 16

LIST OF TABLES

No table of figures entries found.

[Handwritten mark]

Заличено по чл.2 от ЗЗЛД



[Handwritten signature]

min

1. INTRODUCTION

1.1 // PURPOSE

The purpose of this document is to verify that the PM135EH, PM172E meets all requirements as per the applicable documents.

1.2 // SCOPE

The scope of this Environmental Test Report includes the environmental test results as specified by the customer and by the related resources.

1.3 // GLOSSARY

Term	Description
N.A	Not Applicable
N.C	Not Controlled
PSD	Power Spectral Density
TBD	To Be Defined
RH	Relative Humidity
UUT	Unit Under Test

1.4 // APPLICABLE DOCUMENTS

This section contains a list of resources (e.g., documents, files) referenced by or related to this document. All documents' revisions are the latest known on the date of the contract signing.

Main Document Customer Requirements

// Test-specific sources

Test	Document
Dust IP5X	IEC 60529
Water Splash IPX4	IEC 60529

Заличено по чл.2 от ЗЗЛД

Handwritten signature

1.5 // TEST INSTRUMENTATION

Test	Name	S/N	Calibration Due Date
Dust IP5X	Yishai Instruments & Equipments	SSC-010	31 January 2016
Water Splash IPX4	Oscillating Tube Facility	TOP2903	31 October 2015

1.6 // SYSTEM OVERVIEW



Figure 1.1 - System Overview

1.7 // EXECUTIVE SUMMARY

The following table summarizes the tests that have been performed in Carmel Environmental Test Laboratories.

Test Name	Verdict
Dust IP5X	✓Pass
Water Splash IPX4	✓Pass



Statement of Compliance with Test Requirements

We, Carmel Environmental Test Laboratories, declare under our sole responsibility that the PM135EH, PM172E was tested to comply with the requirements of the applicable environmental test specification.

Заличено по чл.2 от ЗЗЛД

ВЯРНО С ОРИГИНАЛА



Handwritten signature

Handwritten signature

1.8 // LABORATORY ACCREDITATION

Carmel Environmental Test Laboratories Ltd. Is an accredited Laboratory by the American Association for Laboratory Accreditation – A2LA (see accreditation herein).

A2LA logo in the front page is applicable only to the tests under the scope of Carmel Environmental Test Laboratories accreditations.

Carmel Environmental Test Laboratories has A2LA accreditation to ISO/IEC 17025:2005 for test types as listed in the following link:

<http://www.a2la.org/scopepdf/2881-01.pdf>




American Association for Laboratory Accreditation

Accredited Laboratory
 A2LA has accredited
CARMEL-ENVIRONMENTAL TESTS LTD.
Petach Tikva,
 for technical competence in the field of
Mechanical Testing

This laboratory is accredited in accordance with the recognized International Standard ISO/IEC 17025:2005 General requirements for the competence of testing and calibration laboratories. This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality management system (refer to joint ISO-ILAC-IAF Communiqué dated 8 January 2009).

Presented this 25th day of March 2014.



Заличено по чл.2 от ЗЗЛД
 President & CEO
 For the Accreditation Council
 Certificate Number 2881.01
 Valid to March 31, 2016

For the types of tests to which this accreditation applies, please refer to the laboratory's Mechanical Scope of Accreditation.

Handwritten signature

Заличено по чл.2 от ЗЗЛД

Заличено по чл.2 от ЗЗЛД

СМО

Handwritten signature

ujn

2. DUST IP5X TEST

2.1 // UNIT UNDER TEST OVERVIEW

Test Dates	23/08/2015
Customer	Satec
Customer Rep.	Avi Beim
Unit Name	PM135EH, PM172E Same enclosure & construction for the following Instruments: PM130P, PM130E, PM130EH, PM135P, PM135E, PM135EH, PM172P, PM172E, PM172EH, PM174 & PM175.
P/N	PM172E , PM135EH
S/N	1133212 , 1132673
Item Manufacturer	Satec
Number of Units	1+1

2.2 // TEST DESCRIPTION

2.2.1 // TEST PROCEDURE

Dust Size	<75µm	Amount of Dust	2Kg per cubic meter
Temperature	25°C - 35°C	Duration	8 hrs.

2.2.2 // EXCLUSIONS FROM THE TEST METHOD

Not Applicable.

2.2.3 // TEST INSPECTION

	Visual Test	Functional Test
Before Test	✓	✓
During Test	✗	✗
After Test	✓	✓

2.3 // TEST RESULTS

In visual inspection at completion of the test, no external damage observed.

operationa
 Test Result

Заличено по чл.2 от ЗЗЛД

[Handwritten signature]

[Handwritten signature]

[Handwritten signature]

mjm

2.4 // TEST PICTURES



Figure 2.1– UUT before the Dust Test



Figure 2.2– UUT inside the Dust Chamber



Figure 2.3– UUT a

Заличено по чл.2 от ЗЗЛД

ДАТНО С СЪСТАВИТЕЛНИТЕ ЧАСТИ



mjh



Figure 2.4– UUT after the Dust Test

[Handwritten mark]

Заличено по чл.2 от ЗЗЛД

[Faint stamps and markings]

[Handwritten signature]

mj

3. WATER SPLASH IPX4 TEST

3.1 // UNIT UNDER TEST OVERVIEW

Test Dates	24/08/2015
Customer	Satec
Customer Rep.	Avi Beim
Unit Name	PM135EH, PM172E Same enclosure & construction for the following Instruments: PM130P, PM130E, PM130EH, PM135P, PM135E, PM135EH, PM172P, PM172E, PM172EH, PM174 & PM175.
P/N	PM172E , PM135EH
S/N	1133212 . 1132673
Item Manufacturer	Satec
Number of Units	1+1

3.2 // TEST DESCRIPTION

3.2.1 // TEST PROCEDURE

The oscillating tube consist of spray holes over the whole 180" of the semicircle.
 The tube is caused to oscillate through an angle of almost 360", 180" on either side of the vertical, the time for one complete oscillation (2 x 360") being about 12 s.
 The duration of the test: 10 min.




Figure 3.1-Test Device

Заличено по чл.2 от ЗЗД

[Handwritten signature]

577

3.2.2 // EXCLUSIONS FROM THE TEST METHOD

Not Applicable.

3.2.3 // TEST INSPECTION

	<i>Visual Test</i>	<i>Functional Test</i>
Before Test	✓	✓
During Test	✗	✗
After Test	✓	✓

3.3 // TEST RESULTS

In visual inspection at completion of the test, no external damage observed.
operational and visual tests have been conducted at the end of the test.

Test Result: ✓Pass



Заличено по чл.2 от ЗЗЛД



mya

3.4 // TEST PICTURES



Figure 3.2—UUT during the WaterTest




Figure 3.3— UUT during the Water Test



Figure 3.4— UUT during the Water Test

[Handwritten mark]

Заличено по чл.2 от ЗЗЛД

ВЪРНО СЪОБЩАВАНЕ

СМО

001

[Handwritten signature]

ungh




Figure 3.5—UUT after the Water test



Figure 3.6—UUT after the Water test



Заличено по чл.2 от ЗЗЛД



M



Figure 3.7-UUT at the End of the Tests



Figure 3.8- UUT at the End of the Tests

Заличено по чл.2 от ЗЗЛД

ВЯРНО С ОРИГИНАЛА

ООП

M



my 11

TEST REPORT	
IEC 62053-22	
Electricity metering equipment (a.c.) – Particular requirements – Part 22: Static meters for active energy (classes 0,2 S and 0,5 S)	
IEC 62052-11	
Electricity metering equipment (a.c.) – General requirements, tests and test conditions Part 11: Metering equipment	
Report Number.....	9412301409
Date of issue.....	16/09/2014
Total number of pages	23 + appendices
Applicant's name	SATEC Ltd.
Address.....	7 Ha-Marpe St., Har Hotzvim Industrial Park, P.O.B. 45022, Jerusalem 9145001, Israel
Testing Laboratory:	The Standards Institution of Israel
Testing location/ address	42 Chaim Levanon St., Tel Aviv 69977, Israel
Tested by (name + signature).....	SERGEY VOYTENKO Заличено по чл.2 от ЗЗЛД
Approved by (name + signature)....	MICHAEL TERMAN
Test specification:	
Standard	IEC 62053-22: 2003 used in conjunction with IEC 62052-11: 2003
Test procedure	N/A
Non-standard test method	N/A
Test Report Form No.	IEC62053_22A
Test Report Form(s) Originator	The Standards Institution of Israel
Master TRF	Dated 2014-07
General disclaimer:	
The test results presented in this report relate only to the object tested. This report shall not be reproduced, except in full, without the written approval of the issuing laboratory.	
Test item description.....	Power/Energy Management Meters
Trade Mark.....	
Manufacturer	SATEC Ltd.
Model/Type reference	PM130EH PLUS, PM130PLUS, PM130P, PM130E, PM130EH, PM135; BFM136; EM133, EM132, EM131; PM175, PM172P, PM172E, PM172EH
Ratings	PM130 models: PS: 85-265Vac, 88-290Vdc, 50/60Hz, 9VA; Measurement inputs: 690Vac, 1A, 5A BFM136: PS and measurement inputs: (115) 88-138 Vac or (230/277) 176-320Vac, 50/60Hz, 10VA EM133/132/131: PS: 40-300Vac/dc, 3VA max. Measurement inputs: 3x58/100-400/690Vac, 50/60Hz, 3x5A; PM17 PS 8 Measurement inputs: 690Vac, 50Hz, 5A
Заличено по чл.2 от ЗЗЛД	

Handwritten signature



List of Attachments (including a total number of pages in each attachment):

- Appendix 1 – Photographs (13 pages attached)
- Appendix 2 – EMC test report (57 pages attached)
- Appendix 3 – Environmental test report (45 pages attached)
- Appendix 4 – Accuracy reports (60 pages attached)

Summary of testing:

1. All testing was performed on Models PM130EH PLUS, EM133 and PM175 (the worst case configurations with all functions active) and was considered representative of all other models of the same group.
2. The maximum operating ambient temperature declared by the manufacturer for the product: 45°C.

Possible test case verdicts:

- test case does not apply to the test object.....: N/A
- test object does meet the requirement.....: P (Pass)
- test object does not meet the requirement.....: F (Fail)

Testing.....:

Date of receipt of test item: 9/01/2014
 Date (s) of performance of tests: 20/01/2014-17/08/2014

General remarks:

Throughout this report a comma / point is used as the decimal separator.

General product information:


1. The equipment under test are electronic power or energy meters, mainly consisting of electronic boards housed inside an enclosure
2. Models PM130EH PLUS, PM130PLUS, PM130P, PM130E, PM130EH, and PM135 are electrically and mechanically identical except a number of active functions.
 Models EM133, EM132 and EM131 are electrically and mechanically identical except a number of active functions.
 Models PM175, PM172P, PM172E, and PM172EH are electrically and mechanically identical except a number of active functions.

General conclusion:

Electronic power/energy meters models PM130EH PLUS, PM130PLUS, PM130P, PM130E, PM130EH, PM135, BFM136, EM133, EM132, EM131, PM175, PM172P, PM172E, PM172EH comply with the requirements of IEC 62053-22: 2003 and IEC 62052-11: 2003 standards.

Заличено по чл.2 от ЗЗЛД

Copy of marking plate:




Заличено по чл.2 от ЗЗЛД

TRF No. IEC62053_22A



mj vl



Заличено по чл.2 от ЗЗЛД

TRF No. IEC62053_22A



IEC 62053-22 / IEC 62052-11			
Clause	Requirement + Test	Result - Remark	Verdict

4	STANDARD ELECTRICAL VALUES (IEC62052-11)		P
4.1	Standard reference voltages		P
4.2	Standard currents		P
4.3	Standard reference frequencies		P

5	MECHANICAL REQUIREMENTS AND TESTS (IEC62052-11)		P
5.1	General mechanical requirements	Meters are designed and constructed in such a way as to avoid introducing any danger in normal use and under normal conditions with respect to electric shock, excessive temperatures, penetration of solid objects, dust and water, and other foreseeable hazards.	P
5.2	Case		P
5.2.1	General requirements		P
5.2.2	Mechanical tests		P
5.2.2.1	Spring hammer test (IEC 60068-2-75)	Mechanical strength of the meter case was tested with a spring hammer (0,2 J ± 0,02 J)	P
5.2.2.2	Shock test (IEC60068-2-27)	See Appendix 3	P
5.2.2.3	Vibration test (IEC60068-2-6)	See Appendix 3	P
5.3	Window	The meters employ displays with clearly see readings	P
5.4	Terminals – Terminal block(s) – Protective earth terminal		
	<p>Terminals may be grouped in (a) terminal block(s) having adequate insulating properties and mechanical strength. In order to satisfy such requirements when choosing insulating materials for the terminal block(s), adequate testing of materials shall be taken into account.</p> <p>The material of which the terminal block is made shall be capable of passing the tests given in ISO 75-2 for a temperature of 135 °C and a pressure of 1,8 MPa (method A).</p> <p>The holes in the insulating material which form an extension of the terminal holes shall be of sufficient size to also accommodate the insulation of the conductors.</p> <p>The manner of fixing the conductors to the terminals shall ensure adequate and durable contact such that there is no risk of loosening or undue heating. Screw connections transmitting contact force and screw fixings which may be loosened and tightened several times during the life of the meter shall be provided.</p>	<p>EM133 and PM175: The terminals consist of special screw contact mounted in plastic enclosure of the meter. Insulation material of the enclosure is approved and rated heat deflection temperature according ISO 75-2 138°C</p> <p>PM130EH PLUS and BFM136: UL approved terminal blocks. Material of the housing: polyamide PA 6.6. rated heat deformation temperature 240°C.</p> <p>The adequate and durable contact of the conductors is provided.</p> <p>No risk of corrosion. All contact surfaces are provided</p>	P

TRF No. IEC62053_22A

ВАРНО С С

Заличено по чл.2 от 33ЛД



Handwritten initials

IEC 62053-22 / IEC 62052-11			
Clause	Requirement + Test	Result - Remark	Verdict
	<p>into a metal nut.</p> <p>All parts of each terminal shall be such that the risk of corrosion resulting from contact with any other metal part is minimized.</p> <p>Electrical connections shall be so designed that contact pressure is not transmitted through insulating material.</p> <p>For current circuits, the voltage is considered to be the same as for the related voltage circuit.</p> <p>Terminals with different potentials which are grouped close together shall be protected against accidental short-circuiting. Protection may be obtained by insulating barriers. Terminals of one current circuit are considered to be at the same potential.</p> <p>The terminals, the conductor fixing screws, or the external or internal conductors shall not be liable to come into contact with metal terminal covers.</p> <p>The protective earth terminal, if any:</p> <ul style="list-style-type: none"> a) shall be electrically bonded to the accessible metal parts; b) should, if possible, form part of the meter base; c) should preferably be located adjacent to its terminal block; d) shall accommodate a conductor having a cross-section at least equivalent to the main current conductors but with a lower limit of 6 mm² and an upper limit of 16 mm² (these dimensions apply only when copper conductors are used); e) shall be clearly identified by the graphical symbol IEC 60417-5019: Protective earth (ground). <p>After installation, it shall not be possible to loosen the protective earth terminal without the use of a tool.</p>	<p>with galvanic coating.</p> <p>Contact pressure is not transmitted through insulating material.</p> <p>The terminals with different potentials are separated by insulation barriers.</p> <p>Protective earth terminal is part of the approved terminal block.</p>	
5.5	<p>Terminal cover(s)</p> <p>The terminals of a meter, if grouped in a terminal block and if not protected by any other means, shall have a separate cover which can be sealed independently of the meter cover. The terminal cover shall enclose the actual terminals, the conductor fixing screws and, unless otherwise specified, a suitable length of the external conductors and their insulation.</p> <p>When the meter is panel-mounted, no access to the terminals shall be possible without breaking the seal(s) of the terminal cover(s).</p>	All terminals are provided with insulation covers	P

Заличено по чл.2 от ЗЗЛД



IEC 62053-22 / IEC 62052-11			
Clause	Requirement + Test	Result - Remark	Verdict
5.6	<p>Clearance and creepage distances</p> <p>The clearance and creepage distances between</p> <p>a) any terminal of a circuit with a reference voltage over 40 V and</p> <p>b) earth, together with terminals of auxiliary circuits with reference voltages below or equal to 40 V shall not be less than stated in</p> <p>– Table 3a for meters of protective class I;</p> <p>– Table 3b for meters of protective class II.</p> <p>The clearance and creepage distances between terminals of circuits with reference voltages over 40 V shall not be less than stated in Table 3a.</p> <p>The clearance between the terminal cover, if made of metal, and the upper surface of the screws when screwed down to the maximum applicable conductor fitted shall be not less than the relevant values indicated in Tables 3a and 3b.</p> <p>The requirement of the impulse voltage test shall also be met (see 7.3.2).</p>	See appended Table 5.6	P
5.7	<p>Insulating encased meter of protective class II</p> <p>A meter of protective class II shall have a durable and substantially continuous enclosure made wholly of insulating material, including the terminal cover, which envelopes all metal parts, with the exception of small parts, for example, name-plate, screws, suspensions and rivets. If such small parts are accessible by the standard test finger (as specified in IEC 60529) from outside the case, then they shall be additionally isolated from live parts by supplementary insulation against failure of basic insulation or loosening of live parts. The insulating properties of laquer, enamel, ordinary paper, cotton, oxide film on metal parts, adhesive film and sealing compound, or similar unsure materials, shall not be regarded as sufficient for supplementary insulation. For the terminal block and terminal cover of such a meter, reinforced insulation is sufficient.</p>	<p>EM133, EM130EH PLUS:</p> <p>The meter is fully enclosed by plastic enclosure with thickness 2mm.</p> <p>Laquer, enamel, ordinary paper, cotton, oxid film on metal. Adhesive film and sealing compound are not used as insulation.</p>	P
5.8	<p>Resistance to heat and fire</p> <p>The terminal block, the terminal cover and the meter case shall ensure reasonable safety against spread of fire. They should not be ignited by thermal overload of live parts in contact with them. To comply therewith they shall fulfil the following test.</p> <p>The test shall be carried out according to IEC 60695-2-11, with the following temperatures:</p> <p>– terminal block: 960 °C ± 15 °C;</p> <p>– terminal cover and meter case: 650 °C ± 10 °C,</p> <p>– duration of application: 30 s ± 1 s.</p> <p>The contact with the glow wire may occur at</p>	<p>Terminals.</p> <p>Insulation material of the EM133 enclosure is used as terminal housing. The material is rated GWIT 960°C.</p> <p>For other models approved terminals are used. Rated GWIT of the terminal housing is 960°C.</p> <p>Covers and enclosures.</p> <p>EM133 - 960°C. M O X</p> <p>Заличено по чл.2 от ЗЗЛД</p>	P

TRF No. IEC62053_22A

ВЯРНО С ОРИГИНАЛА

* СОФИЯ *



IEC 62053-22 / IEC 62052-11			
Clause	Requirement + Test	Result - Remark	Verdict
	random location. If the terminal block is integral with the meter base, it is sufficient to carry out the test only on the terminal block.	PM175 - 875°C All materials of the covers and enclosures are approved.	
5.9	<p>Protection against penetration of dust and water</p> <p>The meter shall conform to the degree of protection given in IEC 60529.</p> <p>Indoor meter: IP51, but without suction in the meter.</p> <p>Outdoor meter: IP54.</p> <p>The tests shall be carried out according to IEC 60529, under the following conditions:</p> <p>a) Protection against penetration of dust</p> <ul style="list-style-type: none"> - meter in non-operating condition and mounted on an artificial wall; - the test should be conducted with sample lengths of cable (exposed ends sealed) of the types specified by the manufacturer and terminal cover in place; - for indoor meters only, the same atmospheric pressure is maintained inside the meter as outside (neither under- nor over-pressure); - first characteristic digit: 5 (IP5X) <p>Any ingress of dust shall be only in a quantity not impairing the operation of the meter. An insulation test according to 7.3 shall be passed.</p> <p>b) Protection against penetration of water</p> <ul style="list-style-type: none"> - meter in non-operating condition; - second characteristic digit: 1 (IPX1) for indoor meters; 4 (IPX4) for outdoor meters. <p>Any ingress of water shall be only in a quantity not impairing the operation of the meter. An insulation test according to 7.3 shall be passed.</p>	<p>All meters are intended for indoor installation.</p> <p>Panel-mount models PM130EH PLUS and PM175 were tested for IP51;</p> <p>DIN-mount models BFM136 and EM133 were tested for IP30. For these models protection shall be provided by an external cabinet.</p>	P
5.10	Display of measured values		P
	<p>The information can be shown either by an electromechanical register or an electronic display. In the case of an electronic display the corresponding non-volatile memory shall have a minimum retention time of four months.</p> <p>NOTE: 1 Longer retention time of the non-volatile memory should be the subject of a purchase contract.</p> <p>In the case of multiple values presented by a single display it shall be possible to display the content of all relevant memories. When displaying the memory, the identification of each tariff applied shall be possible and, for automatic sequencing displays, each display of register for billing purposes shall be retained for a minimum of 5 s</p>	<p>All the meters have an electronic display, the energy registers and tariffs value and status have corresponding non-volatile memory with the retention time of 10 years.</p> <p>All these values accessible through the communication to PC or other Master device.</p>	P

Залічено по чл.2 от ЗЗЛД

TRF No. IEC6:



IEC 62053-22 / IEC 62052-11			
Clause	Requirement + Test	Result - Remark	Verdict

	The active tariff rate shall be indicated.	One of the registers assigned for the active tariff rate	P
	When the meter is not energized, the electronic display need not be visible.		P
	The principal unit for the measured values shall be the kilowatt-hour (kWh), kilovar-hour (kvarh), kilovolt-ampere-hour (kVAh) or the megawatt-hour (MWh), megavar-hour (Mvarh), megavolt-ampere-hour (MVAh).	Active, reactive & total energy values are measured in the recommended principal units: kilowatt-hour (kWh), kilovar-hour (kvarh), kilovolt-ampere-hour (kVAh) or the megawatt-hour (MWh), megavar-hour (Mvarh), megavolt-ampere-hour (MVAh).	P
	For electromechanical registers, register markings shall be indelible and easily readable. When continuously rotating, the lowest values of the drums shall be graduated and numbered in ten divisions, each division being subdivided into ten parts, or any other arrangement ensuring the same reading accuracy. The drums which indicate a decimal fraction of the unit shall be marked differently when they are visible.		N/A
	Every numerical element of an electronic display shall be able to show all the numbers from "zero" to "nine".	Meet the requirements	P
	The register shall be able to record and display, starting from zero, for a minimum of 1 500 h, the energy corresponding to maximum current at reference voltage and unity power factor. NOTE: 2 Values higher than 1 500 h should be the subject of purchase contract. It shall be impossible to reset the indication of the cumulative total of electrical energy during use. NOTE 3 The regular roll over of the display is not considered as a reset.	The energy registers contain 9 digits number of kWh, kVAh, kvarh. It is more than enough for 1500 h. The maximum secondary parameters: 100A x 3 maximum currents; 230V x 3 reference voltages. $230 \times 100 \times 3 \times 1500 = 103.5 \times 10^6 = 103500 \text{ kWh}$ (6 digits).	P
5.11	Output device		P
	The meter shall have a test output device capable of being monitored with suitable testing equipment. Output devices generally may not produce homogeneous pulse sequences. Therefore, the manufacturer shall state the necessary number of pulses to ensure a measuring accuracy of at least 1/10 of the class of the meter at the different test points. For electrical test output see, IEC 62053-31. If the test output is an optical test output, then it shall fulfil the requirements according to 5.11.2. The operation indicator, if fitted, shall be visible from the front.	The meters have an optical output device - RED LED.	P

Заличено по чл.2 от ЗЗЛД

ВЯРНО С ОРИГИНАЛА



TRF No. IEC62053_22A



IEC 62053-22 / IEC 62052-11			
Clause	Requirement + Test	Result - Remark	Verdict
5.11.1	<p>Mechanical and electrical characteristics</p> <p>An optical test output shall be accessible from the front.</p> <p>The maximum pulse frequency shall not exceed 2,5 kHz.</p> <p>Modulated and unmodulated output pulses are permitted. The unmodulated output pulses shall have the shape shown in Figure D.2.</p> <p>The pulse transition time (rise time or fall time) is the time of transition from one state to the other state, including transient effects. The transition time shall not exceed 20 μs (see Figure D.2).</p> <p>The distance of the optical pulse output from further adjacent ones or from an optical status display shall be sufficiently long that the transmission is not affected.</p> <p>An optimum pulse transmission² is achieved when, under test conditions, the receiving head is aligned with its optical axis on the optical pulse output.</p> <p>The rise time given in Annex D, Figure D.2 shall be verified by a reference receiver diode with $t_r \leq 0,2 \mu$s.</p>	<p>The LED is accessible from the front and meet all requirements.</p> <p>The output device was tested with following testing equipment: The optical heads: 1. Model SH2003 (MTE manufacturer) 2. Model TK325 (Zera manufacturer) The calibrator: Model CMC256PLUS (OMICRON electronics GmbH manufacturer)</p>	P
5.11.2	<p>Optical characteristics</p> <p>The wavelength of the radiated signals for emitting systems shall be between 550 nm and 1 000 nm.</p> <p>The output device in the meter shall generate a signal with a radiation strength E_T over a defined reference surface (optically active area) at a distance of $a_1 = 10 \text{ mm} \pm 1 \text{ mm}$ from the surface of the meter, with the following limiting values: ON-condition: $50 \mu\text{W}/\text{cm}^2 \leq E_T \leq 1\ 000 \mu\text{W}/\text{cm}^2$ OFF-condition: $E_T \leq 2 \mu\text{W}/\text{cm}^2$ See also Figure D.1.</p>	<p>The wavelength of the radiated signals for emitting is 650 nm.</p> <p>The distance of the correct signal acceptance is in the range of: 1mm ... 50mm.</p> <p>The output device meets the requirements of ON/OFF condition.</p>	P
5.12	Marking of meter		P
5.12.1	<p>Name-plates:</p> <p>Every meter shall bear the following information as applicable:</p> <p>a) manufacturer's name or trade mark and, if required, the place of manufacture;</p> <p>b) designation of type (see 3.1.8) and, if required, space for approval mark;</p> <p>c) the number of phases and the number of wires for which the meter is suitable;</p> <p>d) the serial number and year of manufacture;</p> <p>e) the reference voltage;</p> <p>f) for direct connected meters, the basic current and the maximum current expressed</p>	<p>All required information is included on the nameplates, additional markings and instructions.</p>	P

Заличено по чл.2 от ЗЗЛД

TRF No. IEC62053_22A

ВАРНО С ОРИГИНАЛ



IEC 62053-22 / IEC 62052-11			
Clause	Requirement + Test	Result - Remark	Verdict
	g) the reference frequency in Hz; h) the meter constant; i) the class index of the meter; j) the reference temperature if different from 23 °C; k) the sign of the double square □ for insulating encased meters of protective class II.		
5.12.2	Every meter shall preferably be indelibly marked with a diagram of connections. If this is not possible reference shall be made to a connection diagram.	All connections are clearly identified. Electrical wiring diagrams are provided wither on the units or in the product documentation (installation/operation instructions)	P

6 CLIMATIC CONDITIONS (IEC62052-11)			P
6.1	Temperature range	The temperature range of the meter is as shown in Table 5.	P
6.2	Relative humidity	See 6.3.3	P
6.3	Tests of the effect of the climatic environments		P
6.3.1	Dry heat test (IEC60068-2-2)	See Appendix 3	P
6.3.2	Cold test (IEC60068-2-1)	See Appendix 3	P
6.3.3	Damp heat cyclic test (IEC60068-2-30)	See Appendix 3	P
6.3.4	Protection against solar radiation (IEC60068-2-5)	The meters are intended for indoor installation	N/A

7 ELECTRICAL REQUIREMENTS			P
7.1 Influence of supply voltage (IEC62052-11)			P
7.1.1	Voltage range	Meet requirements of Table 7 of the standard	P
7.1.2	Voltage dips and short interruptions	The tests according to a), b) and c) were carried out	P
7.2	Heating (IEC62052-11)	See appended table 7.2	P
7.3	Insulation (IEC62052-11)		P
7.3.1	General test conditions		P
7.3.2	Impulse voltage test	Impulse waveform: 1,2/50 impulse specified in IEC 60060-1	P
7.3.2.1	Impulse voltage tests for circuits and between the circuits	Impulse voltage was applied ten times with one polarity and then repeated with the other polarity.	P
7.3.2.2	Impulse voltage test of electric cir earth		

Залічено по чл.2 от ЗЗЛД

TRF No. IEC62053_22A

ВЕРНО С ОРИГИНАЛА



IEC 62053-22 / IEC 62052-11			
Clause	Requirement + Test	Result - Remark	Verdict
7.3.3	AC voltage test	See 7.4 of IEC62053-22 below	P
7.4	Immunity to earth fault (IEC62052-11)	The meters under test are not intended for use in networks equipped with earth fault neutralizers	N/A
7.5	Electromagnetic compatibility (EMC) (IEC62052-11)		P
7.5.1	General test conditions	See Appendix 2	P
7.5.2	Test of immunity to electrostatic discharges	See Appendix 2	P
7.5.3	Test of immunity to electromagnetic RF fields	See Appendix 2	P
7.5.4	Fast transient burst test	See Appendix 2	P
7.5.5	Test of immunity to conducted disturbances, induced by radio-frequency fields	See Appendix 2	P
7.5.6	Surge immunity test	See Appendix 2	P
7.5.7	Damped oscillatory waves immunity test	See Appendix 2	P
7.5.8	Radio interference suppression	See Appendix 2	P

7	ELECTRICAL REQUIREMENTS (IEC62053-22)		P
	In addition to the electrical requirements in IEC62052-11, meters shall fulfil the following requirements:		P
7.1	Power consumption		P
	The power consumption in the voltage and current circuits shall be determined at reference conditions given in 8.5 by any suitable method. The overall maximum error of the measurement of the power consumption shall not exceed 5 %. The active and apparent power consumption taken at reference temperature and reference frequency, by each voltage circuit at reference voltage and by each current circuit at rated current, shall not exceed the values shown in Table 1.	Power consumption for all models comply with the requirements of Table 1 of IEC62053-22 standard	P
7.2	Influence of short-time overcurrents		P
	Short-time overcurrents shall not damage the meter. The meter shall perform correctly when back to its initial working condition and the variation of error at rated current and unity power factor shall not exceed 0,05 %. The test circuit shall be practically non-inductive and the test shall be performed for polyphase meters phase-by-phase. After the application of the short-time overcurrent with the voltage maintained at the terminals, the meter shall be allowed to return to the initial temperature with the voltage circuit(s) energized (about 1 h).	Tested and comply with the requirements of this clause	P

Заличено по чл.2 от ЗЗЛД

TRF No. IEC62053_22A

ВЯРНО С ОРИГИНАЛА

(+ София) *



IEC 62053-22 / IEC 62052-11			
Clause	Requirement + Test	Result - Remark	Verdict
	The meter shall be able to carry for 0,5 s a current equal to 20 I _{max} with a relative tolerance of +0 % to -10 %.		
7.3	Influence of self-heating		P
	The variation of error due to self-heating shall not exceed the values given in Table 2. The test shall be carried out as follows: after the voltage circuits have been energized at reference voltage for at least 2 h without any current in the current circuits, the maximum current shall be applied to the current circuits. The meter error shall be measured at unity power factor immediately after the current is applied and then at intervals short enough to allow a correct drawing to be made of the curve of error variation as a function of time. The test shall be carried out for at least 1 h, and in any event until the variation of error during 20 min does not exceed 0,05 %. The same test shall then be carried out at 0,5 (inductive) power factor. The cable to be used for energizing the meter shall have a length of 1 m and a cross-section of between 1,5 mm ² and 2,5 mm ² .	Tested, see Appendix 4	P
7.4	AC voltage test	See appended table 7.4	P

8	ACCURACY REQUIREMENTS (IEC 62053-22)		P
8.1	Limits of error due to variation of the current	See Appendix 4	P
8.2	Limits of error due to influence quantities	See Appendix 4	P
8.2.1	Accuracy test in the presence of harmonics		P
8.2.2	Tests of the influence of sub-harmonics		P
8.2.3	Continuous magnetic induction of external origin		P
8.3	Test of starting and no-load condition	See Appendix 4	P
8.3.1	Initial start-up of the meter		P
8.3.2	Test of no-load condition		P
8.3.3	Starting		P
8.4	Meter constant	Considered	P
8.5	Accuracy test conditions	Considered	P
8.6	Interpretation of test results	Considered	P

Заличено по чл.2 от ЗЗЛД

TRF No. IEC62053_22A



IEC 62053-22 / IEC 62052-11			
Clause	Requirement + Test	Result - Remark	Verdict

Table 7.2	TABLE : Temperature Measurements				P
7.2	HEATING. Temperature limits - NORMAL CONDITION				P
Operating conditions:	Normal continuous operation with max load specified by manufacturer: 5A per phase				
Frequency	50 Hz	Test room ambient temperature (t_a)		22 °C	
Voltage	264* V	Test duration		2 h 30 Min	
Part / Location	t_m °C	t_c °C	t_{max} °C	Verdict	Comments
EM133:					
Insulation near L2 contact	26.0	59.0	90	P	Insulation thermal class A (105°C)
Capacitor C7	30.7	63.7	100	P	
Common mode choke T2	31.0	64.0	90	P	Insulation thermal class A (105°C)
Transformer T1 winding	33.7	66.7	90	P	Insulation thermal class A (105°C)
Optocoupler ISO 5	32.4	65.4	100	P	
PCB near transformer T1	30.6	63.6	105	P	
PCB PCO285 near U14	35.8	68.8	105	P	
Battery 3_3V	32.1	65.1	70	P	
Contact panel	29.7	62.7	80	P	
Display panel	31.3	64.3	80	P	
NOTE 4 - See Form A.20B for details of winding temperature measurements					
Supplementary information:					
1. t_c - calculated to the maximum ambient temperature declared by the product manufacturer (55°C).					

Заличено по чл.2 от ЗЗЛД

TRF No. IEC62053_22A



Handwritten initials

IEC 62053-22 / IEC 62052-11			
Clause	Requirement + Test	Result - Remark	Verdict

Table 7.2	TABLE : Temperature Measurements				P
7.2	HEATING. Temperature limits - NORMAL CONDITION				P
Operating conditions:	Normal continuous operation with max load specified by manufacturer: 5A per phase				
Frequency	50 Hz	Test room ambient temperature (t_a)		22 °C	
Voltage	264* V	Test duration		2 h 30 Min	
Part / Location	t_m °C	t_c °C	t_{max} °C	Verdict	Comments
PM130EH PLUS:					
PCB PCO235 near J4	29.7	61.7	105	P	
Transformer T1 winding	36.5	68.5	90	P	Insulation thermal class A (105°C)
Capacitor C5	35.8	67.8	85	P	
Inductance L3	35.8	67.8	90	P	Insulation thermal class A (105°C)
PCB PCO233 near TR	36.5	68.5	105	P	
PCB PCO 210 near U5	38.6	70.6	105	P	
Voltage connector	27.7	59.7	70	P	
AC connector	28.2	60.2	70	P	
Current sensor	26.8	58.8	70	P	
Enclosure rear	26.9	58.9	80	P	
Enclosure up	26.6	58.6	80	P	
Enclosure right side	27.9	59.9	80	P	
Display	29.7	61.7	80	P	
NOTE 4 - See Form A.20B for details of winding temperature measurements					
Supplementary information:					
1. t_c - calculated to the maximum ambient temperature declared by the product manufacturer (55°C).					

Handwritten mark

Залічено по чл.2 от ЗЗЛД

TRF No. IEC62053_22A

Handwritten signature





IEC 62053-22 / IEC 62052-11			
Clause	Requirement + Test	Result - Remark	Verdict

Table 7.2	TABLE : Temperature Measurements					P
7.2	HEATING. Temperature limits - NORMAL CONDITION					P
Operating conditions:	Normal continuous operation with max load specified by manufacturer: 5A per phase					
Frequency	50	Hz	Test room ambient temperature (t_a)	21 °C		
Voltage	264*	V	Test duration	2 h		
Part / Location	t_m °C	t_c °C	t_{max} °C	Verdict	Comments	
PM175:						
Current sensor	35.3	69.3	90	P	Insulation thermal class A (105°C)	
Transformer T2 winding	37.3	71.3	90	P	Insulation thermal class A (105°C)	
PCB PCO196 near R3	33.1	67.1	105	P		
Logic PCB near U3	38.6	72.6	105	P		
Battery	33.6	67.6	80	P		
PCO186 RS232 ISO3	41.6	75.6	85	P		
PCO093 connector J4	37.2	71.2	80	P		
PCO093 Common mode	41.5	75.5	90	P	Insulation thermal class A (105°C)	
PCO093 Capacitor C6	46.3	80.3	105	P		
PCO093 Transformer winding	53.8	87.8	90	P	Insulation thermal class A (105°C)	
PCO093 PCB near Transformer	51.4	85.4	105	P		
Internal wiring	37.0	71.0	80	P		
Enclosure rear panel	31.5	65.5	80	P		
Enclosure left side	35.1	69.1	80	P		
Display panel	36.5	70.5	80	P		
NOTE 4 - See Form A.20B for details of winding temperature measurements						
Supplementary information:						
1. t_c - calculated to the maximum ambient temperature declared by the product manufacturer (55°C).						

Заличено по чл.2 от ЗЗЛД

TRF No. IEC62053_22A



IEC 62053-22 / IEC 62052-11			
Clause	Requirement + Test	Result - Remark	Verdict

Table 7.2	TABLE : Temperature Measurements					P
7.2	HEATING. Temperature limits - NORMAL CONDITION					P
Operating conditions:	Normal continuous operation with max load specified by manufacturer: 5A per phase					
Frequency	50 Hz	Test room ambient temperature (t_a)		20 °C		
Voltage	264* V	Test duration		2 h		
Part / Location	t_m °C	t_c °C	t_{max} °C	Verdict	Comments	
BFM136:						
PCO190 Trans T1 winding	29.0	64.0	90	P	Insulation thermal class A (105°C)	
PCO190 Common mode choke T2	31.7	66.7	90	P	Insulation thermal class A (105°C)	
PCO190 Capacitor C2	31.3	66.3	85	P		
PCO190 PCB near heat sink	33.3	68.3	105	P		
PCO169 Capacitor C167	31.0	66	85	P		
PCO169 PCB near U6	32.7	67.7	105	P		
PCO169 T2 winding	30.4	65.4	90	P	Insulation thermal class A (105°C)	
Enclosure display	27.6	62.6	80	P		
Enclosure up	27.1	62.1	70	P		
Enclosure left side	27.6	62.6	70	P		
NOTE 4 - See Form A.20B for details of winding temperature measurements						
Supplementary information:						
1. t_c - calculated to the maximum ambient temperature declared by the product manufacturer (55°C).						

Заличено по чл.2 от ЗЗЛД

TRF No. IEC62053_22A



IEC 62053-22 / IEC 62052-11			
Clause	Requirement + Test	Result - Remark	Verdict

Table 5.6 TABLE: Clearance and creepage distance measurements								P
Clearance (cl) and creepage distance (cr) at/of/between:	Rated system voltage (V)	Rated impulse voltage (V)	Required Cl, mm		Cl (mm)	Required Cr, mm		Cr (mm)
			Indoor	Outdoor		Indoor	Outdoor	
EM133:								
Functional:								
I1 (phase L1) terminal and "10" (neutral) terminal	<300	4 000	3.0	N/A	7.7	3.2	N/A	7.7
"7" terminal (phase dry contact) and "VN" (neutral) terminal	<300	4 000	3.0	N/A	15.0	3.2	N/A	15.0
Basic/supplementary:								
PCB PCO284. "Com -01" and "N" pads (leads)	<300	4 000	3.0	N/A	6.5	3.2	N/A	6.5
PCB PCO284. "Com -01" and C14 pad (SMPS primary)	<300	4 000	3.0	N/A	6.5	3.2	N/A	6.5
Reinforced:								
I3 terminal (phase L3) and "+x" terminal (interface RS-485)	<300	6 000	5.5	N/A	7.8	6.3	N/A	7.8
ISO5 and ISO6 leads	<300	6 000	5.5	N/A	7.1	6.3	N/A	7.1
Supplementary information: functional insulation meets the requirements of Cl. 5.6., Table 3a								

Заличено по чл.2 от ЗЗЛД



IEC 62053-22 / IEC 62052-11			
Clause	Requirement + Test	Result - Remark	Verdict

Table 5.6 TABLE: Clearance and creepage distance measurements								P
Clearance (cl) and creepage distance (cr) at/of/between:	Rated system voltage (V)	Rated impulse voltage (V)	Required Cl, mm		Cl (mm)	Required Cr, mm		Cr (mm)
			Indoor	Outdoor		Indoor	Outdoor	
PM130EH PLUS:								
Functional:								
PCB PCO235. V3 (phase L3) terminal and "Vn" (neutral) terminal connector J1 – J3	<300	4 000	3.0	N/A	7.0	3.2	N/A	7.0
PCB PCO235. "L" terminal (phase) and "N" (neutral) terminal connector J5	<300	4 000	3.0	N/A	3.5	3.2	N/A	3.5
Basic/supplementary:								
PCB PCO235. "L" pad and "N" track connector J5	<300	4 000	3.0	N/A	3.7	3.2	N/A	3.7
Reinforced:								
PCB PCO235. "N" (netral) lead-pad and "-" lead-pad (interface RS-485) connector J4	<300	6 000	5.5	N/A	5*2=10	6.3	N/A	5*2= 10
PCB PCO235 and PCO233. Components leads in the Primary and the Secondary circuits via spacer.	<300	6 000	5.5	N/A	7.0	6.3	N/A	N/A
Supplementary information: functional insulation meets the requiremetns of Cl. 5.6., Table 3a								

Заличено по чл.2 от ЗЗЛД

TRF No. IEC62053_22A



IEC 62053-22 / IEC 62052-11			
Clause	Requirement + Test	Result - Remark	Verdict

Table 5.6 TABLE: Clearance and creepage distance measurements									P
Clearance (cl) and creepage distance (cr) at/of/between:	Rated system voltage (V)	Rated impulse voltage (V)	Required Cl, mm		Cl (mm)	Required Cr, mm		Cr (mm)	
			Indoor	Outdoor		Indoor	Outdoor		
EM175:									
Functional:									
PCB PCO093 Power supply Casel VAF102. SS11 (Line) and L1 (neutral) leads/pads	<300	4 000	3.0	N/A	3.2	3.2	N/A	3.2	
PCB PCO093. J4 via not used contact	<300	4 000	3.0	N/A	2*1.6 = 3.2	3.2	N/A	2*1.6 = 3.2	
Basic/supplementary:									
RV19 (Line) and C24 (Ground) leads.	<300	4 000	3.0	N/A	7.0	3.2	N/A	7.0	
Reinforced:									
PCB PCO093 Power supply Casel VAF102. Between PC11 leads	<300	6 000	5.5	N/A	7.3	6.3	N/A	7.3	
RV19 lead (Line) and contact 5 J9 (Rs485 interface)	<300	6 000	5.5	N/A	15.7	6.3	N/A	15.7	
R11 pad (Line, V1 circuit) and J22 contact 5 track (COM 1)	<300	6 000	5.5	N/A	18.4	6.3	N/A	18.4	
Supplementary information: functional insulation meets the requirements of Cl. 5.6., Table 3a									

Заличено по чл.2 от ЗЗЛД



IEC 62053-22 / IEC 62052-11			
Clause	Requirement + Test	Result - Remark	Verdict

Clearance (cl) and creepage distance (cr) at/of/between:	Rated system voltage (V)	Rated impulse voltage (V)	Required Cl, mm		Cl (mm)	Required Cr, mm		Cr (mm)
			Indoor	Outdoor		Indoor	Outdoor	
			Table 5.6 TABLE: Clearance and creepage distance measurements					
BFM136								
Functional:								
PCB PCO169. Terminal block J54, J55 leads (V1 or V2 or V3 and Vn)	<300	4 000	3.0	N/A	7.0	3.2	N/A	7.0
PCB PCO190 PH3 (V3) and N leads	<300	4 000	3.0	N/A	6.0	3.2	N/A	6.0
Basic/supplementary:								
PCB PCO169. C27 leads	<300	4 000	3.0	N/A	6.8	3.2	N/A	6.8
J54, J55 leads and left side panel of the enclosure	<300	4 000	3.0	N/A	5.8	3.2	N/A	5.8
The common mode choke T2 winding and grounded rear panel of the enclosure	<300	4 000	3.0	N/A	8.9	3.2	N/A	N/A
Reinforced:								
C2 lead (Primary) and J3 leads (Secondary)	<300	6 000	5.5	N/A	5.8	6.3	N/A	N/A
C11 leads	<300	6 000	5.5	N/A	7.5	6.3	N/A	7.5
ISO1 or ISO2 or ISO3 leads	<300	6 000	5.5	N/A	6.6	6.3	N/A	6.6
Supplementary information: functional insulation meets the requirements of Cl. 5.6., Table 3a								

Заличено по чл.2 от ЗЗД



THE STANDARDS INSTITUTION OF ISRAEL

Electronics & Telematics Laboratory

mgll

Report Ref. No.: 9412301409

APPENDIX 3 ENVIRONMENTAL TEST REPORT

(45 pages including this cover page)

Заличено по чл.2 от ЗЗЛД



IEC 62053-22 / IEC 62052-11			
Clause	Requirement + Test	Result - Remark	Verdict

Table 7.3.3	TABLE: Electric strength tests	P	
Test voltage applied between:	Voltage shape (AC, DC, impulse, surge)	Test voltage (V)	Breakdown Yes / No
EM133:			
Terminal 9 (Phase), terminal 10 (Neutral) and terminal 11 (common)	AC	2000	No
Terminals V1 – V3, I1 – I3 and terminal 11 (common)	AC	2000	No
Terminals V1 – V3, I1 – I3, 9 (phase), 10 (Neutral) and terminals "X+", "X-" (interface RS-485)	AC	2000	No
Terminals V1 – V3, I1 – I3, 9 (phase), 10 (Neutral) and metal foil on the display and terminals covers	AC	2000	No
PM130EH PLUS:			
Terminal J1, J3 (Phase V1, V2, V3, Vn), terminal J5 (L, N,) (Neutral) and terminal J5 (G)	AC	2000	No
Terminal J1, J3 (Phase V1, V2, V3, Vn), terminal J5 (L, N,) (Neutral) and terminal J6 (SH)	AC	2000	No
Terminal J1, J3 (Phase V1, V2, V3, Vn), terminal J5 (L, N,) (Neutral) and terminal J6 ("+", "-" interface RS-485)	AC	2000	No
Terminal J1, J3 (Phase V1, V2, V3, Vn), terminal J5 (L, N,) (Neutral) and metal foil on the display and terminals covers	AC	2000	No
PM175:			
Terminals V1, V2, V3, VN, I1, I2, I3, L, N and terminals marked as protective ground.	AC	2000	No
Terminals V1, V2, V3, VN, I1, I2, I3, L, N and RS485 terminal	AC	2000	No
Terminals V1, V2, V3, VN, I1, I2, I3, L, N and RS232 terminal	AC	2000	No
Terminals V1, V2, V3, VN, I1, I2, I3, L, N and metal foil on display cover	AC	2000	No
BFM136:			
Terminals V1, V2, V3, VN and terminals marked as protective ground	AC	2000	No
Terminals V1, V2, V3, VN and RS485 terminal	AC	2000	No
Terminals V1, V2, V3, VN and RS232 terminal	AC	2000	No
Terminals V1, V2, V3, VN and metal foil on display cover	AC	2000	No
Supplementary information:			

Заличено по чл.2 от ЗЗЛД

TRF No. IEC62053_22A



List of test equipment used:

Testing / measuring equipment / material used				Range used	Calibration date	
SII Ref. No.	Instrument Type	Manufacturer	Model		Last	Due
4875	Power Analyzer	Avpower	PA2200	auto	11/13	11/14
53930	Industrial scopemeter	Fluke	123 S/N DM7540064	auto	11/13	11/14
5047	True RMS Multimeter	Fluke	87III	auto	02/14	02/15
52654	Jointed test finger	PTL	P 10.04	--	02/14	02/17
5972	Ground Bond Tester	Associated Research	3140	auto	12/13	12/14
6501330	Digital Caliper	SIGNET	75430	--	10/13	10/14
52746	Test gauge	PTL	L25.84	--	02/14	02/17
2374	Impact Hammer	PTL	F22.50 No. 9106151.2	--	12/12	12/15
5004 53935	Data Acquisition/Switch Unit with Thermocouples Type J 20-Channel Armature Multiplexer	Agilent	34970A S/N US37030301 34901A S/N US37242806	auto	10/13	10/14
5971	AC/DC Withstand Voltage Tester	Associated Research	3670	auto	12/13	12/14
6501243	Humidity/Baro/Temperature Data Recorder	Lutron	MHB-382SD S/N Q655831	auto	11/13	11/14

Заличено по чл.2 от ЗЗД

TRF No. IEC62053_22A




Handwritten initials or signature.

**APPENDIX 1
PHOTOGRAPHS**

Заличено по чл.2 от ЗЗЛД

Handwritten signature


Fig. 1
BMF136 - overall external views



Залічено по чл.2 от ЗЗЛД

Handwritten mark

Fig. 2
BMF136 – internal board (two sides)



Handwritten mark

Handwritten mark

Заличено по чл.2 от ЗЗЛД

Handwritten signature

Fig. 3
EM133 - overall external views



Handwritten mark




Handwritten signature

Заличено по чл.2 от ЗЗЛД





Fig. 4
EM133 – side view with wiring diagram



Заличено по чл.2 от ЗЗЛД

Fig. 5
EM133 - internal views



Заличено по чл.2 от ЗЗЛД




Handwritten signature

Fig. 6
PM130EH PLUS - overall external views



Handwritten mark

Заличено по чл.2 от ЗЗЛД



my N




Fig. 7
PM130EH PLUS – front view



Заличено по чл.2 от ЗЗЛД




Handwritten mark

Fig. 8
PM130EH PLUS - internal views



Handwritten arrow pointing to the right





Handwritten mark

Заличено по чл.2 от ЗЗД




Fig. 9
PM130EH PLUS - internal views



Залічено по чл.2 от ЗЗЛД

Fig. 10
PM175 - overall external views




Заличено по чл.2 от ЗЗЛД



mjh

Fig. 11
PM175 - internal view



[Handwritten mark]


Заличено по чл.2 от ЗЗЛД

[Handwritten signature]


[Handwritten signature]
[Circular stamp]

Handwritten signature

Fig. 12
PM175 - internal views



Handwritten mark



Handwritten mark

Заличено по чл.2 от ЗЗД



Handwritten signature

APPENDIX 2 EMC TEST REPORT

(57 pages including this cover page)

Handwritten mark

Заличено по чл.2 от ЗЗЛД



The Standards Institution of Israel

This is to certify that:

Equipment Under Test #1: True Power Meter

Name: Multifunctional Power Meter

Model: PM130 PLUS

Equipment Under Test #2: True Power Meter

Name: DIN RAIL Smart Multi Meter

Model: EM133

Equipment Under Test #3: True Power Meter

Name: Multifunctional Power Meter

Model: PM175

Equipment Under Test #4: Energy Management Meter

Name: Branch Feeder Monitor

Model: BFM136

Manufactured by: SATEC Ltd.

**Address: Har Hotzvim Industrial Park, POB 45022
Jerusalem, 91450 Israel**

Tested: 23-24/03, 30/04, 4/05, 13/07, 15-16/07/2014

Has been tested by SII and was found to comply with the requirements of the following standards:

- ❖ IEC 62052-11
Electricity metering equipment (a.c.) -
General requirements, tests and test conditions
Part 11: Metering equipment Ed. 1.0 (2003-02) Section: 7.5.
- ❖ IEC 61000-3-3
Electromagnetic compatibility (EMC). Part 3. Limits.
Section 3. "Limitation of voltage changes, voltage fluctuations and
flicker in public low-voltage supply systems, for equipment with rated
current < 16 A per phase and not subjected to conditional
connection" Ed.2.0 (2008).

Test results are detailed in SII Test Report No. 9412304382

Certificate no.

Date of issue:

Заличено по чл.2 от ЗЗЛД

CERTIFICATE
OF
CONFORMITY





mj

Test Report No.9412304382

Applicant: SATEC Ltd.

Equipment Under Test #1: True Power Meter

Name: Multifunctional Power Meter

Model: PM130 PLUS

Equipment Under Test #2: True Power Meter

Name: DIN RAIL Smart Multi Meter

Model: EM133

Equipment Under Test #3: True Power Meter

Name: Multifunctional Power Meter

Model: PM175

Equipment Under Test #4: Energy Management Meter

Name: Branch Feeder Monitor

Model: BFM136

Issued by:

**The Standards Institution of Israel
Industry Division**

**Electronics & Telematics Laboratory
EMC Branch**

Заличено по чл.2 от ЗЗЛД



Handwritten mark

Test Report No.: 9412304382

Page 1 of 54 Pages

Title: Test on four power meters **PM130 PLUS Multifunctional Power Meter Models:**
PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

Applicant:	SATEC Ltd.
Address:	Har Hotzvim Industrial Park, POB 45022 Jerusalem, 91450 Israel
Sample for test selected by:	The customer
The date of test:	23-24/03, 30/04, 4/05, 13/07, 15-16/07/2014

Description of EUT #1:	True Power Meter
Name:	Multifunctional Power Meter
Model:	PM130 PLUS
Serial No.:	1038842, 1038844
Description of EUT #2:	True Power Meter
Name:	DIN RAIL Smart Multi Meter
Model:	EM133
Serial No.:	1049065, 1049067
Description of EUT #3:	True Power Meter
Name:	Multifunctional Power Meter
Model:	PM175
Serial No.:	1047402, 1047404
Description of EUT #4:	Energy Management Meter
Name:	Branch Feeder Meter
Model:	BFM136
Serial No.:	1048603, 1048607
Manufactured by:	SATEC Ltd.

Reference Documents:


- ❖ IEC 62052-11 Electricity metering equipment (a.c.) - General requirements, tests and test conditions Part 11: Metering equipment Ed. 1.0 (2003-02)
- ❖ IEC 61000-3-3 Electromagnetic compatibility (EMC). Part 3. Limits. Section 3. "Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current < 16 A per phase and not subjected to conditional connection" Ed.2 (2008).

Compliance:

Four EUT units were found to be in compliance with the requirements of the following standards:

- ✓ IEC 62052-11 sec. 7.5.
- ✓ IEC 61000-3-3

Details see in clause 1.



This Test Report contains 54 pages and may be used only in its entirety.	This Test Report applies only to the specimen tested and may not be applied to other specimens of the same product.
--	---



mmj

Test Report No.: 9412304382

Page 2 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models: PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

Table of Contents

1. Summary of Test Results	3
2. EUT Description	7
2.1. General description:	7
2.2. EUT sub-assemblies list:	12
2.3. EUT connector / cable list:	13
2.4. Potential emission sources:	14
2.5. EUT setup and operation:	14
3. Test specification, Methods and Procedures	17
4. Additional deviations or exclusions from the test specifications	18
5. General conditions	18
5.1. Location of the Test Site:	18
5.2. Emission tests:	18
5.3. Initial visual check and functional test:	18
6. Emissions	19
6.1. Radiated Emission Summary	19
6.2. Conducted Emission Summary	22
6.3. Flicker summary	27
7. Immunity Tests	31
7.1. Performance criteria per IEC 62052-11 sec.7.5	31
7.2. Electrostatic Discharge (ESD) immunity test	32
7.3. Radiated Immunity test	33
7.4. Electrical Fast Transients (EFT) immunity test	34
7.5. Surge immunity test	35
7.6. RF conducted immunity test	36
7.7. Ring wave immunity test	37
8. Appendix 1: Test equipment used	38
9. Appendix 2: Antenna factor and cable loss	41
10. Appendix 3: Measurement uncertainty	42
11.	43

S

Заличено по чл.2 от ЗЗЛД

[Handwritten signature]



mjH

Test Report No.: 9412304382

Page 3 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models:
PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

1. Summary of Test Results

Multifunctional Power Meter Model: PM130 PLUS

Test	Standard	Class/ Severity level/lines	Test result
Emission (per IEC 62052-11 sec. 7.5.8)			
Radiated emission Freq. range: 30 - 1000 MHz	CISPR 22	Class A	Complies
Conducted emission Freq. range: 0.15 - 30 MHz		Class A 230VAC mains	Complies
Flicker tests	IEC 61000-3-3	230VAC mains	Complies
Immunity (per IEC 62052-11 sec. 7.5.2 - 7.5.7)			
Immunity from Electrostatic discharge (ESD)	IEC 61000-4-2	8 kV contact discharge 15 kV air discharge	Complies
Immunity from Radiated electromagnetic fields	IEC 61000-4-3	<i>With current:</i> 10 V/m 80 MHz ÷ 2 GHz 80 % AM 1 kHz <i>Without current:</i> 30 V/m 80 MHz ÷ 2 GHz 80 % AM 1 kHz	Complies
Immunity from Electrical Fast transient (EFT)	IEC 61000-4-4	<i>ac mains, Voltage/ Current circuit:</i> ± 4.0kV Tr/Th – 5/50 ns, 5 kHz	Complies
Immunity from Surge	IEC 61000-4-5	<i>ac mains, Voltage circuit:</i> ± 1.0 kV DM Tr/Th – 1.2/50 (8/20) µs	Complies
Immunity from conducted disturbances induced by radio-frequency fields	IEC 61000-4-6	<i>ac mains, Auxiliary circuit:</i> 10 VRMS 0.15-80MHz 80 % AM 1 kHz	Complies
Immunity from Ring wave	IEC 61000-4-12	<i>ac mains, Voltage circuit:</i> ± 1.0 kV DM 20 pulses, ± 2.5kV CM 40 pulses	Complies

Заличено по чл.2 от ЗЗЛД



mjm

Test Report No.: 9412304382

Page 4 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models:
PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

DIN RAIL Smart Multi Meter Model: EM133

Test	Standard	Class/ Severity level/lines	Test result
Emission (per IEC 62052-11 sec. 7.5.8)			
Radiated emission Freq. range: 30 - 1000 MHz	CISPR 22	Class B	Complies
Conducted emission Freq. range: 0.15 - 30 MHz		Class A 230VAC mains	Complies
Flicker tests	IEC 61000-3-3	230VAC mains	Complies
Immunity (per IEC 62052-11 sec. 7.5.2 - 7.5.7)			
Immunity from Electrostatic discharge (ESD)	IEC 61000-4-2	8 kV contact discharge 15 kV air discharge	Complies
Immunity from Radiated electromagnetic fields	IEC 61000-4-3	<i>With current:</i> 10 V/m 80 MHz ÷ 2 GHz 80 % AM 1 kHz <i>Without current:</i> 30 V/m 80 MHz ÷ 2 GHz 80 % AM 1 kHz	Complies
Immunity from Electrical Fast transient (EFT)	IEC 61000-4-4	<i>ac mains, Voltage/ Current circuit:</i> ± 4.0kV Tr/Th – 5/50 ns, 5 kHz	Complies
Immunity from Surge	IEC 61000-4-5	<i>ac mains, Voltage circuit:</i> ± 1.0 kV DM Tr/Th – 1.2/50 (8/20) µs	Complies
Immunity from conducted disturbances induced by radio-frequency fields	IEC 61000-4-6	<i>ac mains, Auxiliary circuit:</i> 10 VRMS 0.15-80MHz 80 % AM 1 kHz	Complies
Immunity from Ring Surge	IEC 61000-4-12	<i>ac mains, Voltage circuit:</i> ± 1.0 kV DM 20 pulses, ± 2.5kV CM 40 pulses	Complies

[Handwritten mark]

Заличено по чл.2 от ЗЗЛД



Test Report No.: 9412304382

Page 5 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models:
PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

Multifunctional Power Meter Model: PM175

Test	Standard	Class/ Severity level/lines	Test result
Emission (per IEC 62052-11 sec. 7.5.8)			
Radiated emission Freq. range: 30 - 1000 MHz	CISPR 22	Class B	Complies
Conducted emission Freq. range: 0.15 - 30 MHz		Class A 230VAC mains	Complies
Flicker tests	IEC 61000-3-3	230VAC mains	Complies
Immunity (per IEC 62052-11 sec. 7.5.2 - 7.5.7)			
Immunity from Electrostatic discharge (ESD)	IEC 61000-4-2	8 kV contact discharge 15 kV air discharge	Complies
Immunity from Radiated electromagnetic fields	IEC 61000-4-3	With current: 10 V/m 80 MHz ÷ 2 GHz 80 % AM 1 kHz Without current: 30 V/m 80 MHz ÷ 2 GHz 80 % AM 1 kHz	Complies
Immunity from Electrical Fast transient (EFT)	IEC 61000-4-4	ac mains, Voltage/ Current circuit: ± 4.0kV Tr/Th – 5/50 ns, 5 kHz	Complies
Immunity from Surge	IEC 61000-4-5	ac mains, Voltage circuit: ± 1.0 kV DM Tr/Th – 1.2/50 (8/20) µs	Complies
Immunity from conducted disturbances induced by radio-frequency fields	IEC 61000-4-6	ac mains, Auxiliary circuit: 10 VRMS 0.15-80MHz 80 % AM 1 kHz	Complies
Immunity from Ring wave	IEC 61000-4-12	ac mains, Voltage circuit: ± 1.0 kV DM 20 pulses, ± 2.5kV CM 40 pulses	Complies

Заличено по чл.2 от ЗЗЛД



Test Report No.: 9412304382

Page 6 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models:
PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

Branch Feeder Meter Model: BFM136

Test	Standard	Class/ Severity level/lines	Test result
Emission (per IEC 62052-11 sec. 7.5.8)			
Radiated emission Freq. range: 30 - 1000 MHz	CISPR 22	Class A	Complies
Conducted emission Freq. range: 0.15 - 30 MHz		Class A 230VAC mains	Complies
Flicker tests	IEC 61000-3-3	230VAC mains	Complies
Immunity (per IEC 62052-11 sec. 7.5.2 - 7.5.7)			
Immunity from Electrostatic discharge (ESD)	IEC 61000-4-2	8 kV contact discharge 15 kV air discharge	Complies
Immunity from Radiated electromagnetic fields	IEC 61000-4-3	With current: 10 V/m 80 MHz ÷ 2 GHz 80 % AM 1 kHz Without current: 30 V/m 80 MHz ÷ 2 GHz 80 % AM 1 kHz	Complies
Immunity from Electrical Fast transient (EFT)	IEC 61000-4-4	ac mains, Voltage/ Current circuit: ± 4.0kV Tr/Th – 5/50 ns, 5 kHz	Complies
Immunity from Surge	IEC 61000-4-5	ac mains, Voltage circuit: ± 1.0 kV DM Tr/Th – 1.2/50 (8/20) µs	Complies
Immunity from conducted disturbances induced by radio-frequency fields	IEC 61000-4-6	ac mains, Auxiliary circuit: 10 VRMS 0.15-80MHz 80 % AM 1 kHz	Complies
Immunity from Ring wave	IEC 61000-4-12	ac mains, Voltage circuit: ± 1.0 kV DM 20 pulses, ± 2.5kV CM 40 pulses	Complies

Заличено по чл.2 от ЗЗЛД

Name: Eng. Yuri Rozenberg
Position: Head of EMC Branch

Tested by: Alexander Karlinas
Position: Testing Engineer

Заличено по чл.2 от ЗЗЛД

Written by: Galit Gorodetsky
Position:

Tested by: Maxim Keizin
Position: Testing Engineer

Заличено по чл.2 от ЗЗЛД

Test Report No.: 9412304382

Page 7 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models:
PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

2. EUT Description

Note: All information in this section was provided by the customer.

2.1. General description:

EUT #1.

Multifunctional Power Meter Model PM130 PLUS:

The Equipment Under Test (hereinafter: EUT) is a low cost multifunctional 3-phase power meter.

The **PM130 PLUS** is True Power-meter, assigned for Energy metering and power quality analysis.

This series provides a cost-effective substitute for numerous analog meters used by industrial, commercial and utility customers for basic power metering

The EUT dimensions: 11.4 x 11.4 x 10.9 cm approx

The EUT power supply: 85-265VAC 50/60/400 Hz, 88-290VDC, 4 W.



Figure 1 PM130 PLUS general view

Заличено по чл.2 от ЗЗД



Handwritten initials

Test Report No.: 9412304382

Page 8 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models: PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

EUT #2.
DIN RAIL Smart Multi Meter Model EM133:

The Equipment Under Test (hereinafter: EUT) is a True Power-meter, assigned for Energy metering and power quality analysis.

The **EM133** is a compact, Din Rail Smart Meter, three-phase AC Power meter (XE-"power") specially designed to meet the requirements of users ranging from electrical panel builders to substation operators.

The EUT dimensions: 9.0 x 12.5 x 7 cm approx
The EUT power supply: 40-300VAC 50/60Hz, 40-300VDC, Burden 5VA.



Figure 2 EM133 general view

Заличено по чл.2 от ЗЗЛД

Test Report No.: 9412304382**Page 9 of 54 Pages****Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models: PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS****EUT #3.****Multifunctional Power Meter Model PM175:**

The Equipment Under Test (hereinafter: EUT) is a True Power-meter, assigned for Energy metering and power quality analysis.

The **PM175** is a multifunctional 3-phase power meter. This series provides a possibility for the complex power quality analysis combined with energy metering.

The EUT dimensions: 13.3 x 12.7 x 12.7 cm approx

The EUT power supply: 85-265VAC 50/60/400 Hz, 88-290VDC, 4 W.

**Figure 3 PM175 general view****EUT #4.****Branch Feeder Meter Model BFM136:**

The Equipment Under Test (hereinafter: EUT) is a 3-phase, multi-channel, multi-function energy meter suitable for use in single-phase and multi-phase electrical networks.

The EUT dimensions: 12.8 x 33.1 x 6.1 cm approx

The EUT power supply: Up to 3 x 277 VAC, 5 W.

**Заличено по чл.2 от ЗЗД**

Handwritten signature

Test Report No.: 9412304382

Page 10 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models: PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS




Figure 5 PM130 PLUS block diagram




Figure 6 EM133 block diagram

Залічено по чл.2 от ЗЗД

M

Test Report No.: 9412304382

Page 11 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models: PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS





Figure 7 PM175 block diagram



Заличено по чл.2 от ЗЗЛД



m/n

Test Report No.: 9412304382

Page 12 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models:
PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

2.2. EUT sub-assemblies list:

Table 1. PM130 PLUS Sub-assemblies list

Description	Mfr	Model
Logic board	SATEC LTD.	PC0210
Analog board	SATEC LTD.	PC0233
CT board	SATEC LTD.	PC0235

Table 2. EM133 Sub-assemblies list

Description	Mfr	Model
Logic board	SATEC LTD.	PC0285
Analog board	SATEC LTD.	PC0284
Display board	SATEC LTD.	PC0286

Table 3. PM175 Sub-assemblies list

Description	Mfr	Model
Logic board	SATEC LTD.	PC0197
Analog board	SATEC LTD.	PC0196
Power Supply board	SATEC LTD.	PC0093

Table 4. BFM136 Sub-assemblies list

Description	Mfr	Model
Motherboard	SATEC LTD.	PC0169
Power Supply	SATEC LTD.	PC0190
Ethernet Module	SATEC LTD.	PC0181

Заличено по чл.2 от ЗЗД

*mg*

Test Report No.: 9412304382

Page 13 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models:
PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

2.3. EUT connector / cable list:

Table 5. PM130 PLUS Connector / Cable list

No.	Connectors description	Connector's type	Type of Cable	Length (m)	Location	No. of identical connectors
1	Voltages	Terminal 4x7.5mm	unshielded	1	Rear Panel	1
2	Power Supply	Terminal 3x7.5mm	unshielded	1		1
3	RS485	Terminal 3x5mm	unshielded	1		1

Table 6. EM133 Connector / Cable list

No.	Connectors description	Connector's type	Type of Cable	Length (m)	Location	No. of identical connectors
1	Voltages	Terminals	unshielded	1	Top Side	4
2	Currents (+)	Terminals	unshielded	1	Top Side	3
3	Currents (-)	Terminals	unshielded	1	Bottom Side	3
4	Power Supply	Terminals	unshielded	1	Bottom Side	2
5	RS485	Terminals	unshielded	1	Bottom Side	2
6	DIG IN	Terminals	unshielded	1	Bottom Side	3
7	DIG OUT	Terminals	unshielded	1	Top Side	2

Table 7. PM175 Connector / Cable list

No.	Connectors description	Connector's type	Type of Cable	Length (m)	Location	No. of identical connectors
1	Voltages	Terminal 4x20 mm	unshielded	1	Rear Panel	1
2	Currents	Terminal 6x10 mm	unshielded	1		1
3	Power Supply	Terminal 2x10 mm	unshielded	1		1
4	RS232/ RS422	DSUB-9	unshielded	1		1
5	DIG IN	Terminal 3x5 mm	unshielded	1		1
6	DIG OUT	Terminal 4x5 mm	unshielded	1		1
7	RS422	Terminal 5x5 mm	unshielded	1		1

Заличено по чл.2 от ЗЗЛД



7/11

Test Report No.: 9412304382

Page 14 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models: PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

Table 8. BFM136 Connector / Cable list

No.	Connectors description	Connector's type	Type of Cable	Length (m)	Location	No. of identical connectors
1	Currents	Terminal 6x5mm	unshielded	1	Front panel	12
2	Voltages	Terminal 4x10mm	unshielded	1	Front panel	1
3	Ground	Screw	unshielded	1	Case	1
4	RS485	Terminal 3x5mm	unshielded	1	Right side	1
5	Ethernet	RJ45	shielded	1	Right side	1

2.4. Potential emission sources:

Table 9. Potential emission sources

Frequency, (MHz)	Location	EUT Model
8	Logic board	PM130 PLUS / EM133
20	Logic board	PM175
20	Motherboard	BFM136

2.5. EUT setup and operation:

The test setup for each EUT is shown in Fig. 9-12.

Each EUT was operated to the normal operation mode.

The list of tests and their applicability is detailed in table 4.

Table 10. List of applicable tests

Mains voltage	Emission tests				Immunity tests					
	IEC 62052-11// CISPR 22		IEC 61000-3-x		IEC 62052-11// IEC 61000-4-x					
	Conduct.	Rad.	-2	-3	-2	-3	-4	-5	-6	-12
230 VAC	✓	✓	NA	✓	✓	✓	✓	✓	✓	✓

"N/A" denotes the test is not applicable, no standard's requirement exists

Заличено по чл.2 от ЗЗЛД



Handwritten mark

Test Report No.: 9412304382

Page 15 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models: PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS




Figure 9. PM130 PLUS Test setup




Figure 10. EM133 Test setup

my 11

Test Report No.: 9412304382

Page 16 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models: PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS





Figure 11. PM175 Test setup



Заличено по чл.2 от ЗЗЛД

Figure 12. BFM136 Test setup



myh

Test Report No.: 9412304382

Page 17 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models: PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

3. Test specification, Methods and Procedures

Test Specification:

- ❖ IEC 62052-11 Electricity metering equipment (a.c.) - General requirements, tests and test conditions Part 11: Metering equipment Ed. 1.0 (2003)
- ❖ IEC 61000-3-3 Electromagnetic compatibility (EMC) Part 3. Limits. Section 3. "Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current < 16 A per phase and not subjected to conditional connection" Ed.2 (2008).

Methods and Procedures:

- ❖ CISPR 22 Information technology equipment - Radio disturbance characteristics - Limits and methods of measurement (2010).
- ❖ IEC 61000-3-3 Electromagnetic compatibility (EMC) Part 3. Limits. Section 3. "Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated current < 16 A per phase and not subjected to conditional connection" Ed.2 (2008).
- ❖ IEC 61000-4 Electromagnetic compatibility (EMC) Part 4. "Testing and measurement techniques;" Section 2: "Electrostatic discharge immunity tests" (1995). Section 3: "Radiated, radio-frequency, electromagnetic field immunity test" (2002). Section 4: "Electrical Fast Transient/burst immunity test" (1995)." Section 5: "Surge immunity tests" (1995). Section 6: "Immunity to conducted disturbances induced by radio-frequency fields" (1996). Section 12: Ring wave immunity test. Ed.2.0 (2006)

ВЪВЕДНО С ПОДПИСИ НА ПД

СЕМ

Заличено по чл.2 от ЗЗЛД



Handwritten mark

Test Report No.: 9412304382

Page 18 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter **Models:** PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

4. Additional deviations or exclusions from the test specifications

Not applicable

5. General conditions

5.1. Location of the Test Site:

The tests were carried out in the EMC laboratory of the Standards Institution of Israel in Tel-Aviv.

5.2. Emission tests:

- * For both radiated and conducted measurements, initial scans were made using a peak detector but still using the appropriate CISPR 16 (Quasi-Peak) detector IF bandwidth.
- * For conducted emissions, a tolerance limit was set 6 dB below the specification limit. Levels above the tolerance limit were retested using the Quasi-Peak detector or an average detector.
- * For radiated emissions, a tolerance limit was set 10 dB below the specification limit. Levels above the tolerance limit were retested using the Quasi-Peak detector.

5.3. Initial visual check and functional test:

Initial visual check and brief built-in test of the EUT was performed before testing. No external damages were found. The test on the EUT passed successfully.

Заличено по чл.2 от ЗЗД



myh

Test Report No.: 9412304382

Page 19 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models: PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

6. Emissions

6.1. Radiated Emission Summary

Reference Documents:

IEC 62052-11 sec.7.5.8// CISPR 22

Test Procedure:

The measurements were conducted in the semi- anechoic chamber.

For each mode of operation the frequency spectrum was monitored. EUT configuration, cable configuration and mode of operation, which produced the emission that had the highest amplitude, were documented.

The frequency range from 30 MHz to 1 GHz was investigated.

Antenna used: Biconilog Antenna (20 MHz - 6000 MHz).

The levels were maximized by initially rotating the turntable through 360°, varying the antenna height between 1 m and 4 m, rerouting EUT cable and changing antenna- to- EUT polarization from vertical to horizontal.

Unless stated otherwise, the measuring equipment settings were:

Initial scan:

Detector type	Peak
Mode	Max hold
Bandwidth	120 kHz
Step size	Continuous sweep
Sweep time	>1 seconds/MHz

Measurements

Detector type	Quasi-peak (CISPR)
Bandwidth	120 kHz/ 1MHz
Measurement time	20 seconds/MHz
Observation	>15 seconds

Test Result:

EUT Model	Ref. Standard	Frequency range	Polar.	Table#	Result	Remarks
PM130 PLUS	CISPR 22 Class A	30-1000 MHz	V/H	11	PASS	The worst result is 9.5dB below limit at 240 MHz
EM133	CISPR 22 Class B			12	PASS	The worst result is 6.4dB below limit at 360 MHz
PM175	CISPR 22 Class B			13	PASS	The worst result is 1.8dB below limit at 215 MHz
BFM136	CISPR 22 Class B			14	PASS	The worst result is 9.4dB below limit at 167.7 MHz

Заличено по чл.2 от ЗЗД



my M

Test Report No.: 9412304382

Page 20 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models:
PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

Results: Pass
 Ref. Standard / Limit: CISPR 22 Class A
 Measured distance: 3m
 Frequency range: 30-1000MHz

Table 11 PM130 PLUS Radiated emission test results

No	Frequency (MHz)	Antenna Polariz	Turn- table Angle (°)	Antenna Height (m)	Emission Level (dB μ V/m)	Limit @ 3 m (dB μ V/m)	Margin (dB)	Results
1	100.0	V	0	1.1	36.7	50	-13.3	Complies
2	114.9	V	360	1.0	38.2	50	-11.8	Complies
3	177.4	H	242	1.2	36.4	50	-13.6	Complies
4	182.6	H	240	1.2	39.6	50	-10.4	Complies
5	192.6	H	212	1.0	38.9	50	-11.1	Complies
6	240.1	H	276	1.4	47.5	57	-9.5	Complies

Results: Pass
 Ref. Standard / Limit: CISPR 22 Class B
 Measured distance: 3m
 Frequency range: 30-1000MHz

Table 12 EM133 Radiated emission test results

No	Frequency (MHz)	Antenna Polariz	Turn- table Angle (°)	Antenna Height (m)	Emission Level (dB μ V/m)	Limit @ 3 m (dB μ V/m)	Margin (dB)	Results
1	37.1	V	269	1.1	32.0	40	-8.0	Complies
2	80.3	V	360	1.1	24.7	40	-15.3	Complies
3	240.0	H	98	1.1	39.2	47	-7.8	Complies
4	360.0	H	57	1.2	40.6	47	-6.4	Complies

Note: Emission level = E Reading (dB μ V) + Cable loss (dB) + Antenna Factor (dB/m)
 For Cable Loss and Antenna Factor refer to Appendix 2.

Заличено по чл.2 от ЗЗЛД



Handwritten mark

Test Report No.: 9412304382

Page 21 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models: PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

Results: Pass
 Ref. Standard / Limit: CISPR 22 Class B
 Measured distance: 3m
 Frequency range: 30-1000MHz

Table 13 PM175 Radiated emission test results

No	Frequency (MHz)	Antenna Polariz	Turn-table Angle (°)	Antenna Height (m)	Emission Level (dBμV/m)	Limit @ 3 m (dBμV/m)	Margin (dB)	Results
1	136.5	H	250	2.6	36.6	40	-3.4	Complies
2	137.9	H	252	2.6	35.8	40	-4.2	Complies
3	148.2	H	262	1.6	31.3	40	-8.7	Complies
4	209.7	H	260	1.9	33.7	40	-6.3	Complies
5	215.1	H	82	1.1	38.2	40	-1.8	Complies
6	223.3	V	335	1.6	33.3	40	-6.7	Complies
7	240.0	H	82	1.1	44.1	47	-2.9	Complies
8	270.3	H	82	1.1	38.3	47	-8.7	Complies

Results: Pass
 Ref. Standard / Limit: CISPR 22 Class A
 Measured distance: 3m
 Frequency range: 30-1000MHz

Table 14 BFM136 Radiated emission test results

No	Frequency (MHz)	Antenna Polariz	Turn-table Angle (°)	Antenna Height (m)	Emission Level (dBμV/m)	Limit @ 3 m (dBμV/m)	Margin (dB)	Results
1	30.6	V	100	1.2	36.6	50	-13.4	Complies
2	167.7	H	258	2.2	40.7	50	-9.4	Complies
3	169.4	H	258	2.0	34.8	50	-15.2	Complies
4	258.7	H	138	1.1	42.3	57	-14.7	Complies
5	312.2	H	41	1.1	40.3	57	-16.7	Complies
6	326.4	H	135	1.2	35.6	57	-21.4	Complies

Заличено по чл.2 от ЗЗД



מ"ח

Test Report No.: 9412304382

Page 22 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter **Models:** PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

6.2. Conducted Emission Summary

Reference Documents:

IEC 62052-11 sec.7.5.8// CISPR 22.

Test procedure:

The measurements were performed on 230VAC mains.

Coupling network used - LISN.

The test was started with an initial scan. The final measurements were performed at each frequency where the signal was 10 dB below the limit or less.

Test equipment (EMI receiver) setup was as follow:

Initial scan:

Detector type	Peak
Mode	Max hold
Bandwidth	9 kHz
Step size	Continuous sweep
Sweep time	>100 msec

Measurements

Detector type	Quasi-peak (CISPR)
Bandwidth	9 kHz
Observation	>15 seconds

Test Result:

EUT Model	Line Description	Ref. standard	Coupling Network	Plot#	Result	Remarks
PM130 Plus	230 VAC mains	CISPR 22 Class A	LISN	#1-2	PASS	All detected peaks are 25dB at least below limit
EM133				#3-4	PASS	All detected peaks are 17dB at least below limit
PM175				#5-6	PASS	All detected peaks are 11dB at least below limit
BFM136				#7-8	PASS	All detected peaks are 7.3dB at least below limit

Заличено по чл.2 от ЗЗЛД



Handwritten initials


Test Report No.: 9412304382

Page 23 of 54 Pages


Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models: PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

Results: Pass
Ref. Standard / Limit: CISPR 22 Class A
Measured line/port: 230VAC mains

Plot 1- Plot 2: PM130 Plus Conducted emission. Phase/ Neutral



Handwritten mark



Handwritten signature

Заличено по чл.2 от ЗЗЛД





Handwritten initials


Test Report No.: 9412304382

Page 24 of 54 Pages


Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models: PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

Results:	Pass
Ref. Standard / Limit:	CISPR 22 Class A
Measured line/port:	230VAC mains

Plot 3- Plot 4: EM133 Conducted emission. Phase/ Neutral



Frequency MHz	Peak dBμA	QP dBμA	Avg dBμA	QP-QP Limit dB	Avg-Avg Limit dB
0.24	58.7	51.9	48.0	-27.1	-18.0
0.25	64.2	61.3	47.0	-17.7	-19.0
0.49	60.6	54.9	42.6	-24.1	-23.4
0.77	55.8	51.1	37.3	-21.9	-22.7
0.93	54.6	46.5	33.0	-26.5	-27.0
1.04	53.1	47.3	31.2	-25.7	-28.8



Frequency MHz	Peak dBμA	QP dBμA	Avg dBμA	QP-QP Limit dB	Avg-Avg Limit dB
0.25	64.1	61.6	45.0	-17.4	-21.0
0.37	58.3	51.5	39.3	-27.5	-26.7
0.50	60.4	55.3	45.2	-23.7	-20.8
0.61	55.1	46.7	32.2	-26.3	-27.8

Заличено по чл.2 от ЗЗЛД



Handwritten mark


Test Report No.: 9412304382

Page 25 of 54 Pages


Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models: PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

Results:	Pass
Ref. Standard / Limit:	CISPR 22 Class A
Measured line/port:	230VAC mains

Plot 5- Plot 6: PM175 Conducted emission. Phase/ Neutral



Frequency MHz	Peak dBμA	QP dBμA	Avg dBμA	QP-QP Limit dB	Avg-Avg Limit dB
0.20	56.8	55.4	53.3	-23.6	-12.7
0.30	54.3	52.9	49.7	-26.1	-16.3
0.41	53.7	52.8	51.7	-26.2	-14.3
0.51	53.2	52.1	48.9	-20.9	-11.1
0.61	52.0	51.4	45.2	-21.6	-14.8
0.71	45.9	44.9	42.1	-28.1	-17.9



Frequency MHz	Peak dBμA	QP dBμA	Avg dBμA	QP-QP Limit dB	Avg-Avg Limit dB
0.20	56.9	55.2	53.0	-23.8	-13.0
0.31	54.3	52.5	50.9	-26.5	-15.1
0.40	53.9	52.9	51.5	-26.1	-14.5
0.51	53.6	52.6	48.4	-20.9	-11.1
0.61	52.0	51.1	44.2	-21.6	-14.8
0.71	45.7	44.8	42.3	-28.1	-17.9

Заличено по чл.2 от ЗЗЛД

Handwritten signature





Handwritten signature


Test Report No.: 9412304382

Page 26 of 54 Pages


Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models: PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

Results:	Pass
Ref. Standard / Limit:	CISPR 22 Class A
Measured line/port:	230VAC mains

Plot 7- Plot 8: BFM136 Conducted emission. Phase/ Neutral




Frequency MHz	Peak dBμA	QP dBμA	Avg dBμA	QP-QP Limit dB	Avg-Avg Limit dB
0.20	66.8	54.4	42.0	-24.6	-24.0
0.27	67.0	59.1	56.6	-19.9	-9.4
0.35	64.3	59.1	42.7	-19.9	-23.3
0.48	61.4	55.2	42.6	-23.8	-23.4
0.55	58.4	55.2	42.5	-17.8	-17.5
0.62	56.0	53.5	41.2	-19.5	-18.8



Frequency MHz	Peak dBμA	QP dBμA	Avg dBμA	QP-QP Limit dB	Avg-Avg Limit dB
0.17	63.1	59.7	49.5	-19.3	-16.5
0.27	68.0	61.1	58.7	-17.9	-7.3
0.33	67.0	60.8	43.8	-18.2	-22.7
0.39	62.3	54.9	44.2		
0.52	62.4	59.8	46.1		
0.55	60.3	57.4	46.0	-15.0	-14.0

Заличено по чл.2 от ЗЗД





Handwritten signature

Test Report No.: 9412304382

Page 27 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models: PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

6.3. Flicker summary

Results: Pass
Ref. Standard: IEC 61000-3-3
Mains: 230VAC

Table 15. PM130 PLUS Flicker data

Product:	SATEC PM130EH				
Serial No:					
Description:					
Voltech IEC61000-3 Windows Software 1.24.12	Test Date:	2014 Jul 13 17:43			
Result:	SATEC PM130EH				
Type of Test:	Flickermeter Test - Table				
Power Analyzer:	Voltech PM6000 SN: 200006700333 Firmware version: v1.22.07RC6				
AC Source:	Mains / Manual Source				
Overall Result	PASS				
Notes:	Plt test duration only 20 minutes Measurement method - Voltage				
	Plt				
Limit	0.65				
Reading	0.046				
	Pst	dc(%)	dmax(%)	3.3	
Limit	1	3.3	4	500	
Reading 1	0.083	0	0	0	
Reading 2	0.083	0	0	0	

Handwritten signature

Заличено по чл.2 от ЗЗЛД



Handwritten signature

Test Report No.: 9412304382

Page 28 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models: PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

Table 16. EM133 Flicker data

Product:	SATEC EM133				
Serial No:					
Description:					
Voltech IEC61000-3 Windows Software 1.24.12	Test Date:	2014 Jul 13 14:51			
Result:	SATEC EM133				
Type of Test:	Flickermeter Test - Table				
Power Analyzer:	Voltech PM6000 SN: 200006700333 Firmware version: v1.22.07RC6				
AC Source:	Mains / Manual Source				
Overall Result	PASS				
Notes:	Plt test duration only 20 minutes Measurement method - Voltage				
	Plt				
Limit	0.65				
Reading	0.047				
	Pst				
	dc(%)	dmax(%)	3.3		
Limit	1	3.3	4	500	
Reading 1	0.085	0	0.706	0	
Reading 2	0.085	0	0.705	0	

Handwritten mark

Заличено по чл.2 от ЗЗЛД

Handwritten signature





my M

Test Report No.: 9412304382

Page 29 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models: PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

Table 17. PM175 Flicker data

Product:	SATEC PM175				
Description:					
Voltech IEC61000-3 Windows Software 1.24.12	Test Date:	2014 Jul 15 08:37			
Result:	SATEC PM175				
Type of Test:	Flickermeter Test - Table				
Power Analyzer:	Voltech PM6000 SN: 200006700333 Firmware version: v1.22.07RC6				
AC Source:	Mains / Manual Source				
Overall Result	PASS				
Notes:	Plt test duration only 20 minutes Measurement method - Voltage				
	Plt				
Limit	0.65				
Reading	0.046				
	Pst	dc(%)	dmax(%)	3.3	
Limit	1	3.3	4	500	
Reading 1	0.084	0	0	0	
Reading 2	0.084	0	0	0	

[Handwritten mark]

[Handwritten mark]

Заличено по чл.2 от ЗЗЛД





Handwritten initials

Test Report No.: 9412304382

Page 30 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models: PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

Table 18. BFM136 Flicker data

Product:	SATEC BFM136			
Serial No:				
Description:				
Voltech IEC61000-3 Windows Software 1.24.12	Test Date:	2014 Jul 15 11:43		
Result:	SAREC BFM136			
Type of Test:	Flickermeter Test - Table			
Power Analyzer:	Voltech PM6000 SN: 200006700333 Firmware version: v1.22.07RC6			
AC Source:	Mains / Manual Source			
Overall Result	PASS			
Notes:	Plt test duration only 20 minutes Measurement method - Voltage			
	Plt			
Limit	0.65			
Reading	0.046			
	Pst	dc(%)	dmax(%)	3.3
Limit	1	3.3	4	500
Reading 1	0.084	0	0.803	0
Reading 2	0.084	0	0.797	0

Handwritten mark

Заличено по чл.2 от ЗЗЛД

Handwritten signature

Stamp: THE STANDARDS INSTITUTION OF ISRAEL





4711

Test Report No.: 9412304382

Page 31 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter **Models:**
PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

7. Immunity Tests

7.1. Performance criteria per IEC 62052-11 sec.7.5

(a):

During the test the behavior of the equipment shall not be perturbed and the variation of the error shall be within the limits as specified in the relevant standards.

(b):

During the test a temporary degradation or loss of function or performance is acceptable

(c):

The application of the EMC disturbance shall not produce a change in the register of more than x units and the test output shall not produce a signal equivalent to more than x units. (formula for x is in IEC 62052-11 sec.7.1.2).

Заличено по чл.2 от ЗЗЛД



Test Report No.: 9412304382

Page 32 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models:
PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

7.2. Electrostatic Discharge (ESD) immunity test

Results: Pass
Ref. Standard: IEC 62052-11 sec. 7.5.2
Test procedure: IEC 61000-4-2
Temperature: 23°C
Relative humidity: 45%
Athmosph. pressure: 1010 mbar
Performance criteria: See sec.7.1 (b), (c).

Table 19 PM130 Plus / EM133/ PM175 ESD Data

ESD type	Test points	Test Voltage (kV)	Number of pulses	EUT performance during test	Result
Contact	HCP	2,4,6,8	+/--(4*20)	NP	PASS
	VCP	2,4,6,8	+/--(4*20)	NP	PASS
Air	Front panel	2,4,6,8, 15	+/--(4*20)	NP	PASS

Table 20 BFM136 ESD Data

ESD type	Test points	Test Voltage (kV)	Number of pulses	EUT performance during test	Result
Contact	HCP	2,4,6,8	+/--(4*20)	NP	PASS
	VCP	2,4,6,8	+/--(4*20)	NP	PASS
	Enclosure - metal parts	2,4,6,8	+/--(4*20)	NP	PASS
Air	Front panel	2,4,6,8, 15	+/--(4*20)	NP	PASS

NP.

Заличено по чл.2 от ЗЗЛД

Test Result: All tested units continued to operate as intended. No change in the readings was observed during and after the test.



Handwritten signature

Test Report No.: 9412304382

Page 33 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models: PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

7.3. Radiated Immunity test

Results:	Pass
Ref. Standard:	IEC 62052-11 sec. 7.5.3
Test procedure:	IEC 61000-4-3
Temperature:	23°C
Relative humidity:	45%
Athmosph. pressure:	1010 mbar
Performance criteria:	<u>test with current:</u> See sec.7.1 (a) <u>test without current:</u> See sec.7.1 (b), (c)

Handwritten signature

Table 21 Radiated Immunity Data

Test parameters	EUT performance	Result
Test with current: EUT is loaded with 1A Load 10 V/m 80 ÷ 2000 MHz 80 % AM 1 kHz	NP	PASS
Test without current: No Load 30 V/m 80 ÷ 2000 MHz 80 % AM 1 kHz	NP	PASS

Test Result: All tested units continued to operate as intended. No change in the readings was observed during and after the test.

Заличено по чл.2 от ЗЗД

Handwritten signature





mjd

Test Report No.: 9412304382

Page 34 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models: PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

7.4. Electrical Fast Transients (EFT) immunity test

Results:	Pass
Ref. Standard:	IEC 62052-11 sec. 7.5.4
Test procedure:	IEC 61000-4-4
Temperature:	23°C
Relative humidity:	45%
Athmosph. pressure:	1010 mbar
Performance criteria:	See sec.7.1 (b), nevertheless the variation of the error shall be within the limits as specified in the relevant standards.

[Handwritten mark]

Table 22 EFT Data

No.	Port / Cable Description	Type of coupling	Test Voltage kV	Impulse	EUT performance during test	Result
1	230VAC mains	CDN	± 4.0 CM	Tr/Th – 5/50 ns, 5 kHz	NP	PASS
2	Voltage/ Current circuit	CDN	± 4.0 CM	Tr/Th – 5/50 ns, 5 kHz	NP	PASS

Test Result: All tested units continued to operate as intended. No change in the readings was observed during and after the test.

Заличено по чл.2 от ЗЗД

ВЯРНО С ОРИГИНАЛА



[Handwritten signature]



Handwritten signature

Test Report No.: 9412304382

Page 35 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter **Models:** PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

7.5. Surge immunity test

Results:	Pass
Ref. Standard:	IEC 62052-11 sec. 7.5.6
Test procedure:	IEC 61000-4-5
Temperature:	23°C
Relative humidity:	45%
Athmosph. pressure:	1010 mbar
Performance criteria:	See sec.7.1 (b), (c)

Table 23: Surge Data

No.	Port / Cable Descript.	Test Voltage kV	Type of coupling	Type of Surge, μ s	Number of Pulses	EUT perform. during test	Result
1	AC mains	± 1.0 DM	CDN	1.2/50 (8/20)	± 20	NP	PASS
2	Voltage circuit	± 1.0 DM	CDN	1.2/50 (8/20)	± 20	NP	PASS

Test Result: All tested units continued to operate as intended. No change in the readings was observed during and after the test.

Заличено по чл.2 от ЗЗЛД

Handwritten signature





Handwritten signature

Test Report No.: 9412304382

Page 36 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models: PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

7.6. RF conducted immunity test

Results: Pass
Ref. Standard: IEC 62052-11 sec. 7.5.5
Test procedure: IEC 61000-4-6
Temperature: 23°C
Relative humidity: 45%
Athmosph. pressure: 1010 mbar
Performance criteria: See sec.7.1 (a)

Table 24 RF Conducted Immunity Data

No	Port/Cable Description	Type of coupling	Frequency range, MHz	Voltage level, Vrms	Modulation	EUT perform. during test	Result
1	AC mains	CDN	0.15 ÷ 80	10.0	AM 80% 1 kHz	NP	PASS
2	Auxiliary circuit	Coupling clamp				NP	PASS

Test Result: All tested units continued to operate as intended. No change in the readings was observed during and after the test.

Заличено по чл.2 от ЗЗЛД

Handwritten signature

Handwritten signature





Handwritten signature

Test Report No.: 9412304382

Page 37 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models: PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

7.7. Ring wave immunity test

Results: Pass
Ref. Standard: IEC 62052-11 sec. 7.5.7
Test procedure: IEC 61000-4-12
Temperature: 23°C
Relative humidity: 45%
Athmosph. pressure: 1010 mbar
Performance criteria: See sec.7.1 (b)

Table 25: Ring wave Data

No.	Port / Cable Descript.	Test Voltage kV	Type of coupling	Number of Pulses	EUT perform. during test	Result
1	AC mains Voltage circuit	± 1.0 DM	CDN	± 20	NP	PASS
2	AC mains Voltage circuit	± 2.5 CM	CDN	± 40	NP	PASS

Test Result: All tested units continued to operate as intended. No change in the readings was observed during and after the test.

Заличено по чл.2 от ЗЗЛД



*mjl***Test Report No.: 9412304382****Page 38 of 54 Pages****Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models: PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS****8. Appendix 1: Test equipment used**

All measurements equipment is on SII calibration schedule with a recalibration interval not exceeding once a year.

Instrument	Manufacturer	Model	SII No.	Last calibration date	Next calibration date
CISPR 22					
EMI Receiver 9 kHz - 6.5 GHz	HP	8546A+85460A	4068	06/14	06/15
EMI Analyzer 10 kHz - 26.5 GHz	HP	E7405A	4944	05/14	05/15
EMI Test Receiver 20 Hz - 40 GHz	ROHDE & SCHWARZ	R&S®ESU40	5911	11/13	11/14
LISN 9 kHz - 30 MHz	FCC	LISN- 50/250-32-4-16	5023	12/13	12/14
Transient limiter 0.009-200 MHz	Agilent Techn	11947A	3107A03104	08/13	08/14
Antenna Mast	Frankonia	FAM6	5952	N/A	N/A
Metallic turntable	Frankonia	FTM2-2	5952	N/A	N/A
Positioning controller	Frankonia	FCO2	5952	N/A	N/A
Biconilog Antenna 20 MHz - 6000 MHz	ETS Lindgren	3142D- SN:00146488	-	12/13	12/14
IEC 61000-3-3					
AC Power Supply	Elgar	SW 5250A	4684	N/A	N/A
Universal Power Analyzer 230 VAC, 3ph, 30A	Voltech	PM 6000	6501179	08/13	08/14

Заличено по чл.2 от ЗЗЛД



M/M

Test Report No.: 9412304382

Page 39 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models:
PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

Instrument	Manufacturer	Model	SII No.	Last calibration date	Next calibration date
IEC 61000-4-2					
ESD Simulator, Contact Disch.: ± 0.5 to ± 8 kV, Air Discharge: ± 0.5 to ± 15 kV	Teseq AG	NSG.435	606332	11/13	11/14
IEC 61000-4-3					
Spectrum Analyzer 9 kHz - 6 GHz	ROHDE & SCHWARZ	R&S@FSL6	5912	06/14	06/15
MXG Analog Microwave Signal generator 100 KHz - 20 GHz	Agilent	N5183A	6501148	05/14	05/16
RF power amplifier 80-1000 MHz, 100W	Amplifier Research	100W1000M1	4883	N/A	N/A
Biconilog Antenna 30 - 2000 MHz	Schaffner	CBL 6112B	5119	01/14	01/15
Horn Antenna High-Gain 0.8 - 4.2 GHz; 20 W	Amplifier Research	AT4002A	4966	N/A	N/A
RF Power Amplifier 0.8 - 4.2 GHz; 25 W	Amplifier Research	25S1G4A	4991	N/A	N/A
Electric Field Probe 100 kHz - 3000 MHz	PMM	EP 330	5448	01/14	01/15
Field Monitor 0.15 - 3000 V/m	Amplifier Research	FM5004	4956	N/A	N/A
Anechoic chamber	Chase	Euroshield	4806	N/A	N/A
IEC 61000-4-4					
Advanced EMC Immunity Sys.	Key-Tek	EMC PRO	4695	10/13	10/14
Capacitive coupling clamp	Key-Tek	CCL-4/S	9412243	N/A	N/A

Заличено по чл.2 от ЗЗЛД



mjt

Test Report No.: 9412304382

Page 40 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models:
PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

Instrument	Manufacturer	Model	SII No.	Last calibration date	Next calibration date
IEC 61000-4-5/ IEC 61000-4-12					
ECAT Control Center:	Key-Tek	ECAT	3751	06/14	06/15
Surge generator		E501A			
EFT/Surge Coupler/Decoupler		E4553			
Advanced EMC Immunity Sys.	Key-Tek	EMC PRO	4695	10/13	10/14
Capacitive coupling clamp	Key-Tek	CCL-4/S	S/N 9412243	N/A	N/A
IEC 61000-4-6					
RF Generator 10 kHz - 1040 MHz	HP	8657A	4923	03/14	03/15
RF Generator 100 KHz - 20 GHz	Agilent	N5183A	6501148	05/13	05/14
RF Generator 10 kHz - 1050 MHz	Fluke	6060B	2384	04/14	04/15
RF power amplifier 10 kHz - 250 MHz; 75 W	Ampl Research	75A250	4847	N/A	N/A
RF power amplifier 150 kHz - 300 MHz; 10 W	ENI	411LA	SII 3757 SN: 797F	N/A	N/A
Oscilloscope 300 MHz	Lecroy	9361	4009	12/13	12/14
CDN 150 kHz - 230 MHz	FCC	801-M3-16	51906	11/13	11/14
CDN 150 kHz - 230 MHz	Schaffner	CDN M325	5122	11/13	11/14
Attenuator 6 dB, 50W	Huber-Suhner AG	5906.17.006	S/N 302789	08/13	08/14
Bulk Current Injection Probe 10 kHz - 230 MHz	FCC	F-120-9A	53923	11/13	11/14

Заличено по чл.2 от ЗЗЛД



Handwritten signature

Test Report No.: 9412304382

Page 41 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models: PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

9. Appendix 2: Antenna factor and cable loss

Cable Loss (10m cable + Mast)

Point	Frequency (MHz)	Cable Loss (dB)	Point	Frequency (MHz)	Cable Loss (dB)	Point	Frequency (MHz)	Cable Loss (dB)
1	30	0.53	15	700	3.06	28	1700	4.85
2	50	0.75	16	750	3.201	29	1800	4.98
3	100	1.08	17	800	3.27	30	1900	5.19
4	150	1.39	18	850	3.38	31	2000	5.34
5	200	1.61	19	900	3.46	32	2100	5.51
6	250	1.752	20	950	3.55	33	2200	5.69
7	300	2.00	21	1000	3.68	34	2300	5.89
8	350	2.15	22	1100	3.82	35	2400	6.07
9	400	2.26	23	1200	4.07	36	2500	6.22
10	450	2.383	30	1900	5.19	37	2600	6.28
11	500	2.52	24	1300	4.24	38	2700	6.41
12	550	2.606	25	1400	4.43	39	2800	6.53
13	600	2.75	26	1500	4.6	40	2900	6.84
14	650	2.856	27	1600	4.7			

Handwritten mark

Antenna Factor

Biconilog Antenna, MFR ETS Lindgren, Type/Model 3142D, S/N: 00146490, 3 m distance

No.	f / MHz	AF / dB/m	f / MHz	AF / dB/m	f / MHz	AF / dB/m
1	30	18.7	250	12.0	2750	31.0
2	35	15.7	300	13.8	3000	31.2
3	40	12.9	400	16.2	3250	32.7
4	45	10.6	500	18.6	3500	34.5
5	50	9.0	600	20.2	3750	34.3
6	60	7.3	700	21.8	4000	34.5
7	70	7.7	800	22.9	4250	35.3
8	80	8.2	900	24.1	4500	35.5
9	90	9.2	1000	24.8	4750	36.1
10	100	9.4	1250	26.9	5000	37.4
11	120	8.5	1500	30.2	5250	38.4
12	140	8.5	1750	28.5	5000	39.9
13	160	9.1	2000	28.9	5750	38.2
14	180	10.5	2250	29.8	6000	39.1
15	200	10.9	2500	32.5		

Handwritten signature

Заличено по чл.2 от ЗЗЛД





Handwritten signature

Test Report No.: 9412304382

Page 42 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models: PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

10. Appendix 3: Measurement uncertainty

The test equipment has been calibrated according to its recommended procedures and is within the manufacturer's published limit of error. The laboratory calibrates its standards by a third party (traceable to NIST, USA) on a regular basis according to equipment manufacturer requirements. In the following table the uncertainty calculation is given. Calculated uncertainty U_{LAB} are less than U_{CISPR} , therefore compliance is deemed to occur if no measured disturbance level exceeds the disturbance limit.

Type of disturbance Test description	Calculated uncertainty U_{LAB}	U_{CISPR}
Conducted disturbance at mains port (9 kHz to 150 kHz)	3.3 dB	3.8 dB
Conducted disturbance at mains port (150 kHz to 30 MHz)	2.8 dB	3.4 dB
Disturbance power (30 MHz to 300 MHz)	3.3 dB	4.5 dB
Radiated disturbance (electric field strength at an OATS at 10 m distance) (30 MHz to 1 000 MHz)	4.18 dB	6.3 dB
Radiated disturbance (electric field strength in a SAR at 3 m distance) (30 MHz to 1 000 MHz)	4.32 dB	6.3 dB
Radiated disturbance (electric field strength in a FAR) (1 GHz to 6 GHz)	4.47 dB	5.2 dB
Radiated disturbance (electric field strength in a FAR) (6 GHz to 18 GHz)	4.47 dB	5.5 dB

The expanded uncertainty at a level of 95% confidence is obtained by multiplying the combined standard uncertainty by coverage factor of 2.

Заличено по чл.2 от ЗЗЛД





Handwritten signature

Test Report No.: 9412304382

Page 43 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models: PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS

11. Appendix 4: Test illustrations



Handwritten mark

Handwritten mark

Picture #1 PM 130 Plus Radiated emission test





my 11

Test Report No.: 9412304382

Page 44 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models:
PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS



2

Picture #2
PM 130 Plus Radiated emission test setup

[Handwritten signature]

Заличено по чл.2 от ЗЗЛД






Handwritten signature


Test Report No.: 9412304382

Page 45 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models:
PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS



Handwritten mark



Picture #3 PM 130 Plus Immunity test setup

Handwritten signature

Заличено по чл.2 от ЗЗЛД






Handwritten signature

Test Report No.: 9412304382

Page 46 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter **Models:**
PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS



Handwritten mark

Picture #4

EM133 Radiated emission test setup

Заличено по чл.2 от ЗЗЛД



Handwritten signature



Handwritten signature

Test Report No.: 9412304382

Page 47 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models: PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS



Picture #5
EM133 Radiated emission test setup

Заличено по чл.2 от ЗЗЛД

ВЪРТИ С ОГНИВАНИЕ





Handwritten signature

Test Report No.: 9412304382

Page 48 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models:
PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS



Picture #6 EM133 Immunity test setup

Заличено по чл.2 от ЗЗЛД




Handwritten signature

Test Report No.: 9412304382

Page 49 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models:
PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS




Handwritten mark

Picture #7
PM175 Radiated emission test setup

Заличено по чл.2 от ЗЗД

Handwritten signature






Handwritten signature

Test Report No.: 9412304382

Page 50 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models:
PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS



Picture #8
PM175 Radiated emission test setup

Заличено по чл.2 от ЗЗЛД





my 81

Test Report No.: 9412304382

Page 51 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models:
PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS



Handwritten scribble

Picture #9 PM175 Immunity tests

Заличено по чл.2 от ЗЗЛД

Handwritten signature







Handwritten signature

Test Report No.: 9412304382

Page 52 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter **Models:** PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS



Picture #10 BFM136 Radiated emission test setup

Заличено по чл.2 от ЗЗЛД




Handwritten mark

Test Report No.: 9412304382

Page 53 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models:
PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS



Handwritten mark

Picture #11
BFM136 Radiated emission test setup

Заличено по чл.2 от ЗЗЛД





Handwritten signature

Test Report No.: 9412304382

Page 54 of 54 Pages

Title: Test on four power meters PM130 PLUS Multifunctional Power Meter Models:
PM130 PLUS, EM133, PM175, BFM136 PM130 PLUS



Picture #12 BFM136 Immunity tests

Залічено по чл.2 от 33ЛД

my 11

Electromagnetic Compatibility Test Report

Test Report No: STC 070711
Issued on: July 07, 2011

Product Name
The Expertmeter™ EM133 Series
S/N 12345685

Tested According to
IEC 62052-11 Edition 1: 2003
IEC 60688 Edition 2.2: 2002

[Handwritten signature]

Tests Performed for
SATEC Ltd.
Har Hotzvim, P.O.Box 45022, Jerusalem 91450
Phone: +972-2-541100

QualiTech EMC Laboratory, ECI Telecom
30 Hasivim Street,
Petah-Tikva, 49517, Israel
Tel: +972-3-926 8443
Fax: +972-3-928 7490



[Handwritten signature]

Заличено по чл.2 от ЗЗЛД



Handwritten signature

The information contained herein is the property of QualiTech, EMC Lab and is supplied without liability for errors or omissions.

*The copyright for this document vests in QualiTech, EMC Lab.
All rights reserved.*

This Test Report may not be reproduced, by any method, without the written permission of the QualiTech, EMC Lab.

If and when such permission is granted, the report must be reproduced only in the full format.

Test Personnel

Tests Performed By: _____
Michael _____ Sergey Kapustin

Handwritten signature

Report Prepared By: _____
Bina T_____

Handwritten signature


Report Reviewed By: _____
Rami _____
EMC _____
Quali _____
_____ nager
_____ C Laboratory

Заличено по чл.2 от ЗЗЛД

Handwritten signature

Handwritten signature

Заличено по чл.2 от ЗЗЛД



Handwritten signature

Test Report Details:

Test commencement date: 21.06.2011
Test completion date: 28.06.2011
Customer's representative: Ilya Jacobi
Issued on: 07.07.2011

Assessment Information:

This report contains an assessment of the EUT against Electromagnetic Compatibility based upon tests carried out on the samples submitted. The results contained in this report relate only to the items tested. Manufactured products will not necessarily give identical results due to production and measurement tolerances. QualiTech, EMC Lab does not assume responsibility for any conclusion and generalization drawn from the test results with regards to other specimens or samples of type of the equipment represented by test item.

Handwritten signature

The EUT was setup and exercised using the configuration, modes of operation and arrangements defined in this report only.

Customer's declaration:

All the information and test results presented in Appendix A were provided by SATEC Ltd. and the relevant testing was performed by the SATEC staff in QualiTech Lab.

Modifications:

Modifications made to the EUT

None

Modifications made to the Test Standard

None

Handwritten signature

Заличено по чл.2 от ЗЗЛД





Summary of Compliance Status

The EUT was tested according to the following test methods.
Test results are given in full in sections 3+14.

Emission Tests

Test type	Applied on	Test Method	Class applied	Frequency Range	Test results
Radiated Emission	System	CISPR 22	B	30MHz+1GHz	Comply
Conducted Emission	230 VAC	CISPR 22	A	150kHz+30MHz	Comply
	3 Phase AC	CISPR 22	B	150kHz+30MHz	Comply
	RS485		Not applicable		
	Input		Not applicable		
	Output		Not applicable		

Immunity Tests

Test type	Applied on	Test Method	Frequency Range/ application type	Test Voltage/ Stress	Performance Criteria applied	Test results
ESD	Enclosure	IEC 61000-4-2 IEC 62052-11/7.5.2	Contact	±8kV	B	Comply
			Air	±15kV	B	Comply
Radiated Immunity	System	IEC 61000-4-3 IEC 62052-11/7.5.3	80MHz + 1GHz	10V/m	A	Comply
			1GHz + 2GHz	10V/m	A	Comply
			80MHz + 1GHz	30V/m	A	Comply
			1GHz + 2GHz	30V/m	A	Comply
EFT	230 VAC	IEC 61000-4-4 IEC 62052-11/7.5.4	-	±4kV	A	Comply
	3 Phase AC		-	±4kV	A	Comply
	RS485		-	±2kV	A	Comply
	Input		-	±2kV	A	Comply
	Output		-	±2kV	A	Comply
Surge	230 VAC	IEC 61000-4-5 IEC 62052-11/7.5.6	Line to Line	±4kV	A	Comply
	3 Phase AC		Line to Line	±4kV	A	Comply
	RS485		Not applicable			
	Input		Not applicable			
	Output		Line to Line	±4kV	A	Comply
Conducted Immunity	230 VAC	IEC 61000-4-6 IEC 62052-11/7.5.5	150kHz+80MHz	10Vrms	A	Comply
	3 Phase AC		150kHz+80MHz	10Vrms	A	Comply
	RS485		150kHz+80MHz	10Vrms	A	Comply
	Input		150kHz+80MHz	10Vrms	A	Comply
	Output		150kHz+80MHz	10Vrms	A	Comply
Magnetic Field	System	IEC 61000-4-8	50Hz	400A/m	A	Comply
Oscillatory Waves	230 VAC	IEC 61000-4-12 IEC 62052-11/7.5.7	Line to Line	± 1	A	Comply
			Line to Earth	± 2.5	A	Comply
	3 Phase AC		Line to Line	± 1	A	Comply
			Line to Earth	± 2.5	A	Comply
	DO		Line to Line	± 1	A	Comply
			Line to Earth	± 2.5	A	Comply

Заличено по чл.2 от ЗЗЛД

Handwritten signature

Test type	Applied on	Test Method	Frequency Range/ application type	Test Voltage/ Stress	Performance Criteria applied	Test results
Ambient temperature	-	IEC 60688 section 6.4	-	4kVrms/1min	A	Comply
AC Voltage insulation	-	IEC 61010-1	-	4kVrms/1min	A	Comply
		IEC 62052-11/7.3.3	-	4kVrms/1min	A	Comply
		IEC 62052-11/7.3.3	-	4kVrms/1min	A	Comply
Impulse Voltage tests	All Terminals connected together	IEC 60688 /6.20 IEC 62052-11/7.3.2	-	6 kV	A	Comply
	3 Phase AC		-	6 kV	A	Comply
	1 Phase AC		-	6 kV	A	Comply



Handwritten mark

Handwritten signature

Заличено по чл.2 от ЗЗЛД



my 11



Table of Contents

1. GENERAL	7
1.1. Purpose:.....	7
1.2. Referenced documents:.....	7
1.3. Description of the EUT system:.....	8
1.3.1. General Description:.....	8
1.3.2. EUT Configuration:.....	9
1.3.3. EUT Cards/Modules List:.....	10
1.3.4. Cables Identification:.....	10
1.3.5. Clock Frequencies Table:.....	10
1.3.6. Method of Performance verification:.....	11
1.3.7. EUT Pass/Fail criteria for immunity tests:.....	11
2. TEST FACILITY & UNCERTAINTY OF MEASUREMENT	12
2.1. Accreditation/ Registration reference:.....	12
2.2. Test Facility description.....	12
2.3. Uncertainty of Measurement:.....	13
3. ELECTRIC FIELD EMISSION MEASUREMENTS	14
4. CONDUCTED EMISSION MEASUREMENTS	20
5. IMMUNITY TO ELECTROSTATIC DISCHARGE	29
6. IMMUNITY TO RADIATED ELECTROMAGNETIC FIELD	33
7. IMMUNITY TO ELECTRICAL FAST TRANSIENTS (EFT)	37
8. IMMUNITY TO VOLTAGE SURGE	45
9. IMMUNITY TO CONDUCTED RF STRESS	51
10. VARIATION DUE TO MAGNETIC FIELD OF EXTERNAL ORIGIN	57
11. IMMUNITY TO OSCILLATORY WAVES MEASUREMENTS	60
12. VARIATIONS DUE TO AMBIENT TEMPERATURE	66
13. AC VOLTAGE INSULATION TEST	68
14. IMPULSE VOLTAGE TESTS	70
15. APPENDIX	72

Handwritten mark

Заличено по чл.2 от ЗЗЛД

Handwritten signature

my 11

1. General

1.1. Purpose:

The purpose of this report is to show compliance to Electromagnetic Emission and Immunity requirements outlined in the referenced specifications. *This report serves as the basis for the "Declaration of Conformity"*.

1.2. Referenced documents:

IEC 62052-11:2003	Electricity metering equipment (AC) – General requirements, tests and test conditions – Part 11: Metering equipment
IEC 60688:2002	Electrical measuring transducers for converting a.c. electrical quantities to analogue or digital signals
IEC 62053-22:2003	Electricity metering equipment (a.c.) – Particular requirements – Part 22: Static meters for active energy (classes 0,2 S and 0,5 S)
IEC 62053-23:2003	Electricity metering equipment (a.c.) - Particular requirements -- Part 23: Static meters for reactive energy (classes 2 and 3) IEC 62053-23:2003
CISPR 22: 2006 AS/NZS CISPR 22:2006	Information Technology Equipment – Radio disturbance characteristics - Limits and Methods of Measurement.
IEC 61000-4-2:2001-04	Electrostatic Discharge (ESD) Immunity test
IEC 61000-4-3:2008	Electro magnetic compatibility (EMC), Section 3: Radiated, radio frequency, electromagnetic field immunity IEC test
IEC 61000-4-4:2007	Electro magnetic compatibility (EMC), Section 4: Electrical fast transient/burst immunity test
IEC 61000-4-5:2005	Electromagnetic compatibility (EMC), Section 5: Surge immunity test
IEC 61000-4-6:2008	Electromagnetic compatibility (EMC), Section 6: Immunity to conducted disturbances, induced by radio- frequency fields
IEC 61000-4-8:2001	Power Frequency Magnetic Field Immunity

[Handwritten mark]

Заличено по чл.2 от ЗЗЛД

[Handwritten signature]

[Handwritten signature]




Handwritten mark

1.3. Description of the EUT system:

General description of the EUT, configuration used for Emission and Immunity testing, and the method of performance verification were defined by the manufacturer. The acceptance performance criterion was declared by the manufacturer.

1.3.1. General Description:

The EM133 is a compact, Din Rail Smart Meter, three-phase AC Powermeter specially designed to meet the requirements of users ranging from electrical panel builders to substation operators. The Din Rail Smart Meter, EM133 designed for acquiring real time analog inputs through 3 phase 3 wire CT/PTs circuits/ 3 phase 4 wire CT/PTs circuits. The EM133 – SATEC Smart DIN Rail Meter is built of standard LCD display (16 characters x 2), all necessary Hardware to handle all Power Measurements that includes I/O and communication ports: 2 x Digital Inputs, 1 x Relay Output, RS-485 and IR (optional) communication ports.



Handwritten mark

Handwritten mark


Заличено по чл.2 от ЗЗЛД

Handwritten signature and stamp

myk

1.3.2. EUT Configuration:

EUT Configuration for Emissions & Immunity Testing:



Заличено по чл.2 от ЗЗЛД

БЛГПО С УГНИ ПЛАВИМ



Handwritten mark

1.3.3. EUT Cards/Modules List:

No	Hardware Component	Manufacturer's Catalog Number	Serial Number	Hardware Revision	Quantity
1	Analog Board	AP1065/1071/1075	PC0284	A3	1
2	Logic Board	AP1067	PC0285	A1	1
3	Display	AP1069	PC0286	A1	1

1.3.4. Cables Identification:

Port/Line Name @ EUT	Type	Indoor/outdoor	Impedance [Ohm]	Typical Length [m]	Tested Length [m]	# of ports/ boards available	# of ports/ boards connected	From	To
Voltage circuits	3 x Phases unshielded	Indoor	>1M	1	1	1	1	Common 3 phase Energy source	Voltage input
Current circuits	3 pairs unshielded	Indoor	<0.10	1	1	1	-	-	Current input
Auxiliary Voltage Input	Single Phase unshielded	Indoor	>160	1	1	1	1	Phase Energy source	Voltage Inlet
RS485	Unshielded	Indoor	>100	-	6	1	Terminal	-	PC
Dig Input	Unshielded	Indoor	>350	-	1.5	2	Terminal	-	-
Dig Output	Unshielded	Indoor	<0.10	-	1.5	1	Terminal	-	-

Handwritten mark

1.3.5. Clock Frequencies Table:

Frequency [MHz]	Location
0.032	Logic
8	Logic

Handwritten signature

Заличено по чл.2 от ЗЗЛД

Handwritten signature
Handwritten signature
Handwritten signature
ООЛ

1.3.6. Method of Performance verification:

During all Immunity Tests EUT was under constant observation for normal performance. Voltage from the energy source was applied to voltage circuits V1-V3, VN; 3 pairs current circuits were connected according standards requirements; all peripheral connection – Communication port, dig. Inputs/Outputs were connected and controlled by external PC. EUT provided the measurement of the energy supplied by the common energy source. Display readings, Errors and alarms were verified.

1.3.7. EUT Pass/Fail criteria for immunity tests:

General performance criteria:

Performance Criterion A:

The EUT shall continue to operate as intended. No degradation of performance or loss of functionality is allowed below a performance level specified by the manufacturer. Normal Performance for criteria A is specified as:

- *The EUT shall continue to operate as intended. No degradation of performance or loss of functionality is allowed below a performance level specified by the manufacturer.*
- *For the standard PASS criterion details and verification tests results see Appendix A.*

Performance Criterion B:

The EUT shall continue to operate as intended after the test. No degradation of performance or loss of functionality is allowed below a performance level specified by the manufacturer. During the exposure to electromagnetic phenomenon, degradation of performance is, however allowed. No change of actual operation state or stored data is allowed. Minimum performance level for criteria B is specified as:

- *The EUT shall continue to operate as intended after the test. No degradation of performance or loss of functionality is allowed below a performance level specified by the manufacturer. During the exposure to electromagnetic phenomenon, degradation of performance is, however allowed.*
- *No change of actual operation state or stored data is allowed.*
- *For the standard PASS criterion details and verification tests results see Appendix A.*

Performance Criterion C:

Temporary loss of functionality is allowed provided the function is self-recoverable or can be restored by the operation of the controls.

Performance Criterion R:

The equipment shall withstand the test without damage or other disturbance (such as corruption of software or disoperation of fault protection facilities) and shall operate properly within specified limits after the transient electromagnetic stress has ceased. *It is not necessary to operate properly while the test condition is present.* The exposure may cause the operation of fuses or other specified devices, which have to be replaced or reset before normal operation is restored.

Заличено по чл.2 от ЗЗЛД

my

2. Test Facility & Uncertainty of Measurement

2.1. Accreditation/ Registration reference:

- A2LA Certificate Number: 1633.01

2.2. Test Facility description

The tests were performed at the EMC Laboratory, QualiTech Division, ECI Telecom

Address: 30, Hasivim Street, Petah Tikva, Israel.
Tel: 972-3-926-8443

3m Anechoic Chamber:

The 3m-screened chamber is used in two configurations: the semi-anechoic configuration for Radiated Emission measurements and the full-anechoic configuration for Radiated Immunity tests.

Semi Anechoic Configuration:


Measurement distance	3m
Chamber dimensions	9.5m x 6.5m x 5.2m
Antenna height	1 - 4m
Shielding Effectiveness	Magnetic field ≥ 80 dB at 15 kHz ≥ 90 dB at 100 kHz Electric field > 120 dB from 1MHz to 1GHz > 110 dB from 1GHz to 10GHz
Absorbing material	Ferrite tiles on the walls and ceiling Frankonia hybrid absorbing material in selected positions on the walls
Normalized Site Attenuation measured at 5 positions	± 3.49 dB, 30MHz to 1GHz
Transmission Loss measured at 5 positions, at 1.5m height	± 3 dB, 1GHz to 18GHz

Handwritten mark

Full-Anechoic Configuration:

Measurement distance	3m
Chamber dimensions	7m x 4m x 3m
Antenna height	1.55m at Horizontal & Vertical polarizations
Shielding Effectiveness	Magnetic field ≥ 80 dB at 15 kHz ≥ 90 dB at 100 kHz Electric field > 120 dB from 1MHz to 1GHz > 110 dB from 1GHz to 10GHz
Absorbing material	Ferrite tiles on the walls and ceiling Frankonia hybrid absorbing material in selected positions on the walls and floor
Field Uniformity to EN61000-4-3	± 3 dB 80MHz to 18GHz

Заличено по чл.2 от ЗЗЛД



Handwritten signature

2.3. Uncertainty of Measurement:


Test Name	Test Method & Range	Uncertainty	
		Combined std. Uc(y)	Expanded U
Radiated Emission	30MHz+230MHz, Horiz. polar.	[dB] 1.8	[dB] 3.6
	30MHz+230MHz, Ver. polar.	1.967	3.934
	230MHz+1000MHz, Horiz. polar.	1.487	2.973
	230MHz+1000MHz, Vert. polar.	1.499	2.998
Conducted Emission	9 kHz+150 kHz	[dB] 1.378	[dB] 2.756
	150 kHz+30MHz	1.095	2.190

Note: Note: QualiTech, ECI Telecom expanded measurement instrumentation uncertainty U_{lab} is 3.934dB for radiated emissions and U_{lab} is 2.756dB for conducted emissions which are both less than the U_{cispr} values of 5.2dB for radiated emissions and the U_{cispr} values of 4.0dB for conducted emissions. Therefore, we have less uncertainty than the industry norm and compliance is deemed to occur as no measured disturbance exceeds the disturbance limit.

Note: The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor of k=2, providing a level of confidence of approximately 95%.

Handwritten mark

Заличено по чл.2 от ЗЗЛД



Wg

3. Electric Field Emission Measurements

Date of Test: 26.06.2011
Relative Humidity: 54%
Ambient Temperature: 21°C
Atmospheric Pressure: 1011.4 hPa

Test Method: CISPR22 limits according to IEC 62052-11 section 7.5.8

Limits:

30MHz to 1GHz frequency range

Frequency [MHz]	QP Limit [dB μ V /m] [Class A]	QP Limit [dB μ V /m] [Class B]
30÷230	50	40
230÷1000	57	47

Test Procedure:

Measurements were performed at a 3-meter measurement distance in the semi-anechoic chamber in order to evaluate the radiated electromagnetic interference characteristics of the EUT. The EUT was placed on a non-metallic table, 0.8m above the turntable, was configured, arranged and operated in a manner consistent with typical application and load conditions. The test program of exercising the equipment ensured that various parts of the EUT were exercised to permit detection of all EUT disturbances. An appropriate antenna depending upon the frequency range was used. While the turntable was being rotated, the height of the antenna was varied from 1 to 4m for the frequency range of 30MHz to 1GHz. The highest radiated emission was detected by manipulating the system cables to the worst-case position. This process was repeated for both antenna polarizations. The amplitudes of worst-case emission were measured with the QP detector using resolution-bandwidth per CISPR16-1.

List of Test Equipment:

Semi Anechoic Chamber, 9.5m[L] x 6.5m[W] x 5.2m[H]
HP8546A, CISPR16 EMI Receiver
HP8593EM EMC Analyzer
Schwarzbeck VHBB9124, Biconical Antenna
Schwarzbeck VUSLP9111, LogPeriodic Antenna

Test Details:

Interference	Frequency Range	Measurement Means	Test Setup No.	Photograph No.	Plot Nos.
Electric Field	30MHz÷1GHz	Biconical, Log-periodic &	Fig.3	Photo.3	3.1-3.4

Заличено по чл.2 от ЗЗЛД



WPH

Test Results:

Table 3: Frequency range 30MHz÷1GHz

Frequency [MHz]	Ant. Type	Ant. Pol.	Ant. Pos. [cm]	Turn-table Azimuth [°]	Radiated Emission dB(μV/m)	Limit at 3m dB(μV/m)	Margin [dB]	Pass/Fail
32.398050	Biconical	V	231	87	21.2	40	-18.8	Pass
63.928775	Biconical	V	348	269	22.1	40	-17.9	Pass
239.990825	Log-periodic	H	107	240	30.2	47	-16.8	Pass
272.355425	Log-periodic	H	106	34	27.2	47	-19.8	Pass
360.018950	Log-periodic	V	100	264	27.0	47	-20	Pass
942.327475	Log-periodic	V	100	241	29.1	47	-17.9	Pass

Note: Radiated Emission [dBμV/m] = measured [dBμV] + Correction-factor [dB(1/m)]
Correction Factor = Antenna factor + Cable Loss

Summary:

Frequency Range	Test method reference	Class Limits applied	Test Results	Remarks
30MHz÷1GHz	EN55022, Sec. 8 & 10	B	Tab. 3	Pass


Заличено по чл.2 от ЗЗЛД

[Handwritten signature]

**Horizontal Polarization
30MHz-230MHz
Plot 3.1**

④

ACTV DET: PEAK
MERS DET: PEAK OP AVG
Mkr 65.7 MHz
24.01 dB μ V/m




[Handwritten mark]

**Horizontal Polarization
230MHz-1GHz
Plot 3.2**

④

ACTV DET: PEAK
MERS DET: PEAK OP AVG
Mkr 947.6 MHz
36.91 dB μ V/m



[Handwritten signature]

Заличено по чл.2 от ЗЗЛД




my 2/1

**Vertical Polarization
30MHz-230MHz
Plot 3.3**



ACTV DET: PEAK
MEAS DET: PEAK OP AVG
MKR 65.7 MHz
29.23 dB μ V/m




Handwritten mark on the right side of the plot.

**Vertical Polarization
230MHz-1GHz
Plot 3.4**




ACTV DET: PEAK
MEAS DET: PEAK OP AVG
MKR 944.7 MHz
36.54 dB μ V/m



Залічено по чл.2 от ЗЗЛД

Handwritten initials

Figure 3: Setup for Radiated Emission Testing - 30MHz +1GHz Frequency Range



Handwritten mark


Handwritten signature

Заличено по чл.2 от ЗЗЛД



Handwritten initials

Photograph 3: Radiated Emission Testing



Handwritten signature

Заличено по чл.2 от ЗЗЛД



MM

4. Conducted Emission Measurements

Date of Test: 26.06.2011

Relative Humidity: 48%

Ambient Temperature: 21°C

Atmospheric Pressure: 1011.4 hPa

Test Method: CISPR 22 limits according to IEC 62052-11 section 7.5.8

Limits:

Power Supply Port: Class A

Frequency [MHz]	Limits [dBμV]	
	QP	Average
0.15÷0.5	79	66
0.5÷30	73	60

Power Supply Port: Class B

Frequency [MHz]	Limits [dBμV]	
	QP	Average
0.15÷0.5	66 to 56	56 to 46
0.5÷5	56	46
5÷30	60	50

Test Procedure:

The measurements were performed on the line under test in a 4m x 3m x 3m screened enclosure by means of an Impedance Stabilization Network (ISN) bonded to the ground plane and connected to the spectrum analyzer. The EUT was placed on a non-metallic table, 0.8m above the ground reference plane and was configured, arranged and operated in a manner consistent with typical application and load conditions. Normal performance of the EUT was verified.

Conducted common mode (asymmetric mode) disturbance at the tested port was investigated in the appropriate frequency range using the resolution-bandwidth per CISPR16-1, Table 7, and QP and Average readings were taken.

Worst-case results were recorded.

List of Test Equipment:

Screened Enclosure 4m x 3m x 3m
HP8546A, CISPR16 EMI Analyzer
Schwarzbeck NNBL 8226-2 V-LISN
HP11947A, Transient Limiter

Заличено по чл.2 от ЗЗЛД

Handwritten signature

Test Details:

Port under Test	Measured at	Test method reference	Test Setup No.	Photograph No.	Plot Nos.
230 VAC	AC line	Sec. 9.2 & 9.5.2	Fig. 4	Photo. 4.1	4.1-4.2
3 Phase AC	3 phase AC	Sec. 9.2 & 9.5.2	Fig. 4	Photo. 4.2	4.3-4.6
RS485	Not applicable				
Input	Not applicable				
Output	Not applicable				

Test Results:

Table 4.1: Power Supply Port:

“Phase” Lead

Frequency [MHz]	Measured Result [dBμV]		Limit [dBμV]		Margin [dB]		Pass/Fail
	QP	AVR	QP	AVR	QP	AVR	
0.517669	63.9	53.9	73.00	60.00	-9.10	-6.10	Pass
0.644816	61.7	49.9	73.00	60.00	-11.30	-10.10	Pass
0.790684	59.7	46.3	73.00	60.00	-13.30	-13.70	Pass
1.7801	57	36.6	73.00	60.00	-16.00	-23.40	Pass
1.5725	55.5	37.1	73.00	60.00	-17.50	-22.90	Pass
3.189	53.2	37	73.00	60.00	-19.80	-23.00	Pass

“Neutral” Lead

Frequency [MHz]	Measured Result [dBμV]		Limit [dBμV]		Margin [dB]		Pass/Fail
	QP	AVR	QP	AVR	QP	AVR	
0.660713	59.1	45.6	73.00	60.00	-13.90	-14.40	Pass
0.533970	58.1	43.7	73.00	60.00	-14.90	-16.30	Pass
1.948245	59.1	37.5	73.00	60.00	-13.90	-22.50	Pass
2.050928	57.2	35.7	73.00	60.00	-15.80	-24.30	Pass
3.03799	52.7	32.2	73.00	60.00	-20.30	-27.80	Pass
3.182	52.8	36.6	73.00	60.00	-20.20	-23.40	Pass

Заличено по чл.2 от ЗЗЛД

Handwritten signature



mgh

Table 4.2: Power Supply port:

“Phase 1” Lead

Frequency [MHz]	Measured Result [dB μ V]		Limit [dB μ V]		Margin [dB]		Pass/Fail
	QP	AVR	QP	AVR	QP	AVR	
1.548	25.6	9.1	56.00	46.00	-30.40	-36.90	Pass
7.3867	21.1	7	60.00	50.00	-38.90	-43.00	Pass
9.30267	25.4	12.1	60.00	50.00	-34.60	-37.90	Pass
11.711851	28.8	15.1	60.00	50.00	-31.20	-34.90	Pass
13.318202	38.2	24.4	60.00	50.00	-21.80	-25.60	Pass
25.275529	43	34.5	60.00	50.00	-17.00	-15.50	Pass

“Phase 2” Lead

Frequency [MHz]	Measured Result [dB μ V]		Limit [dB μ V]		Margin [dB]		Pass/Fail
	QP	AVR	QP	AVR	QP	AVR	
0.509024	33.1	21	56.00	46.00	-22.90	-25.00	Pass
0.530195	32.5	22.7	56.00	46.00	-23.50	-23.30	Pass
1.65844	30.7	14.8	56.00	46.00	-25.30	-31.20	Pass
1.984085	29.9	13.1	56.00	46.00	-26.10	-32.90	Pass
2.87	24.6	7.1	56.00	46.00	-31.40	-38.90	Pass
13.322011	33.3	19	60.00	50.00	-26.70	-31.00	Pass

“Phase 3” Lead

Frequency [MHz]	Measured Result [dB μ V]		Limit [dB μ V]		Margin [dB]		Pass/Fail
	QP	AVR	QP	AVR	QP	AVR	
1.574635	28.3	12.6	56.00	46.00	-27.70	-33.40	Pass
1.907155	26.6	9.7	56.00	46.00	-29.40	-36.30	Pass
2.121175	26.4	9.7	56.00	46.00	-29.60	-36.30	Pass
2.891	21.3	5.6	56.00	46.00	-34.70	-40.40	Pass
13.449476	32.3	18.8	60.00	50.00	-27.70	-31.20	Pass
25.524585	42	32.9	60.00	50.00	-18.00	-17.10	Pass

Заличено по чл.2 от ЗЗЛД

Handwritten signature

“Neutral” Lead

Frequency [MHz]	Measured Result [dBμV]		Limit [dBμV]		Margin [dB]		Pass/Fail
	QP	AVR	QP	AVR	QP	AVR	
0.514089	42.3	30.3	56.00	46.00	-13.70	-15.70	Pass
0.668029	41.8	23.9	56.00	46.00	-14.20	-22.10	Pass
1.868409	43.1	20.1	56.00	46.00	-12.90	-25.90	Pass
2.098569	41.5	21.6	56.00	46.00	-14.50	-24.40	Pass
3.059	38.6	20.8	56.00	46.00	-17.40	-25.20	Pass
25.614615	45.5	36.6	60.00	50.00	-14.50	-13.40	Pass

Summary:

Port under Test	Measurement Means	Class Limits applied	Frequency Range	Test Results	Remarks
230 VAC	LISN	A	150kHz – 30MHz	Tab. 4.1	Pass
3 Phase AC	LISN	B	150kHz – 30MHz	Tab. 4.2	Pass
RS485				Not applicable	
Input				Not applicable	
Output				Not applicable	

Handwritten signature

Handwritten signature

Заличено по чл.2 от ЗЗЛД




Handwritten mark

**Power Supply Ports
150kHz – 30MHz
“Phase” Lead
Plot 4.1**



ACTV DET: PEAK
MERS DET: PEAK OP AVG
NKR 510 kHz
63.79 dBµV




Handwritten mark

**Power Supply Ports
150kHz – 30MHz
“Neutral” Lead
Plot 4.2**



ACTV DET: PEAK
MERS DET: PEAK OP AVG
NKR 1.79 MHz
63.66 dBµV



Handwritten mark




Заличено по чл.2 от ЗЗЛД

Handwritten mark

**Power Supply Ports
150kHz – 30MHz
"Phase 1" Lead
Plot 4.1**



ACTV DET: PEAK
MERS DET: PEAK OP AVG
MKR 25.55 MHz
48.54 dBµV




Handwritten mark

**Power Supply Ports
150kHz – 30MHz
"Phase 2" Lead
Plot 4.2**



ACTV DET: PEAK
MERS DET: PEAK OP AVG
MKR 12.99 MHz
37.20 dBµV



Handwritten mark


Залічено по чл.2 от ЗЗЛД

Handwritten mark

**Power Supply Ports
150kHz – 30MHz
"Phase 3" Lead
Plot 4.3**



ACTV DET: PEAK
MERS DET: PEAK QP AVG
MKR 25.26 MHz
45.91 dBµV




Handwritten mark

**Power Supply Ports
150kHz – 30MHz
"Neutral" Lead
Plot 4.4**



ACTV DET: PEAK
MERS DET: PEAK QP AVG
MKR 25.85 MHz
47.86 dBµV




Handwritten mark

Заличено по чл.2 от ЗЗЛД

Handwritten mark

Figure 4: Setup for Conducted Emission Testing on AC Power Supply Port




Handwritten mark

Заличено по чл.2 от ЗЗЛД




Handwritten mark

Photograph 4.1: Conducted Emission Testing on AC Power Supply Port



Handwritten mark

Photograph 4.2: Conducted Emission Testing on 3 Phase AC



Handwritten signature

Заличено по чл.2 от ЗЗЛД



myh

5. Immunity to Electrostatic Discharge

Date of Test: 26.06.2011
Relative Humidity: 50%
Ambient Temperature: 23°C
Atmospheric Pressure: 1011.4 hPa

Test Method: IEC 61000-4-2 according to IEC 62052-11 section 7.5.2

Test Voltage:

Type of Application	Test Voltage	# of Discharges each polarity	Performance Criteria
Contact Discharge	±8 kV	10	B
Air Discharge	±15 kV	10	B

2

Test Procedure:

Electrostatic Discharge tests were performed on a ground reference plane 3m x 3m wide. The EUT was placed on a wooden table 0.8m high, standing on the ground reference plane. A horizontal coupling plane (HCP), 1.6m x 0.8m, was placed on the table underneath the EUT, and the EUT was isolated from the coupling plane by an insulating support 0.5mm thick. The HCP was connected to the ground reference plane by a bleed resistor lead. The EUT was placed on the HCP with its front face 10cm from the edge of the plane, and configured, arranged and operated in a manner consistent with typical application and load conditions. The cables were taken away from the test area separated from the HCP by 5cm and draped off the HCP as necessary. Normal performance of the EUT was verified.

Direct and air application:

For pre-selected points, 10 single Contact discharges in both positive and negative polarities, were applied with at least 1sec time interval between successive discharges. Discharges were applied to surfaces and metal points which are accessible during normal usage. Inside the EUT, only the points and surfaces, which have to be accessed during maintenance, were included. The same procedure was repeated for air discharges on non- metallic parts or insulating surfaces.

Indirect application:

Ten single discharges, in both positive and negative polarities, were applied to the HCP on each side of the EUT. The same procedure was repeated with the vertical coupling plane VCP (connected to the ground reference plane by a bleed resistor lead) on each side of the EUT such that the face of the EUT was completely illuminated. For air discharges, voltage levels were increased gradually from 2kV until the maximum severity level was reached, for each polarity. During the test, the EUT operation was monitored to verify the required Performance Criteria.

List of Test Equipment:

Noiseken, ESS-2000 Discharge Simulator

Заличено по чл.2 от ЗЗЛД

M

Test Details:


Test Setup No.	Photograph No.
Fig. 5.1	Fig. 5.2

Test Results:

Type of discharge	Points of Discharge	Discharge Voltage	Number of Discharges at each polarity	Performance Criteria applied	BER/ # of errors	Remarks
Contact Discharge	EUT	±8 kV	10	B	None	Pass
	HCP	±8 kV	10	B	None	Pass
	VCP	±8 kV	10	B	None	Pass
Air Discharge	EUT	±15 kV	10	B	None	Pass

*Verified after the test.


Figure 5.1: Setup for Electrostatic Discharge Test



2

Заличено по чл.2 от ЗЗЛД

ВЛГ ПО С ОГ ВРИПКОМ



M

mgm


Figure 5.2: Electrostatic Discharge Map

Contact Electrostatic Discharge applied at **X** spots

Air Electrostatic Discharge applied at **O** spots



[Handwritten mark]





[Handwritten signature]

Заличено по чл.2 от ЗЗЛД

Handwritten mark

Electrostatic Discharge Map



Заличено по чл.2 от ЗЗЛД

Handwritten mark

6. Immunity to Radiated Electromagnetic Field

Date of Test: 26.06.2011
Relative Humidity: 50%
Ambient Temperature: 23°C
Atmospheric Pressure: 1011.4 hPa

Test Method: IEC 61000-4-3 according to IEC 62052-11 section 7.5.3

Test Levels:

Frequency range	Mode Of Operation	Test Level	Performance Criteria
80 MHz – 1GHz 80% AM, 1 kHz sine	Test with current	10 V/m	A
1GHz -2GHz 80% AM, 1 kHz sine		10 V/m	A
80 MHz – 1GHz 80% AM, 1 kHz sine	Test without current	30 V/m	A
1GHz -2GHz 80% AM, 1 kHz sine		30 V/m	A

Test Procedure:

The EUT was placed in a full-anechoic chamber on a non-conductive table 0.8m above the absorbing ground plane, and was configured, arranged and operated in a manner consistent with typical application and load conditions. Normal performance of the EUT was verified.

The EUT was positioned parallel to the pre-calibrated “uniform area” at a distance of 3m from the transmitting antenna.

The frequency range was swept in steps of 1% with 1kHz sine-wave 80% Amplitude modulated or 200Hz square wave 50% pulse modulated, according to the frequency range, with a dwell time of 1 sec. A list of clock and sensitive frequencies were analyzed separately if made available.

Special exercising S/W was used in order to precisely generate the required electromagnetic field based on the calibrated field uniformity data.

All tests were performed four times, with the antenna facing each of the four sides of the EUT. Each test was performed for both, horizontal and vertical antenna polarization

During the tests, the EUT and external equipment were monitored to verify normal functional performance.

List of Test Equipment:

- IFI 2025 RF Signal Generator
- Boonton 4230 Power Meter
- Boonton 51015 Power Sensor
- Anechoic Chamber 7m x 4m x 3m
- AR100W100, 30MHz-1GHz Wideband Linear RF Amplifier
- Werlaton C3910, 30MHz-1GHz Directional Coupler
- EMCO 3142, BiLog Antenna
- Ophir GRF5061, 0.8 GHz-4.2 GHz RF Amplifier
- AR DC7144, 0.8 GHz

Заличено по чл.2 от ЗЗЛД

Handwritten signature

ВЛГНО С СТУДИЯ...



Handwritten initials

Test Details:

Frequency range	Radiating Antenna	Test Setup No.	Photograph No.
80 MHz – 1GHz 80% AM, 1 kHz sine	Bilog	Fig 6	Photo.6
1GHz -2GHz 80% AM, 1 kHz sine			
80 MHz – 1GHz 80% AM, 1 kHz sine			
1GHz -2GHz 80% AM, 1 kHz sine			

Test Results:

Frequency range	Test Level	Mode Of Operation	BER/ # of errors	Performance Criteria applied	Remarks
80 MHz – 1GHz 80% AM, 1 kHz sine	10 V/m	Test with current	None	A	Pass
1GHz -2GHz 80% AM, 1 kHz sine	10 V/m		None	A	Pass
80 MHz – 1GHz 80% AM, 1 kHz sine	30 V/m	Test without current	None	A	Pass
1GHz -2GHz 80% AM, 1 kHz sine	30 V/m		None	A	Pass

Handwritten mark

Заличено по чл.2 от ЗЗЛД


Handwritten signature

Handwritten signature



M

Figure 6: Setup for Radiated Immunity Test




[Handwritten mark]

Заличено по чл.2 от ЗЗЛД



mm

Photograph 6: Radiated Immunity Test



[Signature]

Заличено по чл.2 от ЗЗЛД

[Signature]

[Signature]
*
ООП

Handwritten mark

7. Immunity to Electrical Fast Transients (EFT)

Date of Test: 26.06.2011
Relative Humidity: 49%
Ambient Temperature: 25°C
Atmospheric Pressure: 1011.4 hPa

Test Method: IEC 61000-4-4 according to IEC 62052-11 section 7.5.4

Test Levels:

Power Supply Port:

Power Supply leads	Peak Voltage [kV]	Test Duration	Performance Criteria
230 VAC, 3 Phase AC	± 4	60sec	B

Handwritten mark

Telecommunication ports and Signal Lines:

Signal Line	Peak Voltage [kV]	Test Duration	Performance Criteria
RS485, Input, Output	± 2	60sec	B

Test Procedure:

Electrical Fast Transient/Burst Tests were performed on a ground reference plane 3m x 3m wide. The EUT was placed on a table 0.8m above the ground reference plane, and was configured, arranged and operated in a manner consistent with typical application and load conditions. Normal functional performance of the EUT was verified.

Fast transients/Burst voltage at a repetition rate of 5 kHz was applied between the reference plane and the signal lines by means of a Capacitive Coupling Clamp, and between the ground reference plane and each of the power supply terminals, AC or DC, and protective earth (PE) terminal by means of a Coupling/Decoupling Network (CDN). Every coupling mode was applied for 1minute in each polarity. The Fast transients/Burst generator and CDN were bonded to the reference plane. The distance between the EUT and the coupling network or clamp was 1m or less. Clear distance of 0.5m was kept from the EUT to all other conducting structures. All cables, including the one being tested, were separated by 10cm from the ground reference plane. During the tests, the EUT and external equipment were monitored to verify the required performance criteria.

List of Test Equipment:

Haefely Test System, including PEFT 4010 EFT/Burst Generator
PSPN1610 coupling network
IP4A Capacitive Coupling Clamp
WinPATS Control S/W

Заличено по чл.2 от ЗЗЛД

Handwritten signature



Test Details:

Supply/Signal line/Port under Test	Test applied at	Coupling Means	Test Setup No.	Photograph No.
230 VAC	AC line	CDN	Fig.7.1	Photo.7.1
3 Phase AC	3 Phase AC	CDN	Fig.7.2	Photo.7.2
RS485	RS485	Capacitive Coupling Clamp	Fig.7.3	Photo.7.3
Input	Input	Capacitive Coupling Clamp	Fig.7.3	Photo.7.4
Output	Output	Capacitive Coupling Clamp	Fig.7.3	Photo.7.5

Test Results:


Supply/Signal line/Port under Test	Peak Voltage [kV]	Test Duration [Minutes]	BER/ # of errors	Performance Criteria Applied	Pass/ fail
230 VAC	± 4	7	None	A	Pass
3 Phase AC	± 4	20	None	A	Pass
RS485	± 2	7	None	A	Pass
Input	± 2	7	None	A	Pass
Output	± 2	7	None	A	Pass

Note: During the EFT test the EUT screen was blinking

Заличено по чл.2 от ЗЗЛД

Handwritten signature

Figure 7.1: Setup for EFT Test on AC Power Supply Port



Handwritten scribble


Заличено по чл.2 от ЗЗЛД

Handwritten signature

Handwritten signature and stamp

Handwritten signature

Figure 7.2: Setup for EFT Test on AC Power Supply Port



Handwritten mark


Заличено по чл.2 от ЗЗЛД

Handwritten signature

Handwritten signature and circular stamp

Handwritten mark

Figure 7.3: Setup for EFT Test on RS485, Input, Output



Handwritten mark

Заличено по чл.2 от ЗЗЛД

Handwritten signature

Handwritten signature




Handwritten signature

Photograph: 7.1: EFT test on AC Power Supply Port



Handwritten mark

Photograph: 7.2: EFT test on 3 phase AC



Handwritten signature

Заличено по чл.2 от ЗЗЛД

Handwritten signature

Photograph 7.3: EFT test on RS 485



Handwritten mark

Photograph 7.4: EFT test on Input



Handwritten signature

Заличено по чл.2 от ЗЗЛД

Handwritten signature

Photograph 7.5: EFT test on Output



Handwritten signature

Заличено по чл.2 от ЗЗЛД

Handwritten signature

Handwritten signature and a circular stamp with the letters "ООЛ" inside.

Handwritten initials

8. Immunity to Voltage Surge

Date of Test: 22.06.2011
Relative Humidity: 48%
Ambient Temperature: 21°C
Atmospheric Pressure: 1011.4 hPa

Test Method: IEC 61000-4-5 according to IEC 60251-11 section 7.5.6

Test Levels:

Power Supply Port:

Port under Test	Pulse Shape Combination Wave	Peak Voltage	# of pulses	Performance Criteria
230 VAC & 3 phase AC	Line to Line	±4kV	5, each polarity	B

Handwritten mark

Telecommunication ports and Signal Lines:

Port under Test	Pulse Shape Combination Wave	Indoors/ Outdoor signal	Peak Voltage	# of pulses	Performance Criteria
Output	Line to Line	Indoor	±4kV	5, each polarity	B

Test Procedure:

Surge Tests were performed on a ground reference plane 3m x 3m wide. The EUT was placed on a table 0.8m above the ground reference plane, and was configured, arranged and operated in a manner consistent with typical application and load conditions. Normal performance of the EUT was verified. Surge voltage was applied to the EUT power supply by means of a coupling/decoupling network, and directly to the tested ports or coaxial and shielded cables via gas arrestors. The cable between the EUT and coupling network was 2m or less in length. The surge voltages were applied synchronized to the zero crossing and the positive and negative peaks of the AC voltage wave. The surges were applied line-to-line and line-to-earth. The test was repeated at a voltage level just below the threshold of the surge protector.

During the tests, the EUT and external equipment were monitored to verify the required functional performance criteria on all ports other than the tested port.

List of Test Equipment:

Haefely Test System, comprising of PSURGE 6.1 Mainframe
WinPATS Control S/W and WinPATS Control S/W
IP6.2 2 & 4 -wire Coupling Network
PSPN 1610 Single Port Network
PHV30.2 1.2x50/8x20µs Combination Wave Plug-In unit
EMtest ,VCS500N Surge Generator 3 PH.
EMtest,CNI503, 3 PH Network



Заличено по чл.2 от ЗЗЛД

Handwritten signature


Test Details:

Port under Test	Test applied at	Test method reference	Generator Waveform	Indoor/Outdoor	Test Setup No.	Photograph No.
230 VAC	AC line	Sec. 6.3.2.2	Combination Wave	Indoor	Fig. 8.1	Photo.8.2
3 Phase AC	3 Phase AC	Sec. 6.3.1.1	Combination Wave	Indoor	Fig. 8.1	Photo.8.2
RS485	Not applicable (reference voltage less than 40V)					
Input	Not applicable (reference voltage less than 40V)					
Output	Output	Sec. 6.3.2.2	Combination Wave	Indoor	Fig. 8.2	Photo.8.2

Test Results:

Port under Test	Terminal Connections	Test Level	Repetitions, each polarity	BER/# of errors	Performance Criteria applied	Remarks
230 VAC	Line to Line	±4kV	5, each polarity	None	A	Pass
3 Phase AC	Line to Line	±4kV	5, each polarity	None	A	Pass
RS485	Not applicable (reference voltage less than 40V)					
Input	Not applicable (reference voltage less than 40V)					
Output	Line to Line	±4kV	5, each polarity	None	A	Pass


Заличено по чл.2 от ЗЗЛД




47/87

Figure 8.1: Setup for surge on AC Power Supply Port

Line to Earth




Line to Line




Handwritten signature

ВЯРНО С ОРИГИНАЛА



Handwritten signature

Figure 8.2: Setup for Output



Handwritten scribble


Заличено по чл.2 от ЗЗЛД

Handwritten signature




Handwritten signature

Photograph 8.1: Surge on AC Power Supply Port



Photograph 8.2: Surge on 3 phase AC




Залічено по чл.2 от ЗЗЛД

Handwritten signature

Handwritten signature

MH

Photograph 8.3: Surge on Output



[Handwritten mark]

Заличено по чл.2 от ЗЗЛД



[Handwritten signature]

Handwritten mark

9. Immunity to Conducted RF Stress

Date of Test: 27.06.2011
Relative Humidity: 48%
Ambient Temperature: 21°C
Atmospheric Pressure: 1011.4 hPa

Test Method: IEC 61000-4-6 according to IEC 62052-11 Section 7.5.5

Test Levels:

Power Supply port:

Frequency Range	Interference Value	Performance Criteria
150kHz÷80MHz	10Vrms	A

Telecommunication ports and Signal Lines:

Frequency Range	Interference Value	Performance Criteria
150kHz÷80MHz	10Vrms	A

Test Procedure:

Conducted Immunity tests were performed on a ground reference plane 3m x 3m wide. The EUT was placed on an insulation support of 0.1m above the ground reference plane, and was configured, arranged and operated in a manner consistent with typical application and load conditions. Normal performance of the EUT was verified. All cables other than those under test, were provided with terminated (50Ω) decoupling networks (CDN). Normal performance of the EUT was verified. Different coupling networks were used for the various cables under test. They were pre-calibrated using the same testing system, and the calibration data was used to re-set the instruments to exactly the same settings and recreate the desired RF stress (disturbing signal) during the test. The frequency range was swept in steps of 1% with 1KHz sine-wave 80% Amplitude modulated, with a dwell time of 1 sec. Special exercising S/W was used in order to precisely generate the required disturbing signal, based on the calibrated data.

During the tests, the EUT and external equipment were monitored to verify normal performance.

List of Test Equipment:

- AR100A250, 10KHz-250MHz Power Amplifier
- Werlaton C5085 10KHz-250MHz Directional Coupler
- Marconi 2024 RF Signal Generator
- Boonton 4235 Power Meter
- Boonton 51015 Power Sensor
- Fischer M3 CDN
- Fischer M5 CDN
- Fischer T2 CDN

Заличено по чл.2 от ЗЗЛД



Handwritten signature

Handwritten signature

mm

Test Details:

Port under Test	Test applied at	Test method reference	Coupling Means	Test Setup No	Photograph No
230 VAC	230 VAC	Sec. 6.2.1.1	M3 CDN	Fig.9.1	Photo.9.1
3 Phase AC	3 Phase AC	Sec. 6.2.3	M5 CDN	Fig.9.2	Photo.9.1
RS485	RS485	Sec. 6.2.1.2	T2 CDN	Fig.9.3	Photo.9.2
Input	Input	Sec. 6.2.1.2	T2 CDN	Fig.9.3	Photo.9.2
Output	Output	Sec. 6.2.1.2	T2 CDN	Fig.9.3	Photo.9.2

Test Results:

Port under Test	Frequency Range	Test Level	BER/# of errors	Performance Criteria	Remarks
230 VAC	150kHz+80MHz	10Vrms	None	A	Pass
3 Phase AC	150kHz+80MHz	10Vrms	None	A	Pass
RS485	150kHz+80MHz	10Vrms	None	A	Pass
Input	150kHz+80MHz	10Vrms	None	A	Pass
Output	150kHz+80MHz	10Vrms	None	A	Pass

mm

Заличено по чл.2 от ЗЗЛД


mm

mm



my

Fig 9.1: Setup for Conducted RF Stress on AC Power Supply Port



[Handwritten mark]

Заличено по чл.2 от ЗЗД


ВЪРНО С ОРНИКАЦИЯ



[Handwritten signature]

Handwritten mark

Fig 9.2: Setup for Conducted RF Stress on RS485, Input, Output




Handwritten mark

Заличено по чл.2 от ЗЗЛД


Handwritten signature

Handwritten signature



Handwritten mark

Photograph 9.1: Conducted RF Stress on AC Power Supply Port



Handwritten mark

Заличено по чл.2 от ЗЗЛД

ВЪПРОС С ОРГАНИЗАЦИЯ


СЕМО

09

Handwritten signature

MM

Photograph 9.2: Conducted RF Stress on RS485, Input, Output



Handwritten scribble

Заличено по чл.2 от ЗЗЛД



Handwritten signature

Handwritten initials

10. Variation due to magnetic field of external origin

Date of Test: 28.06.11
Relative Humidity: 53%
Ambient Temperature: 22°C
Atmospheric Pressure: 1011.4 hPa

Test Method: IEC 60688 Section 6.11

Limits:

H-Field [A/m]	Power frequency	Performance Criteria
400	50Hz	A

Test Procedure:

Magnetic Field test was performed on a ground reference plane 3m x 3m wide. The EUT was placed on a table 0.8m above the ground reference plane, and was configured, arranged and operated in a manner consistent with typical application and load conditions. Normal functional performance of the EUT was verified.

The induction coil was placed horizontally surrounding the EUT. The Induction coil was connected to the Test Generator. Test Generator was activated to generate Magnetic field with strength value shown in the table above. The induction coil was then rotated by 90° and test repeated in order to expose the EUT with different orientations. The dwell time was at least 2 minutes.

During the tests, the EUT and external equipment were monitored to verify the required performance criteria.

List of Test Equipment:

Pacific Power TMX-140, AC Power Source
Current Transformer 1000Amp
Immunity Loop
ELF Field Monitor Holady, HI-3624A


Test Details:

Magnetic Field Strength [A/m]	Test method reference	Coupling Means	Test Setup	Photograph No
400	IEC 60688 Section 6.11	Loop	Fig.10	Photo.10

Test Results:


Magnetic Field Strength [A/m]	Power frequency	BER/# of errors	Performance Criteria	Remarks
400	50Hz	None	A	Pass

Заличено по чл.2 от ЗЗЛД



W/N

Figure 10: Immunity to Power frequency Magnetic Field Measurements




W

Заличено по чл.2 от ЗЗЛД

my


Photograph 10: Immunity to Power Frequency Magnetic Field Measurements



2

Заличено по чл.2 от ЗЗЛД

h



7/11

11. Immunity to Oscillatory Waves Measurements

Date of Test: 22.06.2011
Relative Humidity: 48%
Ambient Temperature: 21°C
Atmospheric Pressure: 1011.4 hPa

Test Method: IEC 61000-4-12 According to IEC 62052-11, Section 7.5.7

Test Levels:

Damped Oscillatory Wave	Generator waveform	Terminal connection	Level [kV]	Frequency [MHz]	Test Duration [Sec.]	Performance Criteria
230 VAC	Damp Oscillatory Wave	Line to Line	±1kV	100 KHz/1 MHz	2 sec on 2 sec off 15 cycles Total of 60 sec.	B
		Line to Earth	±2.5kV	100 KHz/1 MHz		B
3 phase		Line to Line	±1kV	100 KHz/1 MHz	2 sec on 2 sec off 15 cycles Total of 60 sec.	B
		Line to Earth	±2.5kV	100 KHz/1 MHz		B
DO		Line to Line	±1kV	100 KHz/1 MHz	2 sec on 2 sec off 15 cycles Total of 60 sec.	B
		Line to Earth	±2.5kV	100 KHz/1 MHz		B

Test Procedure:

Test shall be performed on a reference ground, 3m x 3m. For floor standing equipment, the EUT shall be placed on the reference plane on a 0.1m thickness insulating support and connected directly to the reference ground. One terminal of the generator shall be connected to the reference plane. For tabletop equipment, the generator shall be floating.

The EUT Damped Oscillatory Wave Generator shall be set as shown in Fig 8.1 8.2 and 8.3. Normal performance as described shall be verified.

The test voltage shall be applied through a coupling/decoupling network. when a CDN is not suitable for the operating signal of the EUT port to be exercised.

Tests shall be allied in common mode and differential mode.

Line to Ground (common mode): The test voltage shall be applied through the coupling network between each circuit (phase and neutral) and ground.

Line to Line (differential mode): The test voltage shall be applied through the coupling network between phase and neutral.

During the test, the EUT operation shall be monitored to verify Performance Criteria.

List of Test Equipment:

EMTest,OCS 500M, Ring and Damped Oscillatory Wave Generator

Залічено по чл.2 от ЗЗЛД

Handwritten mark

Test Details:

Port/Cable Name	Terminal connection	Frequency [MHz]	Coupling Means	Test duration	Test Setup No.	Photograph No.
230 VAC	Line to Line	100 KHz/1 MHz	CDN	2 sec on 2 sec off 15 cycles Total of 60 sec.	Fig.11.1	Photo.11.1
	Line to Earth	100 KHz/1 MHz				
3 phase	Line to Earth	100 KHz/1 MHz	CDN	2 sec on 2 sec off 15 cycles Total of 60 sec.	Fig.11.1	Photo.11.2
	Line to Earth	100 KHz/1 MHz				
DO	Line to Earth	100 KHz/1 MHz	CDN	2 sec on 2 sec off 15 cycles Total of 60 sec.	Fig.11.2	Photo.11.3
	Line to Earth	100 KHz/1 MHz				

Test Results:


Port/Cable Name	Damped Oscillatory Wave	Level [kV]	Frequency [MHz]	BER/ # of errors	Performance Criteria	Remarks
230 VAC	Line to Line	± 1	100 KHz/ 1 MHz	None	A	Pass
	Line to Earth	± 2.5	100 KHz/ 1 MHz	None	A	Pass
3 phase	Line to Earth	± 1	100 KHz/ 1 MHz	None	A	Pass
	Line to Earth	± 2.5	100 KHz/ 1 MHz	None	A	Pass
DO	Line to Earth	± 1	100 KHz/ 1 MHz	None	A	Pass
	Line to Earth	± 2.5	100 KHz/ 1 MHz	None	A	Pass

Заличено по чл.2 от ЗЗЛД


WPK

**Fig 11.1: Setup for Immunity to Oscillatory Waves Measurements
AC Line**

Line to Earth



Line to Line




Заличено по чл.2 от ЗЗЛД

WPK



4/11

Figure 11.2: Setup for Immunity to Oscillatory Waves Measurements DO




2

Заличено по чл.2 от ЗЗД


M

**Photograph 11.1: Immunity to Oscillatory waves measurements
230 VAC**



B

Photograph 11.2: Immunity to Oscillatory waves measurements 3 phase



Заличено по чл.2 от ЗЗЛД


[Handwritten signature]

[Handwritten signature]



Handwritten signature

Photograph 11.3: Immunity to Oscillatory waves measurements DO



Handwritten mark

Заличено по чл.2 от ЗЗЛД



Handwritten signature

Handwritten signature

Handwritten mark

12. Variations due to ambient temperature

Date of Test: 22.06.2011
Relative Humidity: 48%
Ambient Temperature: 21°C
Atmospheric Pressure: 1011.4 hPa

Test Method: IEC 60688 section 6.4

Test Levels:

Maximum allowable errors:

Parameters	25 °C	-10 °C	+55 °C
0.05In/PF 1	Reference	1.05%	0.9%
In/PF 1	Reference	1.05%	0.9%
Imax/PF 1	Reference	1.05%	0.9%
0.1In/PF 0.5ind	Reference	1.75%	1.5%
In/PF 0.5ind	Reference	1.75%	1.5%
Imax/PF 0.5ind	Reference	1.75%	1.5%

Test Procedure:

Increase the ambient temperature to the upper limit +55 °C and allow sufficient time for conditions to stabilize (30 min is usually adequate). Record the value of the **output signal**. Reduce the ambient temperature to the lower limit -10 °C and allow the same stabilization to take place. Record the value of the output signal

List of Test Equipment:


Oven, Tenny, Tenny 10

Test Details & results:

Parameters	25 °C	-10 °C	+55 °C	Test Result
0.05In/PF 1	Reference	1.05%	0.9%	Pass
In/PF 1	Reference	1.05%	0.9%	Pass
Imax/PF 1	Reference	1.05%	0.9%	Pass
0.1In/PF 0.5ind	Reference	1.75%	1.5%	Pass
In/PF 0.5ind	Reference	1.75%	1.5%	Pass
Imax/PF 0.5ind	Reference	1.75%	1.5%	Pass

Заличено по чл.2 от ЗЗЛД

Handwritten signature



Handwritten mark

Photograph 12: Variations due to ambient temperature Test



Handwritten mark

Заличено по чл.2 от ЗЗД



Handwritten signature

Handwritten signature

Handwritten mark

13. AC Voltage insulation test

Date of Test: 22.06.2011
Relative Humidity: 48%
Ambient Temperature: 21°C
Atmospheric Pressure: 1011.4 hPa

Test Method: IEC 61010-1 According to IEC 60688 section 6.19

Test Levels:

Port/Cable Name	Test Level [kV]	Test Duration [Sec.]
PH & NE to DI & RS 485	4	60
3 phase to Di & RS 485	4	60
DO to DI & RS 485	4	60

Handwritten mark

Test Procedure:

The requirements for the voltage test and other safety requirements are included in IEC 61010-1 to which reference shall be made.
The testing voltage – 4kVrms, 50Hz.
Duration of the test – 60 min.
Pass criteria: The leakage current shall not exceed 5mA.

After the test of the Meter will complete, the meter should pass the accuracy test according Table 3.

List of Test Equipment:

Quadchck II, Model: 7564SA

Test Details & results:

Port/Cable Name	Test Level [kV]	Test Duration [Sec.]	Photograph No.	Pass/Fail
PH & NE to DI & RS 485	4	60	Photo.13	Pass
3 phase to Di & RS 485	4	60		Pass
DO to DI & RS 485	4	60		Pass




Заличено по чл.2 от ЗЗЛД

Handwritten signature

Handwritten signature

M

Photograph 13: AC Voltage insulation test



2

Заличено по чл.2 от ЗЗЛД

M

[Handwritten signature and circular stamp]

477

14. Impulse Voltage tests

Date of Test: 22.06.2011
Relative Humidity: 48%
Ambient Temperature: 21°C
Atmospheric Pressure: 1011.4 hPa

Test Method: IEC 62052-11 Sec.7.3.2 & IEC 60688 Sec 6.20

Test Levels:

Port under Test	Pulse Shape Combination Wave	Peak Voltage	# of pulses	Performance Criteria
All terminals	1.2x50µs,500 Ohm	±6kV	10, each polarity	B

Test Procedure:

A peak test voltage of 6 kV in both positive and negative senses, having the standardized impulse waveform of 1,2/50 µs, shall be applied to **transducers** as follows:

- between the earth terminal and all the other terminals connected together;
- between the terminals of each circuit in turn, all other circuits being earthed.

Three positive and three negative impulses shall be applied at intervals of not less than 5 s. Any flashover (capacitance discharge) shall be considered a criterion of failure unless occurring in a component designed for such.

List of Test Equipment:

Haefely Test System, comprising of PSURGE 6.1 Mainframe
WinPATS Control S/W and WinPATS Control S/W
IP6.2 2 & 4 -wire Coupling Network
PHV30.2 1.2x50/8x20µs Combination Wave Plug-In unit


Test Details & results:

From	To	Test method reference	Generator Waveform	Photograph No.	Test Result
All Terminals connected together	RS485 & DI	Sec. 6.3.2.2	1.2x50µs,500 Ohm	Photo.14	Pass
3 Phase AC	AC 1 PH & RS485&DI&DO &Current terminals	Sec. 6.3.1.1	1.2x50µs,500 Ohm	Photo.14	Pass
1 Phase AC	AC 3 PH & RS485&DI&DO & Current terminals 3 Phase AC	Sec. 6.3.1.1	1.2x50µs,500 Ohm	Photo.14	Pass

Заличено по чл.2 от ЗЗЛД

Handwritten mark

Photograph 14: Impulse voltage test



Handwritten mark



Заличено по чл.2 от ЗЗЛД

Handwritten mark

Handwritten marks


WHL

15. Appendix

Appendix A: Auxiliary Equipment and tests results Accuracy verification.


1. Accuracy testing equipment

Three Phase Power source: CMC256-Plus – OMICRON electronics GmbH production.



[Handwritten mark]

Laptop: Lenovo T43.



[Handwritten signature]

Заличено по чл.2 от ЗЗЛД



ВЯРНО С ОРИГИНАЛА

ugh

2. The test results Pass/Fail criteria verification. (Performed by SATEC Staff)

2.1 Electrostatic Discharge test, IEC 62052-11, 7.5.2

In accordance with the Standard requirements the EUT was tested as table-top equipment, with reference voltage 230V and without any current in the current circuits (open circuit), at the beginning with Contact discharge 8 kV, and then 15 kV Air discharge 1-2 mm from EUT plastic enclosure to every point defined by QualiTech representatives, 10 negative and 10 positive pulses each type.

The standard pass criterion- *the application of the electrostatic discharge shall not produce a change in register more than x units. During the test a temporary degradation or loss of function or performance is acceptable.*

$$x = 10^n m U_n I_{max}$$

where

$n = -6$;

m is the number of measuring elements - 6;

U_n is the reference voltage in volts - 230;

I_{max} is the maximum current in amperes - 10.

i.e. $x = 0.015$.

Table 1: Energy registers reading before and after test.

Active Energy Before Test (kWh)	Active Energy After Test (kWh)	Reactive Energy Before Test (kVARh)	Reactive Energy After Test (kVARh)
20430.68	20430.68	33911.89	33911.89

The final conclusion- **PASS**



Заличено по чл.2 от ЗЗД


Handwritten signature

Handwritten signature

Handwritten mark

2.2 Immunity to Conducted disturbances induced by radio frequency fields IEC 62052-11, 7.5.5.

Figure 1. Energy measurement verification setup



In accordance with the Standard requirements, the meter under test should be monitored through the energy acceptance. The Voltages, Currents and Power Factor, which must be provided by the precision power source (Omicron CMC256+), defined by the standards and shown below in the Table 2 – Table 6. Disturbances voltage level is 10 V, and frequency range is 150 kHz to 80MHz.

The pass criterion: *during the test, the behavior of the equipment shall not be perturbed and the variation of the error shall be within the limits as specified in the relevant standards (2% as specified in IEC62053-22).*

The test was implemented on the following ports:

- 1 phase power port (230VAC).
- 3 phase power (3 phase AC).
- RS485 Port ((RS485).
- Digital Inputs (Inputs).
- Digital Outputs (Outputs).

Table2. Accuracy test for CONDUCTED DISTURBANCES on 1phase Port

L1,V	L2,V	L3,V	I1,A	I2,A	I3,A	PF	Error,%	Error limit,%	NOTE
230	230	230	5	5	5	0.5ind	0.0972	2	PASS
230	230	230	1	1	1	1	0.0492	2	PASS
230	230	230	5	5	5	1	-0.0072	2	PASS
230	230	230	10	10	10	1	0.0379	2	PASS

Заличено по чл.2 от ЗЗЛД

WTH

Table3. Accuracy test for CONDUCTED DISTURBANCES on 3phase Port

L1,V	L2,V	L3,V	I1,A	I2,A	I3,A	PF	Error,%	Error limit,%	NOTE
230	230	230	5	5	5	0.5ind	0.0492	2	PASS
230	230	230	1	1	1	1	0.0492	2	PASS
230	230	230	5	5	5	1	-0.0097	2	PASS
230	230	230	10	10	10	1	0.0381	2	PASS

Table4. Accuracy test for CONDUCTED DISTURBANCES on RS485 Port

L1,V	L2,V	L3,V	I1,A	I2,A	I3,A	PF	Error,%	Error limit,%	NOTE
230	230	230	5	5	5	0.5ind	0.0010	2	PASS
230	230	230	1	1	1	1	0.0514	2	PASS
230	230	230	5	5	5	1	0.0417	2	PASS
230	230	230	10	10	10	1	-0.0119	2	PASS

Table5. Accuracy test for CONDUCTED DISTURBANCES on Digital Inputs (DI) Port

L1,V	L2,V	L3,V	I1,A	I2,A	I3,A	PF	Error,%	Error limit,%	NOTE
230	230	230	5	5	5	0.5ind	0.0010	2	PASS
230	230	230	1	1	1	1	0.0490	2	PASS
230	230	230	5	5	5	1	-0.0075	2	PASS
230	230	230	10	10	10	1	-0.0119	2	PASS

Table6. Accuracy test for CONDUCTED DISTURBANCES on Digital Outputs (DO) Port

L1,V	L2,V	L3,V	I1,A	I2,A	I3,A	PF	Error,%	Error limit,%	NOTE
230	230	230	5	5	5	0.5ind	0.0010	2	PASS
230	230	230	1	1	1	1	0.0490	2	PASS
230	230	230	5	5	5	1	-0.0075	2	PASS
230	230	230	10	10	10	1	-0.0094	2	PASS

The final conclusion- **PASS**

Заличено по чл.2 от ЗЗЛД

W/M

2.3 Immunity to Electromagnetic RF fields IEC 62052-11, 7.5.3.

In accordance with the Standard requirements the EUT was tested as table-top equipment, with cables length, exposed to the field 1m, frequency band 80 MHz to 2000MHz, carrier modulated with 80%AM at 1kHz sine wave and was fulfilled twice-

a) with current and at the test field 10V/m and b) without current and at the test field 30V/m.

a) In accordance with the Standard requirements, the meter under test should be monitored through the energy acceptance. The Voltages, Currents and Power Factor, which must be provided by the precision power source (Omicron CMC256+), defined by the standards and shown below in the Table 7 – Table 8. (see figure 1).

The standard pass criterion- *during the test, the behaviour of the equipment shall not be perturbed and the variation of the error shall be within the limits as specified in the relevant standards (2% as specified in IEC62053-22).*

During the test (frequency step change in the above described range) all accuracy results were fixed and recorded. The results are show in tables bellow.

Table7. Accuracy test for ELECTROMAGNETIC RF FIELDS immunity. Antenna in Vertical polarization.

Frequency range, MHz	L1,V	L2,V	L3,V	I1,A	I2,A	I3,A	PF	Error,%	Error limit,%	NOTE
80-100	230	230	230	5	5	5	0.5ind	0.0010	2	PASS
	230	230	230	1	1	1	1	0.0463	2	PASS
	230	230	230	5	5	5	1	0.0441	2	PASS
	230	230	230	10	10	10	1	-0.0119	2	PASS
100-120	230	230	230	5	5	5	0.5ind	0.0010	2	PASS
	230	230	230	1	1	1	1	0.0487	2	PASS
	230	230	230	5	5	5	1	-0.0050	2	PASS
	230	230	230	10	10	10	1	-0.0119	2	PASS
120-150	230	230	230	5	5	5	0.5ind	0.0008	2	PASS
	230	230	230	1	1	1	1	0.0490	2	PASS
	230	230	230	5	5	5	1	0.0417	2	PASS
	230	230	230	10	10	10	1	-0.0122	2	PASS
150-230	230	230	230	5	5	5	0.5ind	0.0010	2	PASS
	230	230	230	1	1	1	1	0.0490	2	PASS
	230	230	230	5	5	5	1	0.0417	2	PASS
	230	230	230	10	10	10	1	-0.0122	2	PASS
230-320	230	230	230	5	5	5	0.5ind	0.0487	2	PASS
	230	230	230	1	1	1	1	0.0463	2	PASS
	230	230	230	5	5	5	1	0.0414	2	PASS
	230	230	230	10	10	10	1	-0.0119	2	PASS
320-480	230	230	230	5	5	5	0.5ind	0.0008	2	PASS
	230	230	230	1	1	1	1	0.0466	2	PASS
	230	230	230	5	5	5	1	-0.0075	2	PASS
	230	230	230	10	10	10	1	-0.0119	2	PASS
480-640	230	230	230	5	5	5	0.5ind	-0.0016	2	PASS
	230	230	230	1	1	1	1	0.0466	2	PASS
	230	230	230	5	5	5	1	-0.0102	2	PASS
	230	230	230	10	10	10	1	-0.0119	2	PASS
640-1000	230	230	230	5	5	5	0.5ind	-0.0014	2	PASS
	230	230	230	1	1	1	1	0.0490	2	PASS
	230	230	230	5	5	5	1	-0.0075	2	PASS
	230	230	230	10	10	10	1	-0.0119	2	PASS
1000-2000	230	230	230	5	5	5	0.5ind	0.0010	2	PASS
	230	230	230	1	1	1	1	0.0466	2	PASS
	230	230	230	5	5	5	1	-0.0075	2	PASS
	230	230	230	10	10	10	1	-0.0122	2	PASS



ym

Table8. Accuracy test for ELECTROMAGNETIC RF FIELDS immunity. Antenna in Horizontal polarization.

Frequency range, MHz	L1,V	L2,V	L3,V	I1,A	I2,A	I3,A	PF	Error,%	Error limit,%	NOTE
80-100	230	230	230	5	5	5	0.5ind	0.0034	2	PASS
	230	230	230	1	1	1	1	-0.0014	2	PASS
	230	230	230	5	5	5	1	-0.0075	2	PASS
	230	230	230	10	10	10	1	-0.0117	2	PASS
100-120	230	230	230	5	5	5	0.5ind	0.0010	2	PASS
	230	230	230	1	1	1	1	0.0490	2	PASS
	230	230	230	5	5	5	1	-0.0050	2	PASS
	230	230	230	10	10	10	1	-0.0119	2	PASS
120-150	230	230	230	5	5	5	0.5ind	0.0010	2	PASS
	230	230	230	1	1	1	1	0.0490	2	PASS
	230	230	230	5	5	5	1	0.0417	2	PASS
	230	230	230	10	10	10	1	-0.0119	2	PASS
150-230	230	230	230	5	5	5	0.5ind	0.0490	2	PASS
	230	230	230	1	1	1	1	0.0490	2	PASS
	230	230	230	5	5	5	1	-0.0075	2	PASS
	230	230	230	10	10	10	1	-0.0117	2	PASS
230-320	230	230	230	5	5	5	0.5ind	0.0490	2	PASS
	230	230	230	1	1	1	1	0.0466	2	PASS
	230	230	230	5	5	5	1	0.0417	2	PASS
	230	230	230	10	10	10	1	0.0379	2	PASS
320-480	230	230	230	5	5	5	0.5ind	-0.0014	2	PASS
	230	230	230	1	1	1	1	0.0490	2	PASS
	230	230	230	5	5	5	1	-0.0075	2	PASS
	230	230	230	10	10	10	1	-0.0119	2	PASS
480-640	230	230	230	5	5	5	0.5ind	0.0008	2	PASS
	230	230	230	1	1	1	1	0.0490	2	PASS
	230	230	230	5	5	5	1	-0.0099	2	PASS
	230	230	230	10	10	10	1	-0.0144	2	PASS
640-1000	230	230	230	5	5	5	0.5ind	-0.0016	2	PASS
	230	230	230	1	1	1	1	0.0514	2	PASS
	230	230	230	5	5	5	1	-0.0050	2	PASS
	230	230	230	10	10	10	1	-0.0119	2	PASS
1000-2000	230	230	230	5	5	5	0.5ind	0.0010	2	PASS
	230	230	230	1	1	1	1	0.0466	2	PASS
	230	230	230	5	5	5	1	-0.0075	2	PASS
	230	230	230	10	10	10	1	-0.0122	2	PASS

The final conclusion- **PASS**.



Заличено по чл.2 от ЗЗД

MM

b) During the test b) the setup was not changed but current source was disconnected from EUT current circuits and the EUT current terminals were open circuit. The field strength was adjusted to 30V/m and frequency was changed with step variation from 80 MHz to 2Gz in the standards defined polarizations and angles.

The standard pass criterion- *the application of the RF field shall not produce a change in register more than x units. During the test a temporary degradation or loss of function or performance is acceptable.*

$$x = 10^n m U_n I_{max}$$

where

$n = -6$;

m is the number of measuring elements - 6;

U_n is the reference voltage in volts - 230;

I_{max} is the maximum current in amperes - 10.

i.e. $x = 0.015$.

The recorded EUT Energy registers readings before and after the test were 16461.74 kWh and 1428.65 kVARh and did not change during test.

Table 9: Energy registers reading before and after test.

Active Energy Before Test (kWh)	Active Energy After Test (kWh)	Reactive Energy Before Test (kVARh)	Reactive Energy After Test (kVARh)
16461.74	16461.74	1428.65	1428.65

The final conclusion- **PASS**

Заличено по чл.2 от ЗЗЛД

Handwritten signature

2.4 Surge Immunity Test IEC 62052-11, 7.5.6.

The standard pass criterion- *the application of the surge immunity test voltage shall not produce a change in register more than x units. During the test a temporary degradation or loss of function or performance is acceptable.*

$$x = 10^n m U_n I_{max}$$

where

$n = -6$;

m is the number of measuring elements - 6;

U_n is the reference voltage in volts - 230;

I_{max} is the maximum current in amperes - 10.

i.e. $x = 0.015$.

Handwritten signature

Table 10: Energy registers reading before and after test.

Active Energy Before Test (kWh)	Active Energy After Test (kWh)	Reactive Energy Before Test (kVARh)	Reactive Energy After Test (kVARh)
16461.74	16461.74	1428.65	1428.65

The final conclusion- **PASS**

ВЯРНО С ОРИГИНАЛА



Заличено по чл.2 от ЗЗЛД

Handwritten signature

MM

2.5 Fast Transient burst Test IEC 62052-11, 7.5.4

The standard pass criterion- *during the test a temporary degradation or loss of function or performance is acceptable, nevertheless the variation of error shall be within the limits as specified in the relevant standards (2% as specified in IEC62053-22).*

The results before and after test are show in tables bellow

Table 11. Accuracy test before FAST TRANSIENT BURST TEST

L1,V	L2,V	L3,V	I1,A	I2,A	I3,A	PF	Error,%	Error limit,%	NOTE
230	230	230	5	5	5	0.5ind	0.0008	2	PASS
230	230	230	1	1	1	1	0.0490	2	PASS
230	230	230	5	5	5	1	0.0075	2	PASS
230	230	230	10	10	10	1	-0.0117	2	PASS

Table 12. Accuracy test after FAST TRANSIENT BURST TEST

L1,V	L2,V	L3,V	I1,A	I2,A	I3,A	PF	Error,%	Error limit,%	NOTE
230	230	230	5	5	5	0.5ind	0.0010	2	PASS
230	230	230	1	1	1	1	0.0512	2	PASS
230	230	230	5	5	5	1	0.0014	2	PASS
230	230	230	10	10	10	1	-0.0122	2	PASS

The final conclusion- **PASS**

ВЯРНО С ОРГИНАЛА



Заличено по чл.2 от ЗЗЛД

77

2.6 Damped Oscillatory Waves Immunity Test IEC 62052-11, 7.5.7.

The standard pass criterion- *during the test, the behavior of the equipment shall not be perturbed and the variation of the error shall be within the limits as specified in the relevant standards (2% as specified in IEC62053-22).*

The results before and after test are show in tables bellow

Table 13. Accuracy test before DAMPED OCSILLATORY WAVES IMMUNITY TEST

L1,V	L2,V	L3,V	I1,A	I2,A	I3,A	PF	Error,%	Error limit,%	NOTE
230	230	230	5	5	5	0.5ind	0.0010	2	PASS
230	230	230	1	1	1	1	0.0466	2	PASS
230	230	230	5	5	5	1	0.0050	2	PASS
230	230	230	10	10	10	1	-0.0122	2	PASS

Table 14. Accuracy test after DAMPED OCSILLATORY WAVES IMMUNITY TEST

L1,V	L2,V	L3,V	I1,A	I2,A	I3,A	PF	Error,%	Error limit,%	NOTE
230	230	230	5	5	5	0.5ind	0.0010	2	PASS
230	230	230	1	1	1	1	0.0490	2	PASS
230	230	230	5	5	5	1	-0.0075	2	PASS
230	230	230	10	10	10	1	-0.0119	2	PASS

The final conclusion- **PASS**



Заличено по чл.2 от ЗЗЛД

MM

2.7 Variation due to magnetic field of external origin IEC IEC60688, 6.11.

The standard pass criterion - *the variation of the error shall be within the limits as specified in the relevant standards (1% as specified in IEC 62053-22 8.2).*

The results before and during test are show in tables bellow

Table 15. Accuracy test before Variation due to magnetic field of external origin test

L1,V	L2,V	L3,V	I1,A	I2,A	I3,A	PF	Error,%	Error limit,%	NOTE
230	230	230	5	5	5	0.5ind	0.2898	1	PASS
230	230	230	1	1	1	1	0.0974	1	PASS
230	230	230	5	5	5	1	-0.0561	1	PASS
230	230	230	10	10	10	1	-0.0612	1	PASS

Table 16. Accuracy test during Variation due to magnetic field of external origin, EM133 horizontal to a coil

L1,V	L2,V	L3,V	I1,A	I2,A	I3,A	PF	Error,%	Error limit,%	NOTE
230	230	230	5	5	5	0.5ind	0.2898	1	PASS
230	230	230	1	1	1	1	0.0495	1	PASS
230	230	230	5	5	5	1	-0.1052	1	PASS
230	230	230	10	10	10	1	-0.0612	1	PASS


Table 17. Accuracy test before Variation due to magnetic field of external origin test, EM133 vertical to a coil

L1,V	L2,V	L3,V	I1,A	I2,A	I3,A	PF	Error,%	Error limit,%	NOTE
230	230	230	5	5	5	0.5ind	0.2898	1	PASS
230	230	230	1	1	1	1	0.0492	1	PASS
230	230	230	5	5	5	1	-0.0561	1	PASS
230	230	230	10	10	10	1	-0.0614	1	PASS

Table 18. Accuracy test during Variation due to magnetic field of external origin, EM133 tilt to a coil

L1,V	L2,V	L3,V	I1,A	I2,A	I3,A	PF	Error,%	Error limit,%	NOTE
230	230	230	5	5	5	0.5ind	0.2896	1	PASS
230	230	230	1	1	1	1	0.0495	1	PASS
230	230	230	5	5	5	1	-0.0564	1	PASS
230	230	230	10	10	10	1	-0.0614	1	PASS

The final conclusion- **PASS**



MM

2.8 Variation due to ambient temperature, IEC60688, 6.4.

The standard pass criterion - According to IEC 62053-22 8.2 there are the following max allowable errors:

	25 °C	-10 °C	+55 °C
0.05In/PF 1	Reference	1.05%	0.9%
In/PF 1	Reference	1.05%	0.9%
I _{max} /PF 1	Reference	1.05%	0.9%
0.1In/PF 0.5ind	Reference	1.75%	1.5%
In/PF 0.5ind	Reference	1.75%	1.5%
I _{max} /PF 0.5ind	Reference	1.75%	1.5%

The results during test are show in tables bellow

Table 19. Accuracy test Variation due to ambient temperature test at 25 °C

L1,V	L2,V	L3,V	I1,A	I2,A	I3,A	PF	Error,%	Error limit,%	NOTE
230	230	230	0.25	0.25	0.25	1	0.0459	1	PASS
230	230	230	5	5	5	1	-0.0075	1	PASS
230	230	230	10	10	10	1	0.0379	1	PASS
230	230	230	0.5	0.5	0.5	0.5ind	0.1770	1	PASS
230	230	230	5	5	5	0.5ind	-0.0313	1	PASS
230	230	230	10	10	10	0.5ind	-0.0991	1	PASS

Table 20. Accuracy test Variation due to ambient temperature test at -10 °C

L1,V	L2,V	L3,V	I1,A	I2,A	I3,A	PF	Error,%	Error limit,%	NOTE
230	230	230	0.25	0.25	0.25	1	-0.2037	1.05	PASS
230	230	230	5	5	5	1	0.0916	1.05	PASS
230	230	230	10	10	10	1	-0.0882	1.05	PASS
230	230	230	0.5	0.5	0.5	0.5ind	0.2742	1.75	PASS
230	230	230	5	5	5	0.5ind	0.0733	1.75	PASS
230	230	230	10	10	10	0.5ind	0.0323	1.75	PASS

Table 21. Accuracy test Variation due to ambient temperature test at +55 °C

L1,V	L2,V	L3,V	I1,A	I2,A	I3,A	PF	Error,%	Error limit,%	NOTE
230	230	230	0.25	0.25	0.25	1	0.2069	0.9	PASS
230	230	230	5	5	5	1	0.1394	0.9	PASS
230	230	230	10	10	10	1	0.0870	0.9	PASS
230	230	230	0.5	0.5	0.5	0.5ind	0.4338	1.5	PASS
230	230	230	5	5	5	0.5ind	-0.0125	1.5	PASS
230	230	230	10	10	10	0.5ind	-0.1432	1.5	PASS

The final conclusion- **PASS**

Заличено по чл.2 от ЗЗЛД

Handwritten initials

2.9 Insulation tests, IEC 62052-11, 7.3, IEC60688, 6.20.

Impulse voltage test (6kV) IEC 62052-11, 7.3.2, IEC 60688, 6.20 and AC voltage Insulation test (4kVAC) IEC 62052-11, 7.3.3

The standard pass criterion: The device inspection after the tests: there shall be no change at reference conditions in the percentage error of the meter greater than defined in the relevant standard and no functional and mechanical damage to the equipment.

In Table18 given percentage error limits as specified in IEC 62053-22 8.2

Table 18 – Percentage error limits (single-phase meters and polyphase meters with balanced loads)

Value of current	Power factor	Percentage error limits for meters of class	
		0,2 S	0,5 S
$0,01 I_n \leq I < 0,05 I_n$	1	±0,4	±1,0
$0,05 I_n \leq I \leq I_{max}$	1	±0,2	±0,5
$0,02 I_n \leq I < 0,1 I_n$	0,5 inductive	±0,5	±1,0
	0,8 capacitive	±0,5	±1,0

The results after Insulation tests are show in table 19

Table19. Accuracy test after Insulation tests

L1,V	L2,V	L3,V	I1,A	I2,A	I3,A	PF	Error,%	Error limit,%	NOTE
230	230	230	0.05	0.05	0.05	1	-0.2453	1	PASS
230	230	230	0.25	0.25	0.25	1	-0.0489	1	PASS
230	230	230	5	5	5	1	-0.0225	0.5	PASS
230	230	230	10	10	10	1	-0.0401	0.5	PASS
230	230	230	0.1	0.1	0.1	0.5ind	0.0741	1	PASS
230	230	230	0.5	0.5	0.5	0.5ind	0.1716	1	PASS
230	230	230	5	5	5	0.5ind	-0.0161	1	PASS
230	230	230	10	10	10	0.5ind	-0.0951	1	PASS
230	230	230	0.1	0.1	0.1	0.8cap	-0.1447	1	PASS
230	230	230	0.5	0.5	0.5	0.8cap	0.0016	1	PASS
230	230	230	5	5	5	0.8cap	0.0018	1	PASS
230	230	230	10	10	10	0.8cap	-0.0334	1	PASS

The final conclusion- **PASS**




Заличено по чл.2 от ЗЗЛД

MM

Appendix B: Abbreviations/ Glossary used in the test report

AC	Alternating Current	ISN	Impedance stabilization network
AVR	Average (Detector)	LISN	Line Impedance Stabilization Network
A/m	Ampere per meter	m	Meter
AE	Auxiliary equipment	MHz	Megahertz
AM	Amplitude modulation	NA	Not Applicable
cm	Centimeter	QP	Quasi-Peak (Detector)
CE	Conducted Emission	Ω	Ohm
CI	Conducted Immunity	PM	Pulse modulation
dB	Decibel	PC	Personal Computer
dBm	Decibel referred to one Mill watt	RF	Radio Frequency
dB(μ V)	Decibel referred to one micro volt	RE	Radiated Emission
dB(μ V/m)	Decibel referred to one micro volt per meter	RI	Radiated Immunity
DC	Direct Current	rms	Root-mean-square
ESD	Electrostatic Discharge	sec	Second
EFT	Electrical Fast Transients	SA	Spectrum analyzer
EMC	Electromagnetic Compatibility	Transceiver	Transmitter -receiver
EMI	Electromagnetic Immunity	V	Volt
EN	European Standard	VCP	Vertical coupling plane
EUT	Equipment under test	W	Watt
F/O	Fiber optic		
GHz	Gigahertz		
Hz	Hertz		
HCP	Horizontal Coupling Plane		
kHz	Kilohertz		
kV	Kilovolt		

2



Заличено по чл.2 от ЗЗЛД

WV

Appendix C: Accreditation Certificate



The American Association for Laboratory Accreditation
World Class Accreditation

Accredited Laboratory
A2LA has accredited
QUALITECH (ECI TELECOM)
Petach-Tikva, ISRAEL
for technical competence in the field of
Electrical Testing

This laboratory is accredited in accordance with the recognized International Standard ISO/IEC 17025:2005 *General Requirements for the Competence of Testing and Calibration Laboratories*. This accreditation demonstrates technical competence for a defined scope and the operation of a laboratory quality management system (refer to joint ISO-ILAC-IAP Communiqué dated 8 January 2009).

Presented this 22nd day of March 2011.



Заличено по чл.2 от ЗЗЛД
President & CEO
For the Accreditation Council
Certificate Number 1633.01
Valid to September 30, 2012

For the tests or types of tests to which this accreditation applies, please refer to the laboratory's Electrical Scope of Accreditation.

(Handwritten mark)




Заличено по чл.2 от ЗЗЛД

W/M

End of the Test Report

Заличено по чл.2 от ЗЗЛД



MH

Declaration of Conformity

The Manufacturer SATEC LTD.
HAR HOTZVIM PARK
POB 45022 Jerusalem 91450 ISRAEL

According to EN.ISO/IEC 17050-1:2010 and EN.ISO/IEC 17050-2:2006, do hereby declare under our sole responsibility that the following products:

EM 133 series

Confirm to the provisions of the following Standards and Directives applying to them:

- EN 50022 -Specification for low voltage switchgear and controlgear for industrial use. Mounting rails. Top hat rails 35 mm wide for snap-on mounting of equipment.
- EN 61000-4-2 Level 4 - Electromagnetic compatibility (EMC). Testing and measurement techniques. Electrostatic discharge immunity test.
- EN 61000-4-3 Level 3 - Electromagnetic compatibility (EMC) - Part 4-3: Testing and measurement techniques - Radiated, radio-frequency,electromagnetic field immunity test
- EN 61000-4-4 Level 4 - Electromagnetic compatibility (EMC) - Part 4-4: Testing and measurement techniques - Electrical fast transient/burst immunity test
- EN 61000-4-5 - Electromagnetic compatibility (EMC) - Part 4-5: Testing and measurement techniques - Surge immunity test
- EN 61000-4-8 Level 4 - Electromagnetic compatibility (EMC) - Part 4-8: Testing and measurement techniques - Power frequency magnetic field immunity test
- EN 61000-4-12 Level 3-4 - Electromagnetic compatibility (EMC). Testing and measurement techniques. Oscillatory waves immunity test. Basic EMC publication
- EN 60688 - Electrical measuring transducers for converting A.C. and D.C. electrical quantities to analogue or digital signals
- EN 61010 - Safety requirements for electrical equipment for measurement, control, and laboratory use
- EN 60529 - Degrees of protection provided by enclosures (IP Code)
- EN 60068-2-1/-2/-3 - Environmental testing

Michael Katz
Regional Sales Engineer| SATEC LTD

Заличено по чл.2 от ЗЗЛД

Date.....

18.03.2018



Заличено по чл.2 от ЗЗЛД

אזור תעשייה הר חוצבים, רח' המרפא 7
ת"ד 46022 ירושלים 91450

טל' 02-5411000 פקס 02-5812371 www.satec-global.com

Har Hotzvim Industrial Park, 7 Hamarpe St.
POB 45022 Jerusalem 91450 Israel

Tel. +972-2-5411000 Fax +972-2-5812371 satec@satec-global.com

CERTIFICATE

This is to certify that the Quality Management System of

SATEC LTD.

7, Hamarphe St. , Jerusalem , Israel

Has been audited and registered by SII-QCD as conforming to the requirements of

ISO 9001:2015

This Certificate is Applicable to

Design, development & manufacture of electronic instruments & systems for electrical energy measurement management & control.

Certificate No.:

81696

Certificate Issue Date:

25/07/2016

Initial Certification Date:

13/12/2009

Certification Expiry Date:

12/01/2019

SII-QCD assumes no liability to any party other than the client, and then only in accordance with the agreed upon Certification Agreement. This certificate's validity is subject to the organization maintaining their system in accordance with SII-QCD requirements for system certification. The continued validity may be verified via scanning the code with a smartphone, or via website www.sii.org.il. This certificate remains the property of SII-QCD.

Заличено по чл.2 от ЗЗЛД

Deputy Director General



Director, Quality & Certification Division

Заличено по чл.2 от ЗЗЛД



STANDARDS INSTITUTION OF ISRAEL





הרשות הלאומית להסמכת מעבדות
Israel Laboratory Accreditation Authority

ISO/IEC 17025: 2005

Calibration Laboratory

Accreditation Certificate No. 357

SATEC Calibration Lab.

Main site (Main Laboratory): Zeev Lev 25, Jerusalem, 9145001, Israel

Valid from: 20.11.2016

Until: 19.11.2018

The organization was assessed by the Israel Laboratory Accreditation Authority (ISRAC) and found to be worthy of accreditation to the detailed schedule attached. The schedule is an integral part of this certificate and is numbered with the above certificate number .

Accreditation demonstrates technical competence and operation of an internationally recognized quality management system. The organization accredited by ISRAC complies with the standards/requirements mentioned above, meets the technical competence requirements and management system requirements that are necessary for it to consistently deliver technically competent results.

This accreditation is granted in accordance with the requirements of ISO/IEC 17011:2004, and entails periodic surveillance and reassessment by ISRAC to ensure that the organization continues to comply with the accreditation requirements.

The accreditation is valid provided that the organization continues to meet the criteria as laid down by ISRAC.

This certificate does not constitute an approval in accordance with article 12 of the standard law.

Date of first accreditation: 20.11.2016



Заличено по чл.2 от ЗЗЛД

General Manager

Israel Laboratory Accreditation Authority

Version 1